

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|--------------|--------------|------------------------|--|------------|---------------------|--------------------|------------------|---|--------------|--------------------------|----------------------|---|-----------|-----------------------|
| Ambulatory Care - Pediatrics | | | | | | | | | | | | | | | |
| Exam/ Treatment Modules (ETM) | EXRG3 | 6 | Exam Room | | | | | | | | | | | | |
| Exam/ Treatment Modules (ETM) | EXRG3 | 6 | Exam Room | 3G203, 3G204, 3G205, 3G212, 3G213, 3G214 | | 2/20/2014 | | CASP306 | CART, SPECIALTY | 1 | VV | | CUT SHEET IS FROM 2001, IS THE INFORMATION STILL ACCURATE? | 6 | 0 |
| Exam/ Treatment Modules (ETM) | EXRG3 | 6 | Exam Room | 3G203, 3G204, 3G205, 3G212, 3G213, 3G214 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 6 | 1 |
| Exam/ Treatment Modules (ETM) | EXRG3 | 6 | Exam Room | 3G203, 3G204, 3G205, 3G212, 3G213, 3G214 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 6 | |
| Exam/ Treatment Modules (ETM) | EXRG3 | 6 | Exam Room | 3G203, 3G204, 3G205, 3G212, 3G213, 3G214 | | 2/20/2014 | | COSH321 | CONTAINER, SHARPS, 2 GALLON | 1 | VC | | TWO MODELS LISTED, PLEASE CONFIRM WE ARE USING 8509SA (W/O GLOVE BOX) NEED PRODUCT WEIGHT | 6 | 1 |
| Exam/ Treatment Modules (ETM) | EXRG3 | 6 | Exam Room | 3G203, 3G204, 3G205, 3G212, 3G213, 3G214 | | 2/20/2014 | | COST300 | COMPUTER STATION, WALL MOUNT | 1 | VC | | WAITING ON PRODUCT SELECTION - NEED DIMENSIONS, WEIGHT, AND POWER / DATA REQUIREMENTS | 6 | |
| Exam/ Treatment Modules (ETM) | EXRG3 | 6 | Exam Room | 3G203, 3G204, 3G205, 3G212, 3G213, 3G214 | | 2/20/2014 | | COST320 | MOBILE WORKSTATION, KIDNEY SHAPED TABLE | | | | | 6 | 0 |
| Exam/ Treatment Modules (ETM) | EXRG3 | 6 | Exam Room | 3G203, 3G204, 3G205, 3G212, 3G213, 3G214 | | 2/20/2014 | | DIGL300 | DISPENSER, GLOVE, 3 BOX | 1 | VC | | | 6 | 0 |
| Exam/ Treatment Modules (ETM) | EXRG3 | 6 | Exam Room | 3G203, 3G204, 3G205, 3G212, 3G213, 3G214 | | | | FURN140 | CHAIR, BARIATRIC | 1 | VV | F | | 6 | 0 |
| Exam/ Treatment Modules (ETM) | EXRG3 | 6 | Exam Room | 3G203, 3G204, 3G205, 3G212, 3G213, 3G214 | | 2/20/2014 | | MOBP302 | MONITOR WITH STAND, BLOOD PRESSURE | 2 | VV | | NEED DIMENSIONS, WEIGHT, POWER REQUIREMENTS | 12 | |
| Exam/ Treatment Modules (ETM) | EXRG3 | 6 | Exam Room | 3G203, 3G204, 3G205, 3G212, 3G213, 3G214 | | 2/20/2014 | | MOBP305 | MONITOR, BLOOD PRESSURE, WALL MOUNTED | 1 | VV | | NEED DIMENSIONS, WEIGHT, POWER REQUIREMENTS | 6 | |
| Exam/ Treatment Modules (ETM) | EXRG3 | 6 | Exam Room | 3G203, 3G204, 3G205, 3G212, 3G213, 3G214 | | 1/31/2014 | | OTOP300 | OPHTHALMOSCOPE/OTOSCOPE, WALL BOARD | 1 | VC | | WHICH MODEL NUMBER AND ACCESSORY MODULES? (SEE EQRA300 FOR MOUNTING) | 6 | |
| Exam/ Treatment Modules (ETM) | EXRG3 | 6 | Exam Room | 3G203, 3G204, 3G205, 3G212, 3G213, 3G214 | | 1/31/2014 | | PRIN300 | PRINTER, LASER | 1 | VV | | ORIGINAL CUT SHEET RECEIVED LATER DECIDED WAS INCORRECT | 6 | 0 |
| Exam/ Treatment Modules (ETM) | EXRG3 | 6 | Exam Room | 3G203, 3G204, 3G205, 3G212, 3G213, 3G214 | | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | | 6 | |
| Exam/ Treatment Modules (ETM) | EXRG2 | 6 | Exam Room | 3G203, 3G204, 3G205, 3G212, 3G213, 3G213 | | 3/7/2014 | | SCST320 | SCALE, PEDIATRIC, STAND ON | 1 | VV | | NEED POWER & DATA REQUIREMENTS | 6 | |
| Exam/ Treatment Modules (ETM) | EXRG3 | 6 | Exam Room | 3G203, 3G204, 3G205, 3G212, 3G213, 3G214 | | | | SCBA500 | SCALE, BABY | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" (COUNTERTOP) | 6 | |
| Exam/ Treatment Modules (ETM) | EXRG3 | 6 | Exam Room | 3G203, 3G204, 3G205, 3G212, 3G213, 3G214 | | | | SPHY306 | SPHYGMOMANOMETER, HAND HELD | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" (SEE EQRA300 FOR MOUNTING) | 6 | |
| Exam/ Treatment Modules (ETM) | EXRG3 | 6 | Exam Room | 3G203, 3G204, 3G205, 3G212, 3G213, 3G214 | | | | STDO350 | STOOL, DR. WITHOUT ARMS, ADJUSTABLE | 1 | VV | No | | 6 | |
| Exam/ Treatment Modules (ETM) | EXRG3 | 6 | Exam Room | 3G203, 3G204, 3G205, 3G212, 3G213, 3G214 | | | | MOVI300 | V-TEL SYSTEM - SMART TV / MONITOR WITH CISCO SYSTEM | 1 | VV | | | 6 | |
| Exam/ Treatment Modules (ETM) | EXRG3 | 6 | Exam Room | 3G203, 3G204, 3G205, 3G212, 3G213, 3G214 | | 2/20/2014 | | TAEX302 | TABLE, EXAM, POWER | 1 | VV | | SHOULD THIS BE CHANGED TO TAEX305? | 6 | 1 |
| Exam/ Treatment Modules (ETM) | EXRG3 | 6 | Exam Room | 3G203, 3G204, 3G205, 3G212, 3G213, 3G214 | | 2/20/2014 | | TAEX305 | TABLE, PEDIATRIC EXAM, POWER | 1 | VV | | WHICH ROOMS WILL HAVE THE INFANT EXAM TABLES? | ? | 18 |
| Ambulatory Care - Pediatrics | MEDP1 | 1 | Medication Room | | | | | | | | | | | | |
| Ambulatory Care - Pediatrics | MEDP1 | 1 | Medication Room | 3G216 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | |
| Ambulatory Care - Pediatrics | MEDP1 | 1 | Medication Room | 3G216 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | 1 |
| Ambulatory Care - Pediatrics | MEDP1 | 1 | Medication Room | 3G216 | | 2/20/2014 | | COSH321 | CONTAINER, SHARPS, 2 GALLON | 1 | VC | | TWO MODELS LISTED, PLEASE CONFIRM WE ARE USING 8509SA (W/O GLOVE BOX) NEED PRODUCT WEIGHT | 1 | 1 |
| Ambulatory Care - Pediatrics | MEDP1 | 1 | Medication Room | 3G216 | | 2/20/2014 | | DIGL300 | DISPENSER, GLOVE, 3 BOX | 1 | VC | | | 1 | |
| Ambulatory Care - Pediatrics | MEDP1 | 1 | Medication Room | 3G216 | | 1/31/2014 | | MEST330 | MEDICATION, STATION | 1 | VC | | WHAT IS THE MODEL NUMBER FOR THE SECOND PIECE OF EQUIPMENT AS INDICATED? | 1 | |
| Ambulatory Care - Pediatrics | MEDP1 | 1 | Medication Room | 3G216 | | | | MEST330A | SEISMIC BRACKET FOR ACUDOSE RX | 1 | VC | - | | 1 | |
| Ambulatory Care - Pediatrics | MEDP1 | 1 | Medication Room | 3G216 | | 1/31/2014 | | PRIN300 | PRINTER, LASER | 1 | VV | | ORIGINAL CUT SHEET RECEIVED LATER DECIDED WAS INCORRECT | 1 | |
| Ambulatory Care - Pediatrics | MEDP1 | 1 | Medication Room | 3G216 | | 1/31/2014 | | REUC325 | REFRIGERATOR, FREEZER, UNDERCOUNTER, ADA | 1 | VV | | | 1 | |
| Ambulatory Care - Pediatrics | MEDP1 | 1 | Medication Room | 3G216 | | | | REUC325A | TEMPERATURE ALARM WITH PROBE | 1 | VV | - | | 1 | 0 |
| Ambulatory Care - Pediatrics | MEDP1 | 1 | Medication Room | 3G216 | | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | | 1 | |
| Ambulatory Care - Pediatrics | MEDP1 | 1 | Medication Room | 3G216 | | 1/31/2014 | | SYME301 | OMNIRX TWO CELL / SUPPLIER | 1 | VV | | NEED MODEL NUMBER | 1 | |
| Ambulatory Care - Pediatrics | MEDP1 | 1 | Medication Room | 3G216 | | | | SYME301A | INSTALLATION, SEISMIC RESTRAINT | 1 | VV | - | | 1 | 1 |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|------------------------------|--------------|----------|-------------------|------------|---------------------|--------------------|------------------|---|--------------|--------------------------|----------------------|--|-----------|-----------------------|
| 32 | Ambulatory Care - Pediatrics | MEDP1 | 1 | Medication Room | 3G216 | 2/20/2014 | | WAPH300 | WASTE, PHARMACEUTICAL, 2 GAL | 1 | VV | | NEED DIMENSIONS & WEIGHT | 1 | |
| 33 | Ambulatory Care - Pediatrics | OFA02 | 1 | Office | | | | | | | | | | 1 | |
| 34 | Ambulatory Care - Pediatrics | OFA02 | 1 | Office | 3G301 | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | |
| 35 | Ambulatory Care - Pediatrics | OFA02 | 1 | Office | 3G301 | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | 0 |
| 36 | Ambulatory Care - Pediatrics | OFA02 | 1 | Office | 3G301 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 1 | VV | F | | 1 | 0 |
| 37 | Ambulatory Care - Pediatrics | OFA02 | 1 | Office | 3G301 | | | FURN110 | CHAIR, NO ARMS | 2 | VV | F | | 2 | 0 |
| 38 | Ambulatory Care - Pediatrics | OFA02 | 1 | Office | 3G301 | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 1 | | F | | 1 | |
| 39 | Ambulatory Care - Pediatrics | OFA02 | 1 | Office | 3G301 | 1/31/2014 | | PRIN300 | PRINTER, LASER | 1 | VV | | ORIGINAL CUT SHEET RECEIVED LATER DECIDED WAS INCORRECT | 1 | 0 |
| 40 | Ambulatory Care - Pediatrics | OFA02 | 1 | Office | 3G301 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 1 | |
| 41 | Ambulatory Care - Pediatrics | OFDC3 | 1 | Consult | | | | | | | | | ROOM OMITTED WITH CLINIC REDESIGN | 1 | |
| 42 | Ambulatory Care - Pediatrics | OFDC3 | 1 | Consult | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 2 | |
| 43 | Ambulatory Care - Pediatrics | OFDC3 | 1 | Consult | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 2 | 0 |
| 44 | Ambulatory Care - Pediatrics | OFDC3 | 1 | Consult | | 2/20/2014 | | COST305 | COMPUTER STATION, WALL MOUNT | 1 | VC | | WAITING ON PRODUCT SELECTION - NEED DIMENSIONS, WEIGHT, AND POWER / DATA REQUIREMENTS | 2 | |
| 45 | Ambulatory Care - Pediatrics | OFDC3 | 1 | Consult | | 2/20/2014 | | COST320 | MOBILE WORKSTATION, KIDNEY SHAPED TABLE | 1 | VV | | | 2 | 0 |
| 46 | Ambulatory Care - Pediatrics | OFDC3 | 1 | Consult | | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 1 | VV | F | | 2 | |
| 47 | Ambulatory Care - Pediatrics | OFDC3 | 1 | Consult | | 1/31/2014 | | PRIN300 | PRINTER, LASER | 1 | VV | | ORIGINAL CUT SHEET RECEIVED LATER DECIDED WAS INCORRECT | 2 | 0 |
| 48 | Ambulatory Care - Pediatrics | OFDC3 | 1 | Consult | | | | MOVI300 | V-TEL SYSTEM - SMART TV / MONITOR WITH CISCO SYSTEM | 1 | VV | | | 2 | |
| 48 | Ambulatory Care - Pediatrics | OFDC3 | 1 | Consult | | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 2 | 1 |
| 49 | Ambulatory Care - Pediatrics | RECP1 | 1 | Central Reception | | | | | | | | | | 1 | |
| 50 | Ambulatory Care - Pediatrics | RECP1 | 1 | Central Reception | 3G208 | 2/20/2014 | | BISH300 | BIN, SHRED | 1 | VV | | | 1 | 1 |
| 51 | Ambulatory Care - Pediatrics | RECP1 | 1 | Central Reception | 3G208 | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | |
| 52 | Ambulatory Care - Pediatrics | RECP1 | 1 | Central Reception | 3G208 | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 2 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 2 | 0 |
| 53 | Ambulatory Care - Pediatrics | RECP1 | 1 | Central Reception | 3G208 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 2 | VV | F | | 2 | |
| 54 | Ambulatory Care - Pediatrics | RECP1 | 1 | Central Reception | 3G208 | 1/31/2014 | | PRMF301 | PRINTER, MULTI-FUNCTION | 1 | VV | | PRMF301 & COPI300 LISTED ON SAME CUT SHEET WITH ONLY ONE XEROX MODEL CALLED OUT - SIZE DOES NOT WORK IN MOST PRMF301 LOCATIONS | 1 | 0 |
| 55 | Ambulatory Care - Pediatrics | RECP1 | 1 | Central Reception | 3G208 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 2 | VV | No | | 2 | |
| 56 | Ambulatory Care - Pediatrics | SL002 | 1 | Teamlet Workroom | | | | | | | | | | 1 | |
| 57 | Ambulatory Care - Pediatrics | SL002 | 1 | Teamlet Workroom | 3G310 | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | |
| 58 | Ambulatory Care - Pediatrics | SL002 | 1 | Teamlet Workroom | 3G310 | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 8 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 8 | 0 |
| 58 | Ambulatory Care - Pediatrics | SL002 | 1 | Teamlet Workroom | 3G311 | | | MOPT300 | MONITOR, PATIENT TRACKING | 1 | VV | | **NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN** | 1 | 0 |
| 59 | Ambulatory Care - Pediatrics | SL002 | 1 | Teamlet Workroom | 3G311 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 8 | VV | F | | 8 | 0 |
| 60 | Ambulatory Care - Pediatrics | SL002 | 1 | Teamlet Workroom | 3G312 | | | FURN242 | WORKSTATION, 2'-0" X 4'-0" | 6 | VV | F | | 2 | |
| 61 | Ambulatory Care - Pediatrics | SL002 | 1 | Teamlet Workroom | 3G313 | | | FURN250 | WORKSTATION, 2'-0" X 6'-0" | 2 | VV | F | | 6 | |
| 62 | Ambulatory Care - Pediatrics | SL002 | 1 | Teamlet Workroom | 3G314 | | | HAMP301 | HAMPER, WITH LID, 32" | 2 | VV | No | | 2 | 0 |
| 63 | Ambulatory Care - Pediatrics | SL002 | 1 | Teamlet Workroom | 3G315 | 1/31/2014 | | PRMF301 | PRINTER, MULTI-FUNCTION | 1 | VV | | PRMF301 & COPI300 LISTED ON SAME CUT SHEET WITH ONLY ONE XEROX MODEL CALLED OUT - SIZE DOES NOT WORK IN MOST PRMF301 LOCATIONS | 1 | |
| 64 | Ambulatory Care - Pediatrics | SL002 | 1 | Teamlet Workroom | 3G316 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 4 | VV | No | | 4 | |
| 65 | Ambulatory Care - Pediatrics | SL002 | 1 | Teamlet Workroom | 3G317 | 1/31/2014 | 2/20/2014 | SYME302 | OMNIRX THREE CELL / SUPPLIER | 2 | VV | | NEED MODEL NUMBER | 2 | |
| 66 | Ambulatory Care - Pediatrics | SL002 | 1 | Teamlet Workroom | 3G318 | | | SYME302A | INSTALLATION, SEISMIC RESTRAINT | 2 | VV | - | | 2 | 1 |
| 67 | Ambulatory Care - Pediatrics | SL002A | 1 | Team Work Area | | | | | | | | | | 0 | |
| 68 | Ambulatory Care - Pediatrics | SL002A | 1 | Team Work Area | 3G304 | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | 0 |
| 69 | Ambulatory Care - Pediatrics | SL002A | 1 | Team Work Area | 3G304 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 8 | VV | F | | 8 | 0 |
| 70 | Ambulatory Care - Pediatrics | SL002A | 1 | Team Work Area | 3G304 | | | FURN330 | TABLE, RECTANGLE, 8 PERSON | 1 | VV | F | | 1 | |
| 71 | Ambulatory Care - Pediatrics | SL002A | 1 | Team Work Area | 3G304 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 1 | 1 |
| 72 | Ambulatory Care - Pediatrics | SL002B | 1 | Team Work Area | | | | | | | | | | | |
| 73 | Ambulatory Care - Pediatrics | SL002B | 1 | Team Work Area | 3G306 | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | 0 |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| | EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/ Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|-----|--|-----------|--------------|---------------------------|--------------|------------|---------------------|--------------------|------------------|---|--------------|---------------------------|----------------------|---|-----------|-----------------------|
| 74 | Ambulatory Care - Pediatrics | SL002B | 1 | Team Work Area | 3G306 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 6 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 6 | 0 |
| 75 | Ambulatory Care - Pediatrics | SL002B | 1 | Team Work Area | 3G306 | | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 6 | VV | F | | 6 | |
| 76 | Ambulatory Care - Pediatrics | SL002B | 1 | Team Work Area | 3G306 | | | | FURN242 | WORKSTATION, 2'-0" X 4'-0" | 6 | VV | F | | 6 | 0 |
| 77 | Ambulatory Care - Pediatrics | SL002B | 1 | Team Work Area | 3G306 | | 1/31/2014 | | PRIN300 | PRINTER, LASER | 1 | VV | | ORIGINAL CUT SHEET RECEIVED LATER DECIDED WAS INCORRECT | 1 | |
| 78 | Ambulatory Care - Pediatrics | SL002B | 1 | Team Work Area | 3G306 | | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 1 | |
| 79 | Ambulatory Care - Pediatrics | SRS01 | 1 | Storage Medical Equipment | | | | | | | | | | | | |
| 80 | Ambulatory Care - Pediatrics | SRS01 | 1 | Storage Medical Equipment | 3G302 | | | | CASU313 | CART, SUPPLY 48X24 | 2 | VV | NO | | 2 | |
| 81 | Ambulatory Care - Pediatrics | SRS01 | 1 | Alcove, Equipment | | | | | | | | | | | | |
| 82 | Ambulatory Care - Pediatrics | SRS01 | 1 | Alcove, Equipment | 3G219 | | | | CASU313 | CART, SUPPLY 48X24 | 2 | VV | NO | | 2 | 1 |
| 83 | Ambulatory Care - Pediatrics | TLTU1 | 1 | Toilet, Public | | | | | | | | | | | | 0 |
| 84 | Ambulatory Care - Pediatrics | TLTU1 | 1 | Toilet, Public | 3G209 | | 2/20/2014 | | BACH300 | BABY CHANGING STATION | 1 | VV | | REFER TO SCHEDULE B | 1 | |
| 85 | Ambulatory Care - Pediatrics | TLTU1 | 1 | Toilet, Public | 3G209 | | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | | 1 | 0 |
| 86 | Ambulatory Care - Pediatrics | TLTU1 | 2 | Toilet, Patient | | | | | | | | | | | | |
| 87 | Ambulatory Care - Pediatrics | TLTU1 | 2 | Toilet, Patient | 3G202, 3G218 | | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | | 2 | 1 |
| 88 | Ambulatory Care - Pediatrics | TRGM1 | 1 | Procedure Room | | | | | | | | | | | | |
| 89 | Ambulatory Care - Pediatrics | TRGM1 | 1 | Procedure Room | 3G217 | | 2/20/2014 | | CASP306 | CART, SPECIALTY | 1 | VV | | CUT SHEET IS FROM 2001, IS THE INFORMATION STILL ACCURATE? | 1 | 1 |
| 89 | Ambulatory Care - Pediatrics | TRGM1 | 1 | Procedure Room | 3G217 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | 0 |
| 90 | Ambulatory Care - Pediatrics | TRGM1 | 1 | Procedure Room | 3G217 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | 1 |
| 90 | Ambulatory Care - Pediatrics | TRGM1 | 1 | Procedure Room | 3G217 | | 2/20/2014 | | COST300 | COMPUTER STATION, WALL MOUNT | 1 | VC | | WAITING ON PRODUCT SELECTION - NEED DIMENSIONS, WEIGHT, AND POWER / DATA REQUIREMENTS | 1 | |
| 90 | Ambulatory Care - Pediatrics | TRGM1 | 1 | Procedure Room | 3G217 | | 2/20/2014 | | COST320 | MOBILE WORKSTATION, KIDNEY SHAPED TABLE | | | | | 1 | 0 |
| 91 | Ambulatory Care - Pediatrics | TRGM1 | 1 | Procedure Room | 3G217 | | 2/20/2014 | | COSH321 | CONTAINER, SHARPS, 2 GALLON | 1 | VC | | TWO MODELS LISTED, PLEASE CONFIRM WE ARE USING 8509SA (W/O GLOVE BOX) NEED PRODUCT WEIGHT | 1 | 0 |
| 92 | Ambulatory Care - Pediatrics | TRGM1 | 1 | Procedure Room | 3G217 | | 2/20/2014 | | DIGL300 | DISPENSER, GLOVE, 3 BOX | 1 | VC | | | 1 | 0 |
| 93 | Ambulatory Care - Pediatrics | TRGM1 | 1 | Procedure Room | 3G217 | | | | FURN110 | CHAIR, NO ARMS | 1 | VV | F | | 1 | |
| 94 | Ambulatory Care - Pediatrics | TRGM1 | 1 | Procedure Room | 3G217 | | | | FURN242 | WORKSTATION 2'X4' | 1 | VV | F | | 1 | |
| 95 | Ambulatory Care - Pediatrics | TRGM1 | 1 | Procedure Room | 3G217 | | | | HAMP301 | HAMPER, WITH LID, 32" | 1 | VV | No | | 1 | |
| 96 | Ambulatory Care - Pediatrics | TRGM1 | 1 | Procedure Room | 3G217 | | 2/20/2014 | 3/25/2014 | LIEX305 | LIGHT, EXAM, CEILING HUNG | 1 | VC | | | 1 | |
| 97 | Ambulatory Care - Pediatrics | TRGM1 | 1 | Procedure Room | 3G217 | | 1/31/2014 | | LIPA305 | LIFT, PATIENT, BARIATRIC | 1 | VC | | | 1 | 0 |
| 98 | Ambulatory Care - Pediatrics | TRGM1 | 1 | Procedure Room | 3G217 | | | | LIPR320 | LIGHT, PROCEDURE, SINGLE | 1 | VC | | IS THIS DIFFERENT FROM OTHER EXAM LIGHTS? IS IT MOBILE OR CEILING HUNG? | 1 | |
| 99 | Ambulatory Care - Pediatrics | TRGM1 | 1 | Procedure Room | 3G217 | | 2/20/2014 | | MOBP302 | MONITOR WITH STAND, BLOOD PRESSURE | 1 | VV | | NEED DIMENSIONS, WEIGHT, POWER REQUIREMENTS | 1 | |
| 100 | Ambulatory Care - Pediatrics | TRGM1 | 1 | Procedure Room | 3G217 | | 2/20/2014 | | MOBP305 | MONITOR, BLOOD PRESSURE, WALL MOUNTED | 1 | VV | | NEED DIMENSIONS, WEIGHT, POWER REQUIREMENTS | 1 | |
| 101 | Ambulatory Care - Pediatrics | TRGM1 | 1 | Procedure Room | 3G217 | | 1/31/2014 | | OTOP300 | OPHTHALMOSCOPE/OTOSCOPE, WALL BOARD | 1 | VC | | WHICH MODEL NUMBER AND ACCESSORY MODULES? (SEE EQRA300 FOR MOUNTING) | 1 | 0 |
| 102 | Ambulatory Care - Pediatrics | TRGM1 | 1 | Procedure Room | 3G217 | | 1/31/2014 | | PRIN300 | PRINTER, LASER | 1 | VV | | ORIGINAL CUT SHEET RECEIVED LATER DECIDED WAS INCORRECT | 1 | |
| 103 | Ambulatory Care - Pediatrics | TRGM1 | 1 | Procedure Room | 3G217 | | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | | 1 | |
| 104 | Ambulatory Care - Pediatrics | TRGM1 | 1 | Procedure Room | 3G217 | | | | STDO350 | STOOL, DR. WITHOUT ARMS, ADJUSTABLE | 1 | VV | No | | 1 | |
| 105 | Ambulatory Care - Pediatrics | TRGM1 | 1 | Procedure Room | 3G217 | | | | STMA300 | STAND, MAYO | 1 | VV | No | | 1 | |
| 106 | Ambulatory Care - Pediatrics | TRGM1 | 1 | Procedure Room | 3G217 | | 1/31/2014 | | SYME300 | OMNIRX ONE CELL / SUPPLIER | 1 | VV | | Received 2 different sets of cut sheets, both for Omnicell, but one was labeled with SYSM Equipment code - is this mislabeled and both are for SYME300-302? The only specific product number called out is for a 2-cell unit (with the SYSM Equip no.), what are the product numbers & specifications for the preferred one and three cell units? | 1 | |
| 107 | Ambulatory Care - Pediatrics | TRGM1 | 1 | Procedure Room | 3G217 | | | | SYME300A | INSTALLATION, SEISMIC RESTRAINT | 1 | VV | - | | 1 | 0 |
| 108 | Ambulatory Care - Pediatrics | TRGM1 | 1 | Procedure Room | 3G217 | | 1/31/2014 | | TAPR302 | TABLE, PROCEDURE, POWER | 1 | VV | | | 1 | |
| 109 | Ambulatory Care - Pediatrics | TRGM1 | 1 | Procedure Room | 3G217 | | | | MOVI300 | V-TEL SYSTEM - SMART TV / MONITOR WITH CISCO SYSTEM | 1 | VV | | | 1 | |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|------------------------------|--------------|----------|----------------------|--------------|---------------------|--------------------|------------------|---|--------------|--------------------------|----------------------|---|-----------|-----------------------|
| 109 | Ambulatory Care - Pediatrics | TRGM1 | 1 | Procedure Room | 3G217 | | 2/20/2014 | TAUT300 | TABLE, UTILITY WITH DRAWERS | 1 | VV | | | 1 | 1 |
| 110 | Ambulatory Care - Pediatrics | UCCL1 | 1 | Clean Utility Room | | | | | | | | | | | |
| 111 | Ambulatory Care - Pediatrics | UCCL1 | 1 | Clean Utility Room | 3G303 | | | CACS300 | CART, COLLECTION, SPD | 1 | VV | NO | | 1 | |
| 112 | Ambulatory Care - Pediatrics | UCCL1 | 1 | Clean Utility Room | 3G303 | | | CACY303 | CART, CYLINDER, SINGLE | 1 | VV | NO | | 1 | |
| 113 | Ambulatory Care - Pediatrics | UCCL1 | 1 | Clean Utility Room | 3G303 | | | CAL303 | CART, LINEN 48" X 24" WITH VINYL COVER | 1 | VV | No | | 1 | 0 |
| 114 | Ambulatory Care - Pediatrics | UCCL1 | 1 | Clean Utility Room | 3G303 | | | CASU313 | CART, SUPPLY 48X24 | 1 | VV | NO | | 1 | |
| 115 | Ambulatory Care - Pediatrics | UCCL1 | 1 | Clean Utility Room | 3G303 | 2/20/2014 | | RACY308 | RACK, CYLINDER (6 E SIZE) | 1 | VV | | NEED PRODUCT DIMENSIONS & WEIGHT | 1 | |
| 116 | Ambulatory Care - Pediatrics | UCCL1 | 1 | Clean Utility Room | 3G303 | 1/31/2014 | 2/20/2014 | SYME302 | OMNIRX THREE CELL / SUPPLIER | 1 | VV | | NEED MODEL NUMBER | 1 | |
| 117 | Ambulatory Care - Pediatrics | UCCL1 | 1 | Clean Utility Room | 3G303 | | | SYME302A | INSTALLATION, SEISMIC RESTRAINT | 1 | VV | - | | 1 | 0 |
| 118 | Ambulatory Care - Pediatrics | WRCO1 | 1 | Waiting Area | | | | | | | | | | | 0 |
| 119 | Ambulatory Care - Pediatrics | WRCO1 | 1 | Waiting Area | 3G207 | | | FURN140 | CHAIR, BARIATRIC | 3 | VV | F | | 3 | 0 |
| 120 | Ambulatory Care - Pediatrics | WRCO1 | 1 | Waiting Area | 3G207 | | | FURN150 | CHAIR, WAITING ROOM | 12 | VV | F | | 12 | 0 |
| 121 | Ambulatory Care - Pediatrics | WRCO1 | 1 | Waiting Area | 3G207 | | | FURN400 | SIDE TABLE | 5 | VV | F | | 5 | |
| 122 | Ambulatory Care - Pediatrics | WRCO1 | 1 | Waiting Area | 3G207 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 1 | |
| 123 | Ambulatory Care - Pediatrics | WRCO1 | 1 | Waiting Area | 3G207 | 2/20/2014 | | TELE312 | TELEVISION, FLAT PANEL, 52" LCD | 1 | VC | | WE RECEIVED ONE CUT SHEET WITH TWO EQUIPMENT NUMBERS AND ONLY ONE MODEL INDICATED - ARE THEY TO BE THE SAME SIZE? | 1 | 0 |
| 124 | Ambulatory Care - Pediatrics | | 1 | Play Area | | | | | | | | | | | 0 |
| 125 | Ambulatory Care - Pediatrics | | 1 | Play Area | 3G211 | | | FURN160 | CHAIR, KID'S | 10 | VV | F | | 10 | |
| 126 | Ambulatory Care - Pediatrics | | 1 | Play Area | 3G211 | | | FURN450 | TABLE, KID'S PLAY | 2 | VV | F | | 2 | 1 |
| 127 | Ambulatory Care - Pediatrics | | 1 | Lactation Room | | | | | | | | | | | |
| 128 | Ambulatory Care - Pediatrics | | 1 | Lactation Room | 3G206 | 2/20/2014 | | BACH300 | BABY CHANGING STATION | 1 | VV | | REFER TO SCHEDULE B | 1 | 1 |
| 129 | Ambulatory Care - Pediatrics | | 1 | Lactation Room | 3G206 | | | CHGL300 | CHAIR, GLIDER | 2 | VV | No | | 2 | 0 |
| 130 | Ambulatory Care - Pediatrics | | 1 | Lactation Room | 3G206 | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | |
| 131 | Ambulatory Care - Pediatrics | | 1 | Lactation Room | 3G206 | | | FURN434 | ROUND TABLE | 2 | VV | F | | 2 | |
| 132 | Ambulatory Care - Pediatrics | | 1 | Lactation Room | 3G206 | 2/20/2014 | | OVM303 | OVEN, MICROWAVE | 1 | VV | | | 1 | |
| 133 | Ambulatory Care - Pediatrics | | 1 | Lactation Room | 3G206 | 1/31/2014 | 2/20/2014 | REUC315 | REFRIGERATOR, UNDERCOUNTER, ADA | 1 | VV | | | 1 | 0 |
| 134 | Ambulatory Care - Pediatrics | | 1 | Lactation Room | 3G206 | 1/31/2014 | | REUC315A | TEMPERATURE ALARM WITH PROBE | 1 | VV | | | 1 | |
| 135 | Ambulatory Care - Pediatrics | | 1 | Lactation Room | 3G206 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 1 | |
| 136 | Ambulatory Care - Pediatrics | | 1 | Alcove, Scale | | | | | | | | | | | |
| 137 | Ambulatory Care - Pediatrics | | 1 | Alcove, Scale | 3G219 | 2/20/2014 | | SCST300 | SCALE, STAND ON, PLATFORM, DIGITAL | 1 | VV | | NEED POWER & DATA REQUIREMENTS | 1 | |
| 138 | Ambulatory Care - Primary | | | | | | | | | | | | | | |
| 139 | Ambulatory Care - Primary | CRA01 | 1 | Conference/Classroom | | | | | | | | | | | |
| 140 | Ambulatory Care - Primary | CRA01 | 1 | Conference/Classroom | 2E157 | 2/20/2014 | 3/10/2014 | BOSM300 | BOARD, SMART, INTERACTIVE | 1 | CC | | VA HAS SUPPLIED CUT SHEETS - IS THIS CONTRACTOR ACQUIRED / CONTRACTOR INSTALLED AS INDICATED? | 1 | 0 |
| 141 | Ambulatory Care - Primary | CRA01 | 1 | Conference/Classroom | 2E157 | | | CACC300 | CAMERA, PORTABLE, CCTV WITH RECORDER, CEILING MOUNT | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 142 | Ambulatory Care - Primary | CRA01 | 1 | Conference/Classroom | 2E157 | 3/7/2014 | | PRLC300 | PROJECTOR, LCD, DIGITAL | 1 | VV | | | 1 | |
| 142 | Ambulatory Care - Primary | CRA01 | 1 | Conference/Classroom | 2E157 | | | REWA320 | RECEPTACLE, WASTE, OFFICE, 28 QT, PUBLIC ZONE | 1 | VV | No | | 1 | 0 |
| 142 | Ambulatory Care - Primary | CRA01 | 1 | Conference/Classroom | 2E157 | 2/20/2014 | | SCPR300 | SCREEN, PROJECTOR | 1 | VV | | CEILING OR WALL MOUNTED? NEED POWER REQUIREMENTS | 1 | |
| 143 | Ambulatory Care - Primary | CRA01 | 1 | Conference/Classroom | 2E157 | 2/20/2014 | | TELE312 | TELEVISION, FLAT PANEL, 52" LCD | 1 | VC | | WE RECEIVED ONE CUT SHEET WITH TWO EQUIPMENT NUMBERS AND ONLY ONE MODEL INDICATED - ARE THEY TO BE THE SAME SIZE? | 1 | 0 |
| 144 | Ambulatory Care - Primary | CRA01 | 1 | Conference/Classroom | 2E157 | | | FURN340 | TABLE, CONFERENCE, 10 PERSON | 1 | VV | F | | 1 | 1 |
| 145 | Ambulatory Care - Primary | CRA01 | 1 | Conference/Classroom | 2E157 | | | FURN104 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 12 | VV | F | | 12 | |
| 146 | Ambulatory Care - Primary | CRA01 | 1 | Conference/Classroom | 2E157 | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | |
| 147 | Ambulatory Care - Primary | CRA09 | 2 | Group Room | | | | | | | | | | | |
| 148 | Ambulatory Care - Primary | CRA09 | 2 | Group Room | 2A203, 2A207 | 2/20/2014 | 3/10/2014 | BOSM300 | BOARD, SMART, INTERACTIVE | 1 | CC | | VA HAS SUPPLIED CUT SHEETS - IS THIS CONTRACTOR ACQUIRED / CONTRACTOR INSTALLED AS INDICATED? | 2 | 0 |
| 149 | Ambulatory Care - Primary | CRA09 | 2 | Group Room | 2A203, 2A207 | | | CACC300 | CAMERA, PORTABLE, CCTV WITH RECORDER, CEILING MOUNT | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 2 | |
| 150 | Ambulatory Care - Primary | CRA09 | 2 | Group Room | 2A203, 2A207 | 3/7/2014 | | PRLC300 | PROJECTOR, LCD, DIGITAL | 1 | VV | | | 1 | |
| 150 | Ambulatory Care - Primary | CRA09 | 2 | Group Room | 2A203, 2A207 | 3/7/2014 | | PRLC300 | PROJECTOR, LCD, DIGITAL | 1 | VV | | | 1 | |
| 150 | Ambulatory Care - Primary | CRA09 | 2 | Group Room | 2A203, 2A207 | | | REWA320 | RECEPTACLE, WASTE, OFFICE, 28 QT, PUBLIC ZONE | 1 | VV | No | | 2 | 0 |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| | EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/ Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|-----|--|-----------|--------------|------------|--|------------|---------------------|--------------------|------------------|-------------------------------------|--------------|---------------------------|----------------------|---|-----------|-----------------------|
| 150 | Ambulatory Care - Primary | CRA09 | 2 | Group Room | 2A203, 2A207 | | 2/20/2014 | | SCPR300 | SCREEN, PROJECTOR | 1 | VV | | CEILING OR WALL MOUNTED? NEED POWER REQUIREMENTS | 1 | |
| 150 | Ambulatory Care - Primary | CRA09 | 2 | Group Room | 2A203, 2A207 | | 2/20/2014 | | SCPR300 | SCREEN, PROJECTOR | 1 | VV | | CEILING OR WALL MOUNTED? NEED POWER REQUIREMENTS | 1 | |
| 151 | Ambulatory Care - Primary | CRA09 | 2 | Group Room | 2A203, 2A207 | | 2/20/2014 | | TELE312 | TELEVISION, FLAT PANEL, 52" LCD | 1 | VC | | WE RECEIVED ONE CUT SHEET WITH TWO EQUIPMENT NUMBERS AND ONLY ONE MODEL INDICATED - ARE THEY TO BE THE SAME SIZE? | 2 | 0 |
| 152 | Ambulatory Care - Primary | CRA09 | 2 | Group Room | 2A203, 2A207 | | | | FURN350 | TABLE, CONFERENCE, 12 PERSON | 1 | VV | F | | 2 | 0 |
| 153 | Ambulatory Care - Primary | CRA09 | 2 | Group Room | 2A203, 2A207 | | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 12 | VV | F | | 24 | 0 |
| 154 | Ambulatory Care - Primary | CRA09 | 2 | Group Room | 2A203, 2A207 | | | | FURN170 | CHAIR, LOUNGE | 2 | VV | F | | 4 | 1 |
| 155 | Ambulatory Care - Primary | CRA09 | 2 | Group Room | 2A203, 2A207 | | | | FURN400 | SIDE TABLE | 1 | VV | F | | 2 | |
| | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | |
| 156 | Ambulatory Care - Primary | CRA09 | 2 | Group Room | 2A203, 2A207 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 2 | 0 |
| 157 | Ambulatory Care - Primary | EXRG3 | 40 | Exam Room | | | | | | | | | | | | |
| 158 | Ambulatory Care - Primary | EXRG3 | 40 | Exam Room | 2A215, 2A216, 2A217, 2A218, 2A219, 2A220, 2A223, 2A224, 2A226, 2A228, 2A231, 2A232, 2A233, 2A234, 2A235, 2A236, 2A239, 2A240, 2A242, 2A244, 2B247, 2B248, 2B249, 2B250, 2B251, 2B252, 2B255, 2B256, 2B258, 2B260, 2C236, 2C264, 2C265, 2C266, 2C267, 2C268, 2C271, 2C272, 2C274, 2C276 | | 2/20/2014 | | CASP306 | CART, SPECIALTY | 1 | VV | | CUT SHEET IS FROM 2001, IS THE INFORMATION STILL ACCURATE? | 40 | |
| | | | | | | | | | | | | | | | | |
| 159 | Ambulatory Care - Primary | EXRG3 | 40 | Exam Room | 2A215, 2A216, 2A217, 2A218, 2A219, 2A220, 2A223, 2A224, 2A226, 2A228, 2A231, 2A232, 2A233, 2A234, 2A235, 2A236, 2A239, 2A240, 2A242, 2A244, 2B247, 2B248, 2B249, 2B250, 2B251, 2B252, 2B255, 2B256, 2B258, 2B260, 2C236, 2C264, 2C265, 2C266, 2C267, 2C268, 2C271, 2C272, 2C274, 2C276 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 40 | 1 |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | | | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/ Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|---------------------------|-------|-----------|--------------|--|--------------|------------|---------------------|--------------------|------------------------------|-----------|--------------|---------------------------|---|--------------------------|-----------|-----------------------|
| 160 | Ambulatory Care - Primary | EXRG3 | 40 | Exam Room | 2A215, 2A216, 2A217, 2A218, 2A219, 2A220, 2A223, 2A224, 2A226, 2A228, 2A231, 2A232, 2A233, 2A234, 2A235, 2A236, 2A239, 2A240, 2A242, 2A244, 2B247, 2B248, 2B249, 2B250, 2B251, 2B252, 2B255, 2B256, 2B258, 2B260, 2C236, 2C264, 2C265, 2C266, 2C267, 2C268, 2C271, 2C272, 2C274, 2C276 | | 2/20/2014 | | COST300 | COMPUTER STATION, WALL MOUNT | 1 | VC | | WAITING ON PRODUCT SELECTION - NEED DIMENSIONS, WEIGHT, AND POWER / DATA REQUIREMENTS | 40 | 1 | |
| 161 | Ambulatory Care - Primary | EXRG3 | 40 | Exam Room | 2A215, 2A216, 2A217, 2A218, 2A219, 2A220, 2A223, 2A224, 2A226, 2A228, 2A231, 2A232, 2A233, 2A234, 2A235, 2A236, 2A239, 2A240, 2A242, 2A244, 2B247, 2B248, 2B249, 2B250, 2B251, 2B252, 2B255, 2B256, 2B258, 2B260, 2C236, 2C264, 2C265, 2C266, 2C267, 2C268, 2C271, 2C272, 2C274, 2C276 | | 2/20/2014 | | COSH321 | CONTAINER, SHARPS, 2 GALLON | 1 | VC | | TWO MODELS LISTED, PLEASE CONFIRM WE ARE USING 8509SA (W/O GLOVE BOX) NEED PRODUCT WEIGHT | 40 | | |
| 162 | Ambulatory Care - Primary | EXRG3 | 40 | Exam Room | 2A215, 2A216, 2A217, 2A218, 2A219, 2A220, 2A223, 2A224, 2A226, 2A228, 2A231, 2A232, 2A233, 2A234, 2A235, 2A236, 2A239, 2A240, 2A242, 2A244, 2B247, 2B248, 2B249, 2B250, 2B251, 2B252, 2B255, 2B256, 2B258, 2B260, 2C236, 2C264, 2C265, 2C266, 2C267, 2C268, 2C271, 2C272, 2C274, 2C276 | | 2/20/2014 | | DIGL300 | DISPENSER, GLOVE, 3 BOX | 1 | VC | | | 40 | 0 | |
| 163 | Ambulatory Care - Primary | EXRG3 | 40 | Exam Room | 2A215, 2A216, 2A217, 2A218, 2A219, 2A220, 2A223, 2A224, 2A226, 2A228, 2A231, 2A232, 2A233, 2A234, 2A235, 2A236, 2A239, 2A240, 2A242, 2A244, 2B247, 2B248, 2B249, 2B250, 2B251, 2B252, 2B255, 2B256, 2B258, 2B260, 2C236, 2C264, 2C265, 2C266, 2C267, 2C268, 2C271, 2C272, 2C274, 2C276 | | | | EQRA300 | EQUIPMENT RAIL, WALL MOUNT | 1 | VC | | **NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN** | 40 | | |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | | | | | | | | | | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|---------------------------|-------|----|-----------|--|--|-----------|--|---------|---------------------------------------|--------------|----------|--------------|--|---------------------|--------------------|------------------|-----------|--------------|--------------------------|----------------------|--------------------------|-----------|-----------------------|
| 164 | Ambulatory Care - Primary | EXRG3 | 40 | Exam Room | 2A215, 2A216, 2A217, 2A218, 2A219, 2A220, 2A223, 2A224, 2A226, 2A228, 2A231, 2A232, 2A233, 2A234, 2A235, 2A236, 2A239, 2A240, 2A242, 2A244, 2B247, 2B248, 2B249, 2B250, 2B251, 2B252, 2B255, 2B256, 2B258, 2B260, 2C236, 2C264, 2C265, 2C266, 2C267, 2C268, 2C271, 2C272, 2C274, 2C276 | | 2/20/2014 | | MOBP302 | MONITOR WITH STAND, BLOOD PRESSURE | 1 | VV | | NEED DIMENSIONS, WEIGHT, POWER REQUIREMENTS | 40 | | | | | | | | | |
| 165 | Ambulatory Care - Primary | EXRG3 | 40 | Exam Room | 2A215, 2A216, 2A217, 2A218, 2A219, 2A220, 2A223, 2A224, 2A226, 2A228, 2A231, 2A232, 2A233, 2A234, 2A235, 2A236, 2A239, 2A240, 2A242, 2A244, 2B247, 2B248, 2B249, 2B250, 2B251, 2B252, 2B255, 2B256, 2B258, 2B260, 2C236, 2C264, 2C265, 2C266, 2C267, 2C268, 2C271, 2C272, 2C274, 2C276 | | 2/20/2014 | | MOBP305 | MONITOR, BLOOD PRESSURE, WALL MOUNTED | 1 | VV | | NEED DIMENSIONS, WEIGHT, POWER REQUIREMENTS | 40 | | | | | | | | | |
| 166 | Ambulatory Care - Primary | EXRG3 | 40 | Exam Room | 2A215, 2A216, 2A217, 2A218, 2A219, 2A220, 2A223, 2A224, 2A226, 2A228, 2A231, 2A232, 2A233, 2A234, 2A235, 2A236, 2A239, 2A240, 2A242, 2A244, 2B247, 2B248, 2B249, 2B250, 2B251, 2B252, 2B255, 2B256, 2B258, 2B260, 2C236, 2C264, 2C265, 2C266, 2C267, 2C268, 2C271, 2C272, 2C274, 2C276 | | 1/31/2014 | | OTOP300 | OPHTHALMOSCOPE/OTOSCOPE, WALL BOARD | 1 | VC | | WHICH MODEL NUMBER AND ACCESSORY MODULES? (SEE EQRA300 FOR MOUNTING) | 40 | 0 | | | | | | | | |
| 167 | Ambulatory Care - Primary | EXRG3 | 40 | Exam Room | 2A215, 2A216, 2A217, 2A218, 2A219, 2A220, 2A223, 2A224, 2A226, 2A228, 2A231, 2A232, 2A233, 2A234, 2A235, 2A236, 2A239, 2A240, 2A242, 2A244, 2B247, 2B248, 2B249, 2B250, 2B251, 2B252, 2B255, 2B256, 2B258, 2B260, 2C236, 2C264, 2C265, 2C266, 2C267, 2C268, 2C271, 2C272, 2C274, 2C276 | | 1/31/2014 | | PRIN300 | PRINTER, LASER | 1 | VV | | ORIGINAL CUT SHEET RECEIVED LATER DECIDED WAS INCORRECT | 40 | | | | | | | | | |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | | | | | | | | | | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|---------------------------|-------|----|-----------|--|--|-----------|--|---------|-------------------------------------|--------------|----------|--------------|--|---------------------|--------------------|------------------|-----------|--------------|--------------------------|----------------------|--------------------------|-----------|-----------------------|
| 168 | Ambulatory Care - Primary | EXRG3 | 40 | Exam Room | 2A215, 2A216, 2A217, 2A218, 2A219, 2A220, 2A223, 2A224, 2A226, 2A228, 2A231, 2A232, 2A233, 2A234, 2A235, 2A236, 2A239, 2A240, 2A242, 2A244, 2B247, 2B248, 2B249, 2B250, 2B251, 2B252, 2B255, 2B256, 2B258, 2B260, 2C236, 2C264, 2C265, 2C266, 2C267, 2C268, 2C271, 2C272, 2C274, 2C276 | | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | | | | | | | | | 40 | | |
| 169 | Ambulatory Care - Primary | EXRG3 | 40 | Exam Room | 2A215, 2A216, 2A217, 2A218, 2A219, 2A220, 2A223, 2A224, 2A226, 2A228, 2A231, 2A232, 2A233, 2A234, 2A235, 2A236, 2A239, 2A240, 2A242, 2A244, 2B247, 2B248, 2B249, 2B250, 2B251, 2B252, 2B255, 2B256, 2B258, 2B260, 2C236, 2C264, 2C265, 2C266, 2C267, 2C268, 2C271, 2C272, 2C274, 2C276 | | | | SPHY306 | SPHYGMOMANOMETER, HAND HELD | 1 | VV | No | **NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN** (SEE EQRA300 FOR MOUNTING) | | | | | | | | 40 | | |
| 170 | Ambulatory Care - Primary | EXRG3 | 40 | Exam Room | 2A215, 2A216, 2A217, 2A218, 2A219, 2A220, 2A223, 2A224, 2A226, 2A228, 2A231, 2A232, 2A233, 2A234, 2A235, 2A236, 2A239, 2A240, 2A242, 2A244, 2B247, 2B248, 2B249, 2B250, 2B251, 2B252, 2B255, 2B256, 2B258, 2B260, 2C236, 2C264, 2C265, 2C266, 2C267, 2C268, 2C271, 2C272, 2C274, 2C276 | | | | STDO350 | STOOL, DR. WITHOUT ARMS, ADJUSTABLE | 1 | VV | No | | | | | | | | | 40 | 0 | |
| 171 | Ambulatory Care - Primary | EXRG3 | 40 | Exam Room | 2A215, 2A216, 2A217, 2A218, 2A219, 2A220, 2A223, 2A224, 2A226, 2A228, 2A231, 2A232, 2A233, 2A234, 2A235, 2A236, 2A239, 2A240, 2A242, 2A244, 2B247, 2B248, 2B249, 2B250, 2B251, 2B252, 2B255, 2B256, 2B258, 2B260, 2C236, 2C264, 2C265, 2C266, 2C267, 2C268, 2C271, 2C272, 2C274, 2C276 | | 2/20/2014 | | TAEX302 | TABLE, EXAM, POWER | 1 | VV | | with built-in scale feature | | | | | | | | 40 | 1 | |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|---------------------------|--------------|----------|-----------------|--|---------------------|--------------------|------------------|---|--------------|--------------------------|----------------------|---|-----------|-----------------------|
| 172 | Ambulatory Care - Primary | EXRG3 | 40 | Exam Room | 2A215, 2A216, 2A217, 2A218, 2A219, 2A220, 2A223, 2A224, 2A226, 2A228, 2A231, 2A232, 2A233, 2A234, 2A235, 2A236, 2A239, 2A240, 2A242, 2A244, 2B247, 2B248, 2B249, 2B250, 2B251, 2B252, 2B255, 2B256, 2B258, 2B260, 2C236, 2C264, 2C265, 2C266, 2C267, 2C268, 2C271, 2C272, 2C274, 2C276 | | | FURN140 | CHAIR, BARIATRIC | 1 | VV | | | 40 | |
| 173 | Ambulatory Care - Primary | EXRG3 | 40 | Exam Room | 2A215, 2A216, 2A217, 2A218, 2A219, 2A220, 2A223, 2A224, 2A226, 2A228, 2A231, 2A232, 2A233, 2A234, 2A235, 2A236, 2A239, 2A240, 2A242, 2A244, 2B247, 2B248, 2B249, 2B250, 2B251, 2B252, 2B255, 2B256, 2B258, 2B260, 2C236, 2C264, 2C265, 2C266, 2C267, 2C268, 2C271, 2C272, 2C274, 2C276 | | 2/20/2014 | CLWA801 | CLOCK | 1 | VV | | | 40 | 1 |
| 173 | Ambulatory Care - Primary | EXRG3 | 40 | Exam Room | 2A215, 2A216, 2A217, 2A218, 2A219, 2A220, 2A223, 2A224, 2A226, 2A228, 2A231, 2A232, 2A233, 2A234, 2A235, 2A236, 2A239, 2A240, 2A242, 2A244, 2B247, 2B248, 2B249, 2B250, 2B251, 2B252, 2B255, 2B256, 2B258, 2B260, 2C236, 2C264, 2C265, 2C266, 2C267, 2C268, 2C271, 2C272, 2C274, 2C276 | | | MOVI300 | V-TEL SYSTEM - SMART TV / MONITOR WITH CISCO SYSTEM | 1 | VV | | | 40 | |
| 174 | Ambulatory Care - Primary | MEDP1 | 5 | Medication Room | 2A213, 2A229, 2B245, 2B261, 2C277 | | 2/20/2014 | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | Room 2A213, 2A229, 2B245, 2B261, 2C277 | 5 | 1 |
| 175 | Ambulatory Care - Primary | MEDP1 | 5 | Medication Room | 2A213, 2A229, 2B245, 2B261, 2C277 | | 2/20/2014 | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 5 | 1 |
| 176 | Ambulatory Care - Primary | MEDP1 | 5 | Medication Room | 2A213, 2A229, 2B245, 2B261, 2C277 | | 2/20/2014 | COSH321 | CONTAINER, SHARPS, 2 GALLON | 1 | VC | | TWO MODELS LISTED, PLEASE CONFIRM WE ARE USING 8509SA (W/O GLOVE BOX) NEED PRODUCT WEIGHT | 5 | |
| 177 | Ambulatory Care - Primary | MEDP1 | 5 | Medication Room | 2A213, 2A229, 2B245, 2B261, 2C277 | | 2/20/2014 | DIGL300 | DISPENSER, GLOVE, 3 BOX | 1 | VC | | | 5 | |
| 178 | Ambulatory Care - Primary | MEDP1 | 5 | Medication Room | 2A213, 2A229, 2B245, 2B261, 2C277 | | 1/31/2014 | MEST330 | MEDICATION, STATION | 1 | VC | | WHAT IS THE MODEL NUMBER FOR THE SECOND PIECE OF EQUIPMENT AS INDICATED? | 5 | |
| 179 | Ambulatory Care - Primary | MEDP1 | 5 | Medication Room | 2A213, 2A229, 2B245, 2B261, 2C277 | | | MEST330A | SEISMIC BRACKET FOR ACUDOSE RX | 1 | VC | - | | 5 | |
| 180 | Ambulatory Care - Primary | MEDP1 | 5 | Medication Room | 2A213, 2A229, 2B245, 2B261, 2C277 | | 1/31/2014 | REUC315 | REFRIGERATOR, UNDERCOUNTER, ADA | 1 | VV | | | 5 | 0 |
| 181 | Ambulatory Care - Primary | MEDP1 | 5 | Medication Room | 2A213, 2A229, 2B245, 2B261, 2C277 | | | REUC315A | TEMPERATURE ALARM WITH PROBE | 1 | VV | - | | 5 | |
| 182 | Ambulatory Care - Primary | MEDP1 | 5 | Medication Room | 2A213, 2A229, 2B245, 2B261, 2C277 | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | | 5 | |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| | EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/ Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|-----|--|-----------|--------------|-------------------------|--|------------|---------------------|--------------------|------------------|---|--------------|---------------------------|----------------------|---|-----------|-----------------------|
| 183 | Ambulatory Care - Primary | MEDP1 | 5 | Medication Room | 2A213, 2A229, 2B245, 2B261, 2C277 | | 1/31/2014 | | SYME300 | OMNIRX ONE CELL / SUPPLIER | 1 | VV | | Received 2 different sets of cut sheets, both for Omnicell, but one was labeled with SYSM Equipment code - is this mislabeled and both are for SYME300-302? The only specific product number called out is for a 2-cell unit (with the SYSM Equip no.), what are the product numbers & specifications for the preferred one and three cell units? | 5 | 1 |
| 184 | Ambulatory Care - Primary | MEDP1 | 5 | Medication Room | 2A213, 2A229, 2B245, 2B261, 2C277 | | | | SYME300A | INSTALLATION, SEISMIC RESTRAINT | 1 | VV | - | | 5 | 1 |
| 185 | Ambulatory Care - Primary | MEDP1 | 5 | Medication Room | 2A213, 2A229, 2B245, 2B261, 2C277 | | 2/20/2014 | | WAPH300 | WASTE, PHARMACEUTICAL, 2 GAL | 1 | VC | | NEED DIMENSIONS & WEIGHT | 5 | |
| 186 | Ambulatory Care - Primary | MEDP1 | 5 | Medication Room | 2A213, 2A229, 2B245, 2B261, 2C277 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 5 | |
| 187 | Ambulatory Care - Primary | OFAO2 | 1 | Nurse Management Office | | | | | | | | | | | | |
| 188 | Ambulatory Care - Primary | OFAO2 | 1 | Nurse Management Office | 2C331 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | 0 |
| 189 | Ambulatory Care - Primary | OFAO2 | 1 | Nurse Management Office | 2C331 | | 1/31/2014 | | PRIN300 | PRINTER, LASER | 1 | VV | | ORIGINAL CUT SHEET RECEIVED LATER DECIDED WAS INCORRECT | 1 | 0 |
| 190 | Ambulatory Care - Primary | OFAO2 | 1 | Nurse Management Office | 2C331 | | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 1 | 0 |
| 191 | Ambulatory Care - Primary | OFAO2 | 1 | Nurse Management Office | 2C331 | | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 1 | VV | F | | 1 | 0 |
| 192 | Ambulatory Care - Primary | OFAO2 | 1 | Nurse Management Office | 2C331 | | | | FURN110 | CHAIR, NO ARMS | 2 | VV | F | | 2 | 1 |
| 193 | Ambulatory Care - Primary | OFAO2 | 1 | Nurse Management Office | 2C331 | | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 1 | VV | F | | 1 | |
| 194 | Ambulatory Care - Primary | OFAO2 | 1 | Nurse Management Office | 2C331 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | |
| 195 | Ambulatory Care - Primary | OFDC1 | 10 | Consult Room | | | | | | | | | | | | |
| 196 | Ambulatory Care - Primary | OFDC1 | 10 | Consult Room | 2A204, 2A205, 2A206, 2A209, 2A210, 2A212, 2C279, 2C280, 2C281, 2C283 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 10 | 0 |
| 197 | Ambulatory Care - Primary | OFDC1 | 10 | Consult Room | 2A204, 2A205, 2A206, 2A209, 2A210, 2A212, 2C279, 2C280, 2C281, 2C283 | | 2/20/2014 | | COST305 | COMPUTER STATION, WALL MOUNT | 1 | VC | | WAITING ON PRODUCT SELECTION - NEED DIMENSIONS, WEIGHT, AND POWER / DATA REQUIREMENTS | 10 | 0 |
| 197 | Ambulatory Care - Primary | OFDC1 | 10 | Consult Room | 2A204, 2A205, 2A206, 2A209, 2A210, 2A212, 2C279, 2C280, 2C281, 2C283 | | 2/20/2014 | | COST320 | MOBILE WORKSTATION, KIDNEY SHAPED TABLE | 1 | VV | | | 10 | 0 |
| 198 | Ambulatory Care - Primary | OFDC1 | 10 | Consult Room | 2A204, 2A205, 2A206, 2A209, 2A210, 2A212, 2C279, 2C280, 2C281, 2C283 | | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 1 | VV | F | | | 0 |
| 199 | Ambulatory Care - Primary | OFDC1 | 10 | Consult Room | 2A204, 2A205, 2A206, 2A209, 2A210, 2A212, 2C279, 2C280, 2C281, 2C283 | | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 1 | VV | F | | 10 | 0 |
| 200 | Ambulatory Care - Primary | OFDC1 | 10 | Consult Room | 2A204, 2A205, 2A206, 2A209, 2A210, 2A212, 2C279, 2C280, 2C281, 2C283 | | | | FURN110 | CHAIR, NO ARMS | 4 | VV | F | | 40 | 0 |
| 201 | Ambulatory Care - Primary | OFDC1 | 10 | Consult Room | 2A204, 2A205, 2A206, 2A209, 2A210, 2A212, 2C279, 2C280, 2C281, 2C283 | | | | FURN152 | LOVESEAT | 1 | VV | F | at Rooms 3016 & 3169; only 2 chairs at these rooms. | 20 | 1 |
| 202 | Ambulatory Care - Primary | OFDC1 | 10 | Consult Room | 2A204, 2A205, 2A206, 2A209, 2A210, 2A212, 2C279, 2C280, 2C281, 2C283 | | | | FURN500 | FILE CABINET, LOCKABLE | 2 | VV | F | | 20 | |
| 203 | Ambulatory Care - Primary | OFDC1 | 10 | Consult Room | 2A204, 2A205, 2A206, 2A209, 2A210, 2A212, 2C279, 2C280, 2C281, 2C283 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 10 | 1 |
| 203 | Ambulatory Care - Primary | OFDC1 | 10 | Consult Room | 2A204, 2A205, 2A206, 2A209, 2A210, 2A212, 2C279, 2C280, 2C281, 2C283 | | | | MOVI300 | V-Tel SYSTEM - SMART TV / MONITOR WITH CISCO SYSTEM | 1 | VV | | | 10 | |
| 204 | Ambulatory Care - Primary | OFDC2 | 1 | Consult Room, Large | | | | | | | | | | | | 0 |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| | EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/ Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|-----|--|-----------|--------------|-------------------------|--------------|------------|---------------------|--------------------|------------------|---|--------------|---------------------------|----------------------|--|-----------|-----------------------|
| 205 | Ambulatory Care - Primary | OFDC2 | 1 | Consult Room, Large | 2C284 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | 0 |
| 205 | Ambulatory Care - Primary | OFDC2 | 1 | Consult Room, Large | 2C284 | | 2/20/2014 | | COST305 | COMPUTER STATION, WALL MOUNT | 1 | VC | | WAITING ON PRODUCT SELECTION - NEED DIMENSIONS, WEIGHT, AND POWER / DATA REQUIREMENTS | 1 | |
| 205 | Ambulatory Care - Primary | OFDC2 | 1 | Consult Room, Large | 2C284 | | 2/20/2014 | | COST320 | MOBILE WORKSTATION, KIDNEY SHAPED TABLE | 1 | VV | | | 1 | 0 |
| 206 | Ambulatory Care - Primary | OFDC2 | 1 | Consult Room, Large | 2C284 | | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 1 | VV | F | | | 0 |
| 207 | Ambulatory Care - Primary | OFDC2 | 1 | Consult Room, Large | 2C284 | | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 1 | VV | F | | 1 | 0 |
| 208 | Ambulatory Care - Primary | OFDC2 | 1 | Consult Room, Large | 2C284 | | | | FURN110 | CHAIR, NO ARMS | 4 | VV | F | | 4 | 0 |
| 209 | Ambulatory Care - Primary | OFDC2 | 1 | Consult Room, Large | 2C284 | | | | FURN156 | SOFA | 1 | VV | F | | 1 | 1 |
| 210 | Ambulatory Care - Primary | OFDC2 | 1 | Consult Room, Large | 2C284 | | | | FURN500 | FILE CABINET, LOCKABLE | 2 | VV | F | | 2 | |
| 211 | Ambulatory Care - Primary | OFDC2 | 1 | Consult Room, Large | 2C284 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | 1 |
| 211 | Ambulatory Care - Primary | OFDC2 | 1 | Consult Room, Large | 2C284 | | | | MOVI300 | V-TEL SYSTEM - SMART TV / MONITOR WITH CISCO SYSTEM | 1 | VV | | | 1 | 1 |
| 212 | Ambulatory Care - Primary | OFDC4 | 1 | Lactation (north wall) | | | | | | | | | | | | |
| 213 | Ambulatory Care - Primary | OFDC4 | 1 | Lactation (north wall) | 2A306 | | 2/20/2014 | | BACH300 | BABY CHANGING STATION | 1 | VV | | REFER TO SCHEDULE B | 1 | |
| 214 | Ambulatory Care - Primary | OFDC4 | 1 | Lactation (north wall) | 2A306 | | | | CHGL300 | CHAIR, GLIDER | 2 | VV | No | | 2 | |
| 215 | Ambulatory Care - Primary | OFDC4 | 1 | Lactation (north wall) | 2A306 | | 2/20/2014 | | OVMI303 | OVEN, MICROWAVE | 1 | VV | | | 1 | |
| 216 | Ambulatory Care - Primary | OFDC4 | 1 | Lactation (north wall) | 2A306 | | 1/31/2014 | 2/20/2014 | REUC315 | REFRIGERATOR, UNDERCOUNTER, ADA | 1 | VV | | | 1 | 0 |
| 217 | Ambulatory Care - Primary | OFDC4 | 1 | Lactation (north wall) | 2A306 | | 1/31/2014 | | REUC315A | TEMPERATURE ALARM WITH PROBE | 1 | VV | | | 1 | 0 |
| 218 | Ambulatory Care - Primary | OFDC4 | 1 | Lactation (north wall) | 2A306 | | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 1 | 1 |
| 219 | Ambulatory Care - Primary | OFDC4 | 1 | Lactation (north wall) | 2A306 | | | | FURN434 | ROUND TABLE | 2 | VV | F | | 2 | |
| 220 | Ambulatory Care - Primary | OFDC4 | 1 | Lactation (north wall) | 2A306 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | 1 |
| 221 | Ambulatory Care - Primary | RECP1 | 1 | Central Reception | | | | | | | | | | Room 2D201 | | |
| 222 | Ambulatory Care - Primary | RECP1 | 1 | Central Reception | 2D201 | | 2/20/2014 | | BISH300 | BIN, SHRED | 2 | VV | | | 2 | |
| 223 | Ambulatory Care - Primary | RECP1 | 1 | Central Reception | 2D201 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 5 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 5 | |
| 224 | Ambulatory Care - Primary | RECP1 | 1 | Central Reception | 2D201 | | 2/20/2014 | | COPY310 | COPIER, HIGH VOLUME | 1 | VV | | | 1 | 0 |
| 225 | Ambulatory Care - Primary | RECP1 | 1 | Central Reception | 2D201 | | 1/31/2014 | | PRMF301 | PRINTER, MULTI-FUNCTION | 1 | VV | | PRMF301 & COP1300 LISTED ON SAME CUT SHEET WITH ONLY ONE XEROX MODEL CALLED OUT - SIZE DOES NOT WORK IN MOST PRMF301 LOCATIONS | 1 | 0 |
| 226 | Ambulatory Care - Primary | RECP1 | 1 | Central Reception | 2D201 | | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 5 | VV | No | | 5 | 1 |
| 227 | Ambulatory Care - Primary | RECP1 | 1 | Central Reception | 2D201 | | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 5 | VV | F | | 5 | |
| 227 | Ambulatory Care - Primary | RECP1 | 1 | Central Reception | 2D201 | | | | KICI300 | KIOSK, CHECK-IN | 3 | VV | | **NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN** | 3 | |
| 228 | Ambulatory Care - Primary | RECP1 | 1 | Central Reception | 2D201 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | |
| 229 | Ambulatory Care - Primary | SL001 | 1 | Staff Break Room, Large | | | | | | | | | | | | |
| 230 | Ambulatory Care - Primary | SL001 | 1 | Staff Break Room, Large | 2A211 | | 2/20/2014 | | COMA309 | COFFEE MAKER, PLUMBED | 2 | VC | | | 2 | |
| 231 | Ambulatory Care - Primary | SL001 | 1 | Staff Break Room, Large | 2A211 | | 2/20/2014 | | OVMI303 | OVEN, MICROWAVE | 2 | VV | | | 2 | 0 |
| 232 | Ambulatory Care - Primary | SL001 | 1 | Staff Break Room, Large | 2A211 | | 2/20/2014 | | REFR311 | REFRIGERATOR/FREEZER, 21 CU FT W/ ICE MAKER | 3 | VV | | | 3 | 0 |
| 233 | Ambulatory Care - Primary | SL001 | 1 | Staff Break Room, Large | 2A211 | | | | REWA303 | RECEPTACLE, WASTE, 23 GAL, SLIM JIM | 2 | VV | NO | | 2 | |
| 234 | Ambulatory Care - Primary | SL001 | 1 | Staff Break Room, Large | 2A211 | | | | REWA303A | SWING TOP | 2 | VV | - | | 2 | 0 |
| 235 | Ambulatory Care - Primary | SL001 | 1 | Staff Break Room, Large | 2A211 | | 2/20/2014 | | TELE312 | TELEVISION, FLAT PANEL, 52" LCD | 1 | VC | | WE RECEIVED ONE CUT SHEET WITH TWO EQUIPMENT NUMBERS AND ONLY ONE MODEL INDICATED - ARE THEY TO BE THE SAME SIZE? | 1 | 0 |
| 236 | Ambulatory Care - Primary | SL001 | 1 | Staff Break Room, Large | 2A211 | | | | FURN312 | TABLE, ROUND, 4 PERSON | 3 | VV | F | | 3 | |
| 237 | Ambulatory Care - Primary | SL001 | 1 | Staff Break Room, Large | 2A211 | | | | FURN112 | CHAIR, NO ARMS | 12 | VV | F | | 12 | |
| 238 | Ambulatory Care - Primary | SL001 | 1 | Staff Break Room | | | | | | | | | | | | |
| 239 | Ambulatory Care - Primary | SL001 | 1 | Staff Break Room | 2C335 | | 2/20/2014 | | COMA309 | COFFEE MAKER, PLUMBED | 2 | VC | | | 2 | |
| 240 | Ambulatory Care - Primary | SL001 | 1 | Staff Break Room | 2C335 | | 2/20/2014 | | OVMI303 | OVEN, MICROWAVE | 2 | VV | | | 2 | 0 |
| 241 | Ambulatory Care - Primary | SL001 | 1 | Staff Break Room | 2C335 | | 2/20/2014 | | REFR311 | REFRIGERATOR/FREEZER, 21 CU FT W/ ICE MAKER | 3 | VV | | | 3 | 0 |
| 242 | Ambulatory Care - Primary | SL001 | 1 | Staff Break Room | 2C335 | | | | REWA303 | RECEPTACLE, WASTE, 23 GAL, SLIM JIM | 2 | VV | NO | | 2 | |
| 243 | Ambulatory Care - Primary | SL001 | 1 | Staff Break Room | 2C335 | | | | REWA303A | SWING TOP | 2 | VV | - | | 2 | 0 |
| 244 | Ambulatory Care - Primary | SL001 | 1 | Staff Break Room | 2C335 | | 2/20/2014 | | TELE312 | TELEVISION, FLAT PANEL, 52" LCD | 1 | VC | | WE RECEIVED ONE CUT SHEET WITH TWO EQUIPMENT NUMBERS AND ONLY ONE MODEL INDICATED - ARE THEY TO BE THE SAME SIZE? | 1 | 0 |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/ Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|---------------------------|--------------|----------|-------------------|---|---------------------|--------------------|------------------|-------------------------------------|--------------|---------------------------|----------------------|---|-----------|-----------------------|
| 245 | Ambulatory Care - Primary | SL001 | 1 | Staff Break Room | 2C335 | | | FURN312 | TABLE, ROUND, 4 PERSON | 2 | VV | F | | 2 | |
| 246 | Ambulatory Care - Primary | SL001 | 1 | Staff Break Room | 2C335 | | | FURN112 | CHAIR, NO ARMS | 8 | VV | F | | 8 | |
| 247 | Ambulatory Care - Primary | SL002 | 3 | Teamlet Workroom | | | | | | | | | | | |
| 248 | Ambulatory Care - Primary | SL002 | 3 | Teamlet Workroom | 2D300, 2E314, 2F325 | | 2/20/2014 | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 24 | VV | | WAITING ON MORE INFORMATION. MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 72 | |
| 248 | Ambulatory Care - Primary | SL002 | 3 | Teamlet Workroom | 2D300, 2E314, 2F325 | | | MOPT300 | MONITOR, PATIENT TRACKING | 1 | VV | | **NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN** | 1 | 0 |
| 249 | Ambulatory Care - Primary | SL002 | 3 | Teamlet Workroom | 2D300, 2E314, 2F325 | | | HAMP301 | HAMPER, WITH LID, 32" | 6 | VV | No | | 24 | 0 |
| 250 | Ambulatory Care - Primary | SL002 | 3 | Teamlet Workroom | 2D300, 2E314, 2F325 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 12 | VV | No | | 36 | 0 |
| 251 | Ambulatory Care - Primary | SL002 | 3 | Teamlet Workroom | 2D300, 2E314, 2F325 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 24 | VV | F | | 72 | |
| 252 | Ambulatory Care - Primary | SL002 | 3 | Teamlet Workroom | 2D300, 2E314, 2F325 | | | FURN240 | WORKSTATION, 2'-0" X 4'-0" | 24 | VV | F | | 72 | 1 |
| 253 | Ambulatory Care - Primary | SL002 | 3 | Teamlet Workroom | 2D300, 2E314, 2F325 | | | PRMF 201 | PRINTER, MULTI-FUNCTION | 2 | VV | | **NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN** | 6 | |
| 254 | Ambulatory Care - Primary | SL002 | 3 | Teamlet Workroom | 2D300, 2E314, 2F325 | | 2/20/2014 | CLWA801 | CLOCK | 2 | VV | | | 6 | |
| 255 | Ambulatory Care - Primary | SL002 | 1 | Teamlet Workroom | | | | | | | | | | | |
| 256 | Ambulatory Care - Primary | SL002 | 1 | Teamlet Workroom | 2F326 | | 2/20/2014 | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 20 | VV | | WAITING ON MORE INFORMATION. MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 20 | 0 |
| 256 | Ambulatory Care - Primary | SL002 | 1 | Teamlet Workroom | 2F326 | | | MOPT300 | MONITOR, PATIENT TRACKING | 1 | VV | | **NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN** | 1 | 0 |
| 257 | Ambulatory Care - Primary | SL002 | 1 | Teamlet Workroom | 2F326 | | | HAMP301 | HAMPER, WITH LID, 32" | 6 | VV | No | | 6 | 0 |
| 258 | Ambulatory Care - Primary | SL002 | 1 | Teamlet Workroom | 2F326 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 12 | VV | No | | 12 | 1 |
| 259 | Ambulatory Care - Primary | SL002 | 1 | Teamlet Workroom | 2F326 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 20 | VV | F | | 20 | |
| 260 | Ambulatory Care - Primary | SL002 | 1 | Teamlet Workroom | 2F326 | | | FURN240 | WORKSTATION, 2'-0" X 4'-0" | 20 | VV | F | | 20 | |
| 261 | Ambulatory Care - Primary | SL002 | 1 | Teamlet Workroom | 2F326 | | 2/20/2014 | CLWA801 | CLOCK | 2 | VV | | | 2 | |
| 262 | Ambulatory Care - Primary | SL002 | 1 | Teamlet Workroom | | | | | | | | | | | 0 |
| 263 | Ambulatory Care - Primary | SL002 | 1 | Teamlet Workroom | 2D313 | | 2/20/2014 | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 22 | VV | | WAITING ON MORE INFORMATION. MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 22 | 0 |
| 263 | Ambulatory Care - Primary | SL002 | 1 | Teamlet Workroom | 2D313 | | | MOPT300 | MONITOR, PATIENT TRACKING | 1 | VV | | **NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN** | 1 | 0 |
| 264 | Ambulatory Care - Primary | SL002 | 1 | Teamlet Workroom | 2D313 | | | HAMP301 | HAMPER, WITH LID, 32" | 6 | VV | No | | 6 | 1 |
| 265 | Ambulatory Care - Primary | SL002 | 1 | Teamlet Workroom | 2D313 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 12 | VV | No | | 12 | |
| 266 | Ambulatory Care - Primary | SL002 | 1 | Teamlet Workroom | 2D313 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 22 | VV | F | | 22 | |
| 267 | Ambulatory Care - Primary | SL002 | 1 | Teamlet Workroom | 2D313 | | | FURN240 | WORKSTATION, 2'-0" X 4'-0" | 22 | VV | F | | 22 | 0 |
| 268 | Ambulatory Care - Primary | SL002 | 1 | Teamlet Workroom | 2D313 | | 2/20/2014 | CLWA801 | CLOCK | 2 | VV | | | 2 | 0 |
| 269 | Ambulatory Care - Primary | SL002B | 5 | Team Work Area | | | | | | | | | | | |
| 270 | Ambulatory Care - Primary | SL002B | 5 | Team Work Area | 2A305, 2A309, 2B320, 2C321, 2C334 | | 2/20/2014 | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 6 | VV | | WAITING ON MORE INFORMATION. MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 30 | |
| 271 | Ambulatory Care - Primary | SL002B | 5 | Team Work Area | 2A305, 2A309, 2B320, 2C321, 2C334 | | | FURN430 | TABLE, ROUND | 1 | VV | F | | | |
| 272 | Ambulatory Care - Primary | SL002B | 5 | Team Work Area | 2A305, 2A309, 2B320, 2C321, 2C334 | | | FURN244 | WORKSTATION, 2'-0" X 4'-0" | 6 | VV | F | | 30 | |
| 273 | Ambulatory Care - Primary | SRSO1 | 1 | Equipment Storage | | | | | | | | | | | |
| 274 | Ambulatory Care - Primary | SRSO1 | 1 | Equipment Storage | 2C330 | | | CASU313 | CART, SUPPLY 48X24 | 4 | VV | NO | | 4 | |
| 275 | Ambulatory Care - Primary | SRSO1 | 1 | Equipment Storage | 2C330 | | 2/20/2014 | LIEX310 | LIGHT, EXAM MOBILE | 4 | VV | | NEED PRODUCT WEIGHT | 4 | 1 |
| 276 | Ambulatory Care - Primary | SRSO1 | 1 | Equipment Storage | 2C330 | | | STMA300 | STAND, MAYO | 4 | VV | No | | 4 | 0 |
| 277 | Ambulatory Care - Primary | SRSO1 | 1 | Equipment Storage | 2C330 | | 3/7/2014 | SYEA300 | SYSTEM, EAR WASH | 2 | VV | | NEED PRODUCT DIMENSIONS, WEIGHT, AND POWER REQUIREMENTS | 2 | |
| 278 | Ambulatory Care - Primary | TLTU1 | 6 | Toilet, Public | | | | | | | | | | | 0 |
| 279 | Ambulatory Care - Primary | TLTU1 | 6 | Toilet, Public | 2D150, 2D151, 2E152, 2E153, 2F155, 2F156 | | 2/20/2014 | BACH300 | BABY CHANGING STATION | 1 | VV | | REFER TO SCHEDULE B | 6 | |
| 280 | Ambulatory Care - Primary | TLTU1 | 6 | Toilet, Public | 2D150, 2D151, 2E152, 2E153, 2F155, 2F156 | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | | 6 | 0 |
| 281 | Ambulatory Care - Primary | TLTU1 | 15 | Toilet, Patient | | | | | | | | | | | |
| 282 | Ambulatory Care - Primary | TLTU1 | 15 | Toilet, Patient | 2A208, 2A221, 2A222, 2A227, 2B237, 2B238, 2B234, 2B253, 2B254, 2B259, 2C269, 2C270, 2C275, 2C282, 2C285 | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | | 15 | 1 |
| 283 | Ambulatory Care - Primary | TLTU1 | 5 | Toilet, Staff | | | | | | | | | | | |
| 284 | Ambulatory Care - Primary | TLTU1 | 5 | Toilet, Staff | 2A304, 2A307, 2A308, 2C332, 2C333 | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | | 5 | 1 |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/ Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|---------------------------|--------------|----------|--------------------|----------------------------|---------------------|--------------------|------------------|---|--------------|---------------------------|----------------------|---|-----------|-----------------------|
| 285 | Ambulatory Care - Primary | TRGM1 | 4 | Procedure Room | | | | | | | | | | 1 | |
| 286 | Ambulatory Care - Primary | TRGM1 | 4 | Procedure Room | 2A225, 2B241, 2B257, 2C273 | 2/20/2014 | | CASP306 | CART, SPECIALTY | 1 | VV | No | CUT SHEET IS FROM 2001, IS THE INFORMATION STILL ACCURATE? | 4 | |
| 286 | Ambulatory Care - Primary | TRGM1 | 4 | Procedure Room | 2A225, 2B241, 2B257, 2C273 | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 4 | |
| 287 | Ambulatory Care - Primary | TRGM1 | 4 | Procedure Room | 2A225, 2B241, 2B257, 2C273 | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE | 4 | |
| 287 | Ambulatory Care - Primary | TRGM1 | 4 | Procedure Room | 2A225, 2B241, 2B257, 2C273 | 2/20/2014 | | COST300 | COMPUTER STATION, WALL MOUNT | 1 | VC | | WAITING ON PRODUCT SELECTION - NEED DIMENSIONS, WEIGHT, AND POWER / DATA REQUIREMENTS | 1 | |
| 287 | Ambulatory Care - Primary | TRGM1 | 4 | Procedure Room | 2A225, 2B241, 2B257, 2C273 | 2/20/2014 | | COST320 | MOBILE WORKSTATION, KIDNEY SHAPED TABLE | 1 | VV | | | 1 | 0 |
| 288 | Ambulatory Care - Primary | TRGM1 | 4 | Procedure Room | 2A225, 2B241, 2B257, 2C273 | 2/20/2014 | | COSH321 | CONTAINER, SHARPS, 2 GALLON | 1 | VC | | TWO MODELS LISTED, PLEASE CONFIRM WE ARE USING 8509SA (W/O GLOVE BOX) NEED PRODUCT WEIGHT | 4 | |
| 289 | Ambulatory Care - Primary | TRGM1 | 4 | Procedure Room | 2A225, 2B241, 2B257, 2C273 | 2/20/2014 | | DIGL300 | DISPENSER, GLOVE, 3 BOX | 1 | VC | | | 4 | 0 |
| 290 | Ambulatory Care - Primary | TRGM1 | 4 | Procedure Room | 2A225, 2B241, 2B257, 2C273 | | | EQRA300 | EQUIPMENT RAIL, WALL MOUNT | 1 | VC | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 4 | |
| 291 | Ambulatory Care - Primary | TRGM1 | 4 | Procedure Room | 2A225, 2B241, 2B257, 2C273 | | | HAMP301 | HAMPER, WITH LID, 32" | 1 | VV | No | | 4 | |
| 292 | Ambulatory Care - Primary | TRGM1 | 4 | Procedure Room | 2A225, 2B241, 2B257, 2C273 | 2/20/2014 | 3/25/2014 | LIEX305 | LIGHT, EXAM, CEILING HUNG | 1 | VC | | | 4 | 0 |
| 293 | Ambulatory Care - Primary | TRGM1 | 4 | Procedure Room | 2A225, 2B241, 2B257, 2C273 | 1/31/2014 | | LIPA305 | LIFT, PATIENT, BARIATRIC | 1 | VC | | | 4 | |
| 294 | Ambulatory Care - Primary | TRGM1 | 4 | Procedure Room | 2A225, 2B241, 2B257, 2C273 | 2/20/2014 | | MOBP302 | MONITOR WITH STAND, BLOOD PRESSURE | 1 | VV | | NEED DIMENSIONS, WIEGHT, POWER REQUIREMENTS | 4 | |
| 295 | Ambulatory Care - Primary | TRGM1 | 4 | Procedure Room | 2A225, 2B241, 2B257, 2C273 | 2/20/2014 | | MOBP305 | MONITOR, BLOOD PRESSURE, WALL MOUNTED | 1 | VV | | NEED DIMENSIONS, WEIGHT, POWER REQUIREMENTS | 4 | |
| 296 | Ambulatory Care - Primary | TRGM1 | 4 | Procedure Room | 2A225, 2B241, 2B257, 2C273 | 1/31/2014 | | OTOP300 | OPHTHALMOSCOPE/OTOSCOPE, WALL BOARD | 1 | VC | | WHICH MODEL NUMBER AND ACCESSORY MODULES? (SEE EQRA300 FOR MOUNTING) | 4 | |
| 297 | Ambulatory Care - Primary | TRGM1 | 4 | Procedure Room | 2A225, 2B241, 2B257, 2C273 | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | | 4 | |
| 298 | Ambulatory Care - Primary | TRGM1 | 4 | Procedure Room | 2A225, 2B241, 2B257, 2C273 | | | STDO350 | STOOL, DR. WITHOUT ARMS, ADJUSTABLE | 1 | VV | No | | 4 | 0 |
| 299 | Ambulatory Care - Primary | TRGM1 | 4 | Procedure Room | 2A225, 2B241, 2B257, 2C273 | | | STMA300 | STAND, MAYO | 1 | VV | No | | 4 | |
| 300 | Ambulatory Care - Primary | TRGM1 | 4 | Procedure Room | 2A225, 2B241, 2B257, 2C273 | 1/31/2014 | | SYME300 | OMNIRX ONE CELL / SUPPLIER | 1 | VV | | Received 2 different sets of cut sheets, both for Omnicell, but one was labeled with SYSM Equipment code - is this mislabeled and both are for SYME300-302? The only specific product number called out is for a 2-cell unit (with the SYSM Equip no.), what are the product numbers & specifications for the preferred one and three cell units? | 4 | |
| 301 | Ambulatory Care - Primary | TRGM1 | 4 | Procedure Room | 2A225, 2B241, 2B257, 2C273 | | | SYME300A | INSTALLATION, SEISMIC RESTRAINT | 1 | VV | - | | 4 | |
| 302 | Ambulatory Care - Primary | TRGM1 | 4 | Procedure Room | 2A225, 2B241, 2B257, 2C273 | 1/31/2014 | | TAPR302 | TABLE, PROCEDURE, POWER | 1 | VV | | | 4 | 1 |
| 303 | Ambulatory Care - Primary | TRGM1 | 4 | Procedure Room | 2A225, 2B241, 2B257, 2C273 | | | MOVI300 | V-TEL SYSTEM - SMART TV / MONITOR WITH CISCO SYSTEM | 1 | VV | | | 4 | |
| 303 | Ambulatory Care - Primary | TRGM1 | 4 | Procedure Room | 2A225, 2B241, 2B257, 2C273 | 2/20/2014 | | TAUT300 | TABLE, UTILITY WITH DRAWERS | 1 | VV | | | 4 | |
| 304 | Ambulatory Care - Primary | | 5 | Patient Corridor | 2A404, 2B406 | 2/20/2014 | | SCWC300 | WHEELCHAIR SCALE | 1 | | | NEED PRODUCT WEIGHT, POWER & DATA REQUIREMENTS - only in 2 corridors | 2 | |
| 304 | Ambulatory Care - Primary | | 5 | Patient Corridor | | | | | | | | | | | |
| 304 | Ambulatory Care - Primary | UCCL1 | 1 | Clean Utility Room | | | | | | | | | | 0 | |
| 305 | Ambulatory Care - Primary | UCCL1 | 1 | Clean Utility Room | 2B319 | | | CACS300 | CART, COLLECTION, SPD | 1 | VV | NO | | 1 | |
| 306 | Ambulatory Care - Primary | UCCL1 | 1 | Clean Utility Room | 2B319 | | | CACY303 | CART, CYLINDER, SINGLE | 1 | VV | NO | | 1 | |
| 307 | Ambulatory Care - Primary | UCCL1 | 1 | Clean Utility Room | 2B319 | | | CALI303 | CART, LINEN 48" X 24" WITH VINYL COVER | 1 | VV | No | | 1 | |
| 308 | Ambulatory Care - Primary | UCCL1 | 1 | Clean Utility Room | 2B319 | | | CASU313 | CART, SUPPLY 48X24 | 1 | VV | NO | | 1 | |
| 309 | Ambulatory Care - Primary | UCCL1 | 1 | Clean Utility Room | 2B319 | 2/20/2014 | | RACY308 | RACK, CYLINDER (6 E SIZE) | 1 | VV | | NEED PRODUCT DIMENSIONS & WEIGHT | 1 | |
| 310 | Ambulatory Care - Primary | UCCL1 | 1 | Clean Utility Room | 2B319 | 1/31/2014 | 2/20/2014 | SYME302 | OMNIRX THREE CELL / SUPPLIER | 1 | VV | | NEED MODEL NUMBER | 1 | |
| 311 | Ambulatory Care - Primary | UCCL1 | 1 | Clean Utility Room | 2B319 | | | SYME302A | INSTALLATION, SEISMIC RESTRAINT | 1 | VV | - | | 1 | |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|---------------------------|--------------|----------|--------------------------|-----------------------------------|---------------------|--------------------|------------------|---|--------------|--------------------------|----------------------|---|-----------|-----------------------|
| 312 | Ambulatory Care - Primary | USCL1 | 5 | Soiled Utility Room | | | | | | | | | | | |
| 313 | Ambulatory Care - Primary | USCL1 | 5 | Soiled Utility Room | 2A214, 2B230, 2B246, 2C262, 2C278 | | | CACS300 | CART, COLLECTION, SPD | 1 | VV | NO | | 5 | |
| 314 | Ambulatory Care - Primary | USCL1 | 5 | Soiled Utility Room | 2A214, 2B230, 2B246, 2C262, 2C278 | | | CASO300 | CART, SOILED LINEN | 1 | VV | NO | | 5 | 1 |
| 315 | Ambulatory Care - Primary | USCL1 | 5 | Soiled Utility Room | 2A214, 2B230, 2B246, 2C262, 2C278 | | | CAUT300 | CART, UTILITY | 1 | VV | NO | | 5 | 1 |
| 316 | Ambulatory Care - Primary | USCL1 | 5 | Soiled Utility Room | 2A214, 2B230, 2B246, 2C262, 2C278 | | | CONT300 | CONTAINER, BRUTE 32 GAL. | 1 | VV | No | | 5 | |
| 317 | Ambulatory Care - Primary | USCL1 | 5 | Soiled Utility Room | 2A214, 2B230, 2B246, 2C262, 2C278 | | | CONT300A | FLAT TOP FOR BRUTE, 32 GAL | 1 | VV | - | | 5 | |
| 318 | Ambulatory Care - Primary | USCL1 | 5 | Soiled Utility Room | 2A214, 2B230, 2B246, 2C262, 2C278 | | | CONT300B | DOLLY FOR BRUTE, 32 GAL | 1 | VV | - | | 5 | |
| 319 | Ambulatory Care - Primary | USCL1 | 5 | Soiled Utility Room | 2A214, 2B230, 2B246, 2C262, 2C278 | 2/20/2014 | | COSH321 | CONTAINER, SHARPS, 2 GALLON | 1 | VC | | TWO MODELS LISTED, PLEASE CONFIRM WE ARE USING 8509SA (W/O GLOVE BOX) NEED PRODUCT WEIGHT | 5 | 0 |
| 320 | Ambulatory Care - Primary | USCL1 | 5 | Soiled Utility Room | 2A214, 2B230, 2B246, 2C262, 2C278 | 2/20/2014 | | DIGL300 | DISPENSER, GLOVE, 3 BOX | 1 | VC | | | 5 | 0 |
| 321 | Ambulatory Care - Primary | USCL1 | 5 | Soiled Utility Room | 2A214, 2B230, 2B246, 2C262, 2C278 | | | REWB307 | RECEPTACLE, WASTE, BIOHAZARD, 44 GAL | 1 | VV | No | | 5 | 0 |
| 322 | Ambulatory Care - Primary | USCL1 | 5 | Soiled Utility Room | 2A214, 2B230, 2B246, 2C262, 2C278 | | | REWB307A | RECEPTACLE LID | 1 | VV | No | | 5 | 0 |
| 323 | Ambulatory Care - Primary | WRCO1 | 1 | Waiting Area (at Atrium) | | | | | | | | | | | 0 |
| 324 | Ambulatory Care - Primary | WRCO1 | 1 | Waiting Area (at Atrium) | 2E400 | | | FURN142 | CHAIR, BARIATRIC / LOVE SEAT | 4 | VV | F | | 4 | 0 |
| 325 | Ambulatory Care - Primary | WRCO1 | 1 | Waiting Area (at Atrium) | 2E400 | | | FURN150 | CHAIR, WAITING ROOM | 23 | VV | F | | 20 | 0 |
| 326 | Ambulatory Care - Primary | WRCO1 | 1 | Waiting Area (at Atrium) | 2E400 | | | FURN160 | CHAIR, KID'S | 0 | VV | F | | 0 | 0 |
| 327 | Ambulatory Care - Primary | WRCO1 | 1 | Waiting Area (at Atrium) | 2E400 | | | FURN400 | TABLE, SIDE | 0 | VV | F | | 0 | |
| 328 | Ambulatory Care - Primary | WRCO1 | 1 | Waiting Area (at Atrium) | 2E400 | | | FURN420 | TABLE, OVAL | 5 | VV | F | | 5 | |
| 329 | Ambulatory Care - Primary | WRCO1 | 1 | Waiting Area (at Atrium) | 2E400 | | | FURN430 | TABLE, ROUND | 3 | VV | F | | 2 | 0 |
| 330 | Ambulatory Care - Primary | WRCO1 | 1 | Waiting Area (at Atrium) | 2E400 | | | FURN450 | TABLE, KID'S PLAY | 0 | VV | F | | 0 | 0 |
| 331 | Ambulatory Care - Primary | WRCO1 | 1 | Waiting Area (at Atrium) | 2E400 | | | REWA320 | RECEPTACLE, WASTE, OFFICE, 28 QT, PUBLIC ZONE | 4 | VV | No | | 4 | 0 |
| 332 | Ambulatory Care - Primary | WRCO1 | 1 | Waiting Area (at Atrium) | 2E400 | | | TELE320 | TELEVISION, FLAT PANEL, 52" LCD | 0 | VV | | WE RECEIVED ONE CUT SHEET WITH TWO EQUIPMENT NUMBERS AND ONLY ONE MODEL INDICATED - ARE THEY TO BE THE SAME SIZE? | 0 | 0 |
| 333 | Ambulatory Care - Primary | WRCO1 | 1 | Waiting Area (E) | | | | | | | | | | | |
| 334 | Ambulatory Care - Primary | WRCO1 | 1 | Waiting Area (E) | 2F407 | | | FURN142 | CHAIR, BARIATRIC / LOVE SEAT | 6 | VV | F | | 6 | |
| 335 | Ambulatory Care - Primary | WRCO1 | 1 | Waiting Area (E) | 2F407 | | | FURN150 | CHAIR, WAITING ROOM | 38 | VV | F | | 38 | 0 |
| 336 | Ambulatory Care - Primary | WRCO1 | 1 | Waiting Area (E) | 2F407 | | | FURN400 | TABLE, SIDE | 11 | VV | F | | 11 | 0 |
| 337 | Ambulatory Care - Primary | WRCO1 | 1 | Waiting Area (E) | 2F407 | | | REWA320 | RECEPTACLE, WASTE, OFFICE, 28 QT, PUBLIC ZONE | 9 | VV | No | | 9 | 0 |
| 338 | Ambulatory Care - Primary | WRCO1 | 1 | Waiting Area (E) | 2F407 | | | TELE320 | TELEVISION, FLAT PANEL, 52" LCD | 4 | VV | | WE RECEIVED ONE CUT SHEET WITH TWO EQUIPMENT NUMBERS AND ONLY ONE MODEL INDICATED - ARE THEY TO BE THE SAME SIZE? | 4 | 0 |
| 339 | Ambulatory Care - Primary | WRCO1 | 1 | Waiting Area (W) | | | | | | | | | | | |
| 340 | Ambulatory Care - Primary | WRCO1 | 1 | Waiting Area (W) | 2D402 | | | FURN142 | CHAIR, BARIATRIC / LOVE SEAT | 4 | VV | F | | 4 | |
| 341 | Ambulatory Care - Primary | WRCO1 | 1 | Waiting Area (W) | 2D402 | | | FURN150 | CHAIR, WAITING ROOM | 34 | VV | F | | 34 | |
| 342 | Ambulatory Care - Primary | WRCO1 | 1 | Waiting Area (W) | 2D402 | | | FURN400 | TABLE, SIDE | 7 | VV | F | | 7 | |
| 343 | Ambulatory Care - Primary | WRCO1 | 1 | Waiting Area (W) | 2D402 | | | REWA320 | RECEPTACLE, WASTE, OFFICE, 28 QT, PUBLIC ZONE | 8 | VV | No | | 8 | |
| 344 | Ambulatory Care - Primary | WRCO1 | 1 | Waiting Area (W) | 2D402 | | | TELE320 | TELEVISION, FLAT PANEL, 52" LCD | 4 | VV | | WE RECEIVED ONE CUT SHEET WITH TWO EQUIPMENT NUMBERS AND ONLY ONE MODEL INDICATED - ARE THEY TO BE THE SAME SIZE? | 3 | |
| 345 | Ambulatory Care - Primary | | 1 | Alcove, Scale | | | | | | | | | | | |
| 346 | Ambulatory Care - Primary | | 1 | Alcove, Scale | 2C410 | 2/20/2014 | | SCST300 | SCALE, STAND ON, PLATFORM, DIGITAL | 1 | VV | | NEED POWER & DATA REQUIREMENTS | 1 | |
| 347 | Ambulatory Care - Primary | | 5 | Alcove, Omni Cell | | | | | | | | | | | |
| 348 | Ambulatory Care - Primary | | 5 | Alcove, Omni Cell | 2A302, 2A311, 2B316, 2C323, 2C328 | 1/31/2014 | 2/20/2014 | SYME302 | OMNIRX THREE CELL / SUPPLIER | 4 | VV | | NEED MODEL NUMBER | 20 | |
| 349 | Ambulatory Care - Primary | | 5 | Alcove, Omni Cell | 2A302, 2A311, 2B316, 2C323, 2C328 | | | SYME302A | INSTALLATION, SEISMIC RESTRAINT | 4 | VV | - | | 20 | |
| 350 | Ambulatory Care - Primary | | 5 | Alcove | | | | | | | | | | | |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|-----------------------------|--------------|----------|-----------------------------------|----------------------------|---------------------|--------------------|------------------|---|--------------|--------------------------|----------------------|---|-----------|-----------------------|
| 351 | Ambulatory Care - Primary | 5 | Alcove | 2A301, 2A312, 2B315, 2C324, 2C327 | | 1/31/2014 | 2/20/2014 | SYME302 | OMNIRX THREE CELL / SUPPLIER | 2 | VV | | NEED MODEL NUMBER | 10 | 0 |
| 352 | Ambulatory Care - Primary | 5 | Alcove | 2A301, 2A312, 2B315, 2C324, 2C327 | | | | SYME302A | INSTALLATION, SEISMIC RESTRAINT | 2 | VV | - | | 10 | |
| 353 | Ambulatory Care - Primary | 5 | Alcove | 2A301, 2A312, 2B315, 2C324, 2C327 | | | | PRMF 201 | PRINTER, MULTI-FUNCTION | 2 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 10 | 0 |
| 354 | Ambulatory Care - Primary | 5 | Print | | | | | | | | | | | | |
| 355 | Ambulatory Care - Primary | 5 | Print | 2A303, 2A310, 2B317, 2C322, 2C329 | | | | PRMF 201 | PRINTER, MULTI-FUNCTION | 2 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 10 | |
| 356 | Ambulatory Care - Primary | 5 | Print | 2A303, 2A310, 2B317, 2C322, 2C329 | | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 1 | VV | F | | | 0 |
| 357 | Ambulatory Care - Primary | 1 | Corridor | | | | | | | | | | Room 22318 | | |
| 358 | Ambulatory Care - Primary | 1 | Corridor | | | | | FURN500 | FILE CABINET, LOCKABLE | 9 | VV | F | | | |
| 359 | Ambulatory Care - Specialty | | | | | | | | | | | | | | 1 |
| 360 | Ambulatory Care - Specialty | EXRG3 | 3 | Exam Room | | | | | | | | | Rooms 3C227, 3C229, 3C231 (PREVIOUSLY 10 ROOM TYPES CHANGED WITH CLINIC REDESIGN) | | 1 |
| 361 | Ambulatory Care - Specialty | EXRG3 | 10 | Exam Room | | 2/20/2014 | | CASP306 | CART, SPECIALTY | 1 | VV | | CUT SHEET IS FROM 2001, IS THE INFORMATION STILL ACCURATE? | 10 | |
| 362 | Ambulatory Care - Specialty | EXRG3 | 10 | Exam Room | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 10 | 0 |
| 363 | Ambulatory Care - Specialty | EXRG3 | 10 | Exam Room | | 2/20/2014 | | COST300 | COMPUTER STATION, WALL MOUNT | 1 | VC | | WAITING ON PRODUCT SELECTION - NEED DIMENSIONS, WEIGHT, AND POWER / DATA REQUIREMENTS | 10 | |
| 364 | Ambulatory Care - Specialty | EXRG3 | 10 | Exam Room | | 2/20/2014 | | COSH321 | CONTAINER, SHARPS, 2 GALLON | 1 | VC | | TWO MODELS LISTED, PLEASE CONFIRM WE ARE USING 8509SA (W/O GLOVE BOX) NEED PRODUCT WEIGHT | 10 | |
| 365 | Ambulatory Care - Specialty | EXRG3 | 10 | Exam Room | | 2/20/2014 | | DIGL300 | DISPENSER, GLOVE, 3 BOX | 1 | VC | | | 10 | |
| 366 | Ambulatory Care - Specialty | EXRG3 | 10 | Exam Room | | | | EQRA300 | EQUIPMENT RAIL, WALL MOUNT | 1 | VC | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 10 | 0 |
| 367 | Ambulatory Care - Specialty | EXRG3 | 10 | Exam Room | | 2/20/2014 | | MOBP302 | MONITOR WITH STAND, BLOOD PRESSURE | 1 | VV | | NEED DIMENSIONS, WEIGHT, POWER REQUIREMENTS | 10 | |
| 368 | Ambulatory Care - Specialty | EXRG3 | 10 | Exam Room | | 2/20/2014 | | MOBP305 | MONITOR, BLOOD PRESSURE, WALL MOUNTED | 1 | VV | | NEED DIMENSIONS, WEIGHT, POWER REQUIREMENTS | 10 | |
| 369 | Ambulatory Care - Specialty | EXRG3 | 10 | Exam Room | | 1/31/2014 | | OTOP300 | OPHTHALMOSCOPE/OTOSCOPE, WALL BOARD | 1 | VC | | WHICH MODEL NUMBER AND ACCESSORY MODULES? (SEE EQRA300 FOR MOUNTING) | 10 | |
| 370 | Ambulatory Care - Specialty | EXRG3 | 10 | Exam Room | | 1/31/2014 | | PRIN300 | PRINTER, LASER | 1 | VV | | ORIGINAL CUT SHEET RECEIVED LATER DECIDED WAS INCORRECT | 10 | 0 |
| 371 | Ambulatory Care - Specialty | EXRG3 | 10 | Exam Room | | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | | 10 | 1 |
| 372 | Ambulatory Care - Specialty | EXRG3 | 10 | Exam Room | | | | SPHY306 | SPHYGMOMANOMETER, HAND HELD | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" (SEE EQRA300 FOR MOUNTING) | 10 | |
| 373 | Ambulatory Care - Specialty | EXRG3 | 10 | Exam Room | | | | STDO350 | STOOL, DR. WITHOUT ARMS, ADJUSTABLE | 1 | VV | No | | 10 | |
| 374 | Ambulatory Care - Specialty | EXRG3 | 10 | Exam Room | | 2/20/2014 | | TAEX302 | TABLE, EXAM, POWER | 1 | VV | | with built-in scale feature | 10 | |
| 375 | Ambulatory Care - Specialty | EXRG3 | 10 | Exam Room | | | | FURN140 | CHAIR, BARIATRIC | 1 | VV | F | | 10 | 1 |
| 376 | Ambulatory Care - Specialty | EXRG3 | 10 | Exam Room | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 10 | |
| 376 | Ambulatory Care - Specialty | EXRG3 | 10 | Exam Room | | | | MOVI300 | V-TEL SYSTEM - SMART TV / MONITOR WITH CISCO SYSTEM | 1 | VV | | | 10 | |
| 377 | Ambulatory Care - Specialty | EXRG3 | 4 | Exam Room, Podiatry | | | | | | | | | | | |
| 378 | Ambulatory Care - Specialty | EXRG3 | 4 | Exam Room, Podiatry | 3A204, 3A206, 3A208, 3A212 | | | CAIS305 | CART, SUPPLY/ISOLATION | 1 | VV | NO | | 4 | 1 |
| 378 | Ambulatory Care - Specialty | EXRG3 | 4 | Exam Room, Podiatry | 3A204, 3A206, 3A208, 3A212 | 2/20/2014 | | CASP306 | CART, SPECIALTY | 1 | VV | | CUT SHEET IS FROM 2001, IS THE INFORMATION STILL ACCURATE? | 4 | 1 |
| 379 | Ambulatory Care - Specialty | EXRG3 | 4 | Exam Room, Podiatry | 3A204, 3A206, 3A208, 3A212 | | | CATR320 | CABINET, TREATMENT, MOBILE W/ HANDLES | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 4 | |
| 380 | Ambulatory Care - Specialty | EXRG3 | 4 | Exam Room, Podiatry | 3A204, 3A206, 3A208, 3A212 | 2/20/2014 | | CHPO300 | CHAIR, PODIATRY | 1 | VV | | | 4 | |
| 381 | Ambulatory Care - Specialty | EXRG3 | 4 | Exam Room, Podiatry | 3A204, 3A206, 3A208, 3A212 | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 4 | 0 |
| 382 | Ambulatory Care - Specialty | EXRG3 | 4 | Exam Room, Podiatry | 3A204, 3A206, 3A208, 3A212 | 2/20/2014 | | COST300 | COMPUTER STATION, WALL MOUNT | 1 | VC | | WAITING ON PRODUCT SELECTION - NEED DIMENSIONS, WEIGHT, AND POWER / DATA REQUIREMENTS | 4 | |
| 383 | Ambulatory Care - Specialty | EXRG3 | 4 | Exam Room, Podiatry | 3A204, 3A206, 3A208, 3A212 | 2/20/2014 | | COSH321 | CONTAINER, SHARPS, 2 GALLON | 1 | VC | | TWO MODELS LISTED, PLEASE CONFIRM WE ARE USING 8509SA (W/O GLOVE BOX) NEED PRODUCT WEIGHT | 4 | |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| | EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/ Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|-----|--|-----------|--------------|-----------------------------|----------------------------|------------|---------------------|--------------------|------------------|---|--------------|---------------------------|----------------------|---|-----------|-----------------------|
| 384 | Ambulatory Care - Specialty | EXRG3 | 4 | Exam Room, Podiatry | 3A204, 3A206, 3A208, 3A212 | | 2/20/2014 | | DIGL300 | DISPENSER, GLOVE, 3 BOX | 1 | VC | | | 4 | |
| 385 | Ambulatory Care - Specialty | EXRG3 | 4 | Exam Room, Podiatry | 3A204, 3A206, 3A208, 3A212 | | | | EQRA300 | EQUIPMENT RAIL, WALL MOUNT | 1 | VC | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 4 | |
| 386 | Ambulatory Care - Specialty | EXRG3 | 4 | Exam Room, Podiatry | 3A204, 3A206, 3A208, 3A212 | | | | FTST300 | STOOL, FOOT, BARIATRIC | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 4 | |
| 387 | Ambulatory Care - Specialty | EXRG3 | 4 | Exam Room, Podiatry | 3A204, 3A206, 3A208, 3A212 | | 2/20/2014 | | MOBP302 | MONITOR WITH STAND, BLOOD PRESSURE | 1 | VV | | NEED DIMENSIONS, WEIGHT, POWER REQUIREMENTS | 4 | 0 |
| 388 | Ambulatory Care - Specialty | EXRG3 | 4 | Exam Room, Podiatry | 3A204, 3A206, 3A208, 3A212 | | 2/20/2014 | | MOBP305 | MONITOR, BLOOD PRESSURE, WALL MOUNTED | 1 | VV | | NEED DIMENSIONS, WEIGHT, POWER REQUIREMENTS | 4 | |
| 389 | Ambulatory Care - Specialty | EXRG3 | 4 | Exam Room, Podiatry | 3A204, 3A206, 3A208, 3A212 | | 1/31/2014 | | PRIN300 | PRINTER, LASER | 1 | VV | | ORIGINAL CUT SHEET RECEIVED LATER DECIDED WAS INCORRECT | 4 | 1 |
| 390 | Ambulatory Care - Specialty | EXRG3 | 4 | Exam Room, Podiatry | 3A204, 3A206, 3A208, 3A212 | | | | OTOP307 | OTOSCOPE/OPHTHALMOSCOPE, DESK UNIT | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 4 | |
| 391 | Ambulatory Care - Specialty | EXRG3 | 4 | Exam Room, Podiatry | 3A204, 3A206, 3A208, 3A212 | | | | OTOP307A | 3.5V STANDARD OPHTHALMOSCOPE HEAD | 1 | VV | - | | 4 | |
| 392 | Ambulatory Care - Specialty | EXRG3 | 4 | Exam Room, Podiatry | 3A204, 3A206, 3A208, 3A212 | | | | OTOP307B | 3.5V DIAGNOSTIC OTOSCOPE HEAD | 1 | VV | - | | 4 | |
| 393 | Ambulatory Care - Specialty | EXRG3 | 4 | Exam Room, Podiatry | 3A204, 3A206, 3A208, 3A212 | | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | | 4 | |
| 394 | Ambulatory Care - Specialty | EXRG3 | 4 | Exam Room, Podiatry | 3A204, 3A206, 3A208, 3A212 | | | | STDO350 | STOOL, DR. WITHOUT ARMS, ADJUSTABLE | 1 | VV | No | | 4 | 1 |
| 395 | Ambulatory Care - Specialty | EXRG3 | 4 | Exam Room, Podiatry | 3A204, 3A206, 3A208, 3A212 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 4 | 1 |
| 395 | Ambulatory Care - Specialty | EXRG3 | 4 | Exam Room, Podiatry | 3A204, 3A206, 3A208, 3A212 | | | | MOVI300 | V-TEL SYSTEM - SMART TV / MONITOR WITH CISCO SYSTEM | 1 | VV | | | 4 | 1 |
| 396 | Ambulatory Care - Specialty | EXRG3 | 3 | Exam Room, Dermatology | | | | | | | | | | Rooms 3B223, 3B225, 3B227 (PREVIOUSLY 2 - ROOM ADDED WITH CLINIC REDESIGN) | | |
| 397 | Ambulatory Care - Specialty | EXRG3 | 2 | Exam Room, Dermatology | | | | | CALS300 | CART, L STYLE | 1 | VV | NO | | 2 | |
| 398 | Ambulatory Care - Specialty | EXRG3 | 2 | Exam Room, Dermatology | | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 2 | |
| 399 | Ambulatory Care - Specialty | EXRG3 | 2 | Exam Room, Dermatology | | | 2/20/2014 | | COST300 | COMPUTER STATION, WALL MOUNT | 1 | VC | | WAITING ON PRODUCT SELECTION - NEED DIMENSIONS, WEIGHT, AND POWER / DATA REQUIREMENTS | 2 | |
| 400 | Ambulatory Care - Specialty | EXRG3 | 2 | Exam Room, Dermatology | | | 2/20/2014 | | COSH321 | CONTAINER, SHARPS, 2 GALLON | 1 | VC | | TWO MODELS LISTED, PLEASE CONFIRM WE ARE USING 8509SA (W/O GLOVE BOX) NEED PRODUCT WEIGHT | 2 | 0 |
| 401 | Ambulatory Care - Specialty | EXRG3 | 2 | Exam Room, Dermatology | | | 2/20/2014 | | DIGL300 | DISPENSER, GLOVE, 3 BOX | 1 | VC | | | 2 | |
| 402 | Ambulatory Care - Specialty | EXRG3 | 2 | Exam Room, Dermatology | | | | | ELEC300 | ELECTROCAUTERY UNIT | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 2 | |
| 403 | Ambulatory Care - Specialty | EXRG3 | 2 | Exam Room, Dermatology | | | | | EQRA300 | EQUIPMENT RAIL, WALL MOUNT | 1 | VC | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 2 | |
| 404 | Ambulatory Care - Specialty | EXRG3 | 2 | Exam Room, Dermatology | | | 1/31/2014 | | OTOP300 | OPHTHALMOSCOPE/OTOSCOPE, WALL BOARD | 1 | VC | | WHICH MODEL NUMBER AND ACCESSORY MODULES? (SEE EQRA300 FOR MOUNTING) | 2 | 0 |
| 405 | Ambulatory Care - Specialty | EXRG3 | 2 | Exam Room, Dermatology | | | 1/31/2014 | | PRIN300 | PRINTER, LASER | 1 | VV | | ORIGINAL CUT SHEET RECEIVED LATER DECIDED WAS INCORRECT | 2 | 1 |
| 406 | Ambulatory Care - Specialty | EXRG3 | 2 | Exam Room, Dermatology | | | | | REWA309 | RECEPTACLE, WASTE XS, 4.5 GAL | 1 | VV | No | | 2 | |
| 407 | Ambulatory Care - Specialty | EXRG3 | 2 | Exam Room, Dermatology | | | | | REWB301 | RECEPTACLE, WASTE, BIOHAZARD, SML, 8 GAL | 1 | VV | No | | 2 | |
| 408 | Ambulatory Care - Specialty | EXRG3 | 2 | Exam Room, Dermatology | | | | | STDO350 | STOOL, DR. WITHOUT ARMS, ADJUSTABLE | 1 | VV | No | | 2 | |
| 409 | Ambulatory Care - Specialty | EXRG3 | 2 | Exam Room, Dermatology | | | 1/31/2014 | | TAPR302 | TABLE, PROCEDURE, POWER | 1 | VV | | | 2 | |
| 410 | Ambulatory Care - Specialty | EXRG3 | 2 | Exam Room, Dermatology | | | | | FURN140 | CHAIR, BARIATRIC | 1 | VV | F | | 2 | 1 |
| 411 | Ambulatory Care - Specialty | EXRG3 | 2 | Exam Room, Dermatology | | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 2 | |
| 411 | Ambulatory Care - Specialty | EXRG3 | 2 | Exam Room, Dermatology | | | | | MOVI300 | V-TEL SYSTEM - SMART TV / MONITOR WITH CISCO SYSTEM | 1 | VV | | | 2 | |
| 412 | Ambulatory Care - Specialty | EXRG3 | 1 | Phototherapy Treatment Room | | | | | | | | | | | | 1 |
| 413 | Ambulatory Care - Specialty | EXRG3 | 1 | Phototherapy Treatment Room | 3B222 | | 1/31/2014 | 2/20/2014 | BOPH301 | BOOTH, PHOTOTHERAPY | 1 | VV | | NEED PRODUCT WEIGHT | 1 | 1 |
| 414 | Ambulatory Care - Specialty | EXRG3 | 1 | Phototherapy Treatment Room | 3B222 | | | | CAIS305 | CART, SUPPLY/ISOLATION | 1 | VV | NO | | 1 | |
| 415 | Ambulatory Care - Specialty | EXRG3 | 1 | Phototherapy Treatment Room | 3B222 | | | | CAST303 | CABINET, STORAGE, 18" DEEP | 1 | VC | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 416 | Ambulatory Care - Specialty | EXRG3 | 1 | Phototherapy Treatment Room | 3B222 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 2 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 2 | |
| 417 | Ambulatory Care - Specialty | EXRG3 | 1 | Phototherapy Treatment Room | 3B222 | | 2/20/2014 | | COST300 | COMPUTER STATION, WALL MOUNT | 1 | VC | | WAITING ON PRODUCT SELECTION - NEED DIMENSIONS, WEIGHT, AND POWER / DATA REQUIREMENTS | 1 | |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/ Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|-----------------------------|--------------|----------|-----------------------------|---------------------|---------------------|--------------------|------------------|-----------|--|---------------------------|----------------------|---|-----------|-----------------------|
| 418 | Ambulatory Care - Specialty | EXRG3 | 1 | Phototherapy Treatment Room | 3B222 | | 2/20/2014 | | COSH321 | CONTAINER, SHARPS, 2 GALLON | 1 | VC | TWO MODELS LISTED, PLEASE CONFIRM WE ARE USING 8509SA (W/O GLOVE BOX) NEED PRODUCT WEIGHT | 1 | |
| 419 | Ambulatory Care - Specialty | EXRG3 | 1 | Phototherapy Treatment Room | 3B222 | | 2/20/2014 | | DIGL300 | DISPENSER, GLOVE, 3 BOX | 2 | VC | | 2 | |
| 420 | Ambulatory Care - Specialty | EXRG3 | 1 | Phototherapy Treatment Room | 3B222 | | | | EQRA300 | EQUIPMENT RAIL, WALL MOUNT | 1 | VC | **NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN** | 1 | |
| 421 | Ambulatory Care - Specialty | EXRG3 | 1 | Phototherapy Treatment Room | 3B222 | | | | HAMP301 | HAMPER, WITH LID, 32" | 1 | VV | No | 1 | 0 |
| 422 | Ambulatory Care - Specialty | EXRG3 | 1 | Phototherapy Treatment Room | 3B222 | | 2/20/2014 | | HAPH301 | HAND/FOOT, PHOTOTHERAPY | 1 | VV | 110-120 VOLT MODEL OR 220-240 VOLT MODEL | 1 | |
| 423 | Ambulatory Care - Specialty | EXRG3 | 1 | Phototherapy Treatment Room | 3B222 | | 2/20/2014 | | LIEX310 | LIGHT, EXAM, MOBILE | 1 | VV | | 1 | |
| 424 | Ambulatory Care - Specialty | EXRG3 | 1 | Phototherapy Treatment Room | 3B222 | | 1/31/2014 | | PRIN300 | PRINTER, LASER | 1 | VV | ORIGINAL CUT SHEET RECEIVED LATER DECIDED WAS INCORRECT | 1 | 0 |
| 425 | Ambulatory Care - Specialty | EXRG3 | 1 | Phototherapy Treatment Room | 3B222 | | 1/31/2014 | 2/20/2014 | REUC315 | REFRIGERATOR, UNDERCOUNTER, ADA | 1 | VV | | 1 | 1 |
| 426 | Ambulatory Care - Specialty | EXRG3 | 1 | Phototherapy Treatment Room | 3B222 | | 1/31/2014 | | REUC315A | TEMPERATURE ALARM WITH PROBE | 1 | VV | | 1 | |
| 427 | Ambulatory Care - Specialty | EXRG3 | 1 | Phototherapy Treatment Room | 3B222 | | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | 1 | 1 |
| 428 | Ambulatory Care - Specialty | EXRG3 | 1 | Phototherapy Treatment Room | 3B222 | | | | REWB301 | RECEPTACLE, WASTE, BIOHAZARD, SML, 8 GAL | 1 | VV | No | 1 | |
| 429 | Ambulatory Care - Specialty | EXRG3 | 1 | Phototherapy Treatment Room | 3B222 | | | | STDO350 | STOOL, DR. WITHOUT ARMS, ADJUSTABLE | 1 | VV | No | 1 | |
| 430 | Ambulatory Care - Specialty | EXRG3 | 1 | Phototherapy Treatment Room | 3B222 | | | | FURN140 | CHAIR, BARIATRIC | 1 | VV | F | 1 | |
| 431 | Ambulatory Care - Specialty | EXRG3 | 1 | Phototherapy Treatment Room | 3B222 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | 1 | |
| 432 | Ambulatory Care - Primary | OFDC4 | 1 | Lactation | | | | | | | | | | | 0 |
| 433 | Ambulatory Care - Primary | OFDC4 | 1 | Lactation | 3D150 | | 2/20/2014 | | BACH300 | BABY CHANGING STATION | 1 | VV | REFER TO SCHEDULE B | 1 | 0 |
| 434 | Ambulatory Care - Primary | OFDC4 | 1 | Lactation | 3D150 | | | | CHGL300 | CHAIR, GLIDER | 2 | VV | No | 2 | 1 |
| 435 | Ambulatory Care - Primary | OFDC4 | 1 | Lactation | 3D150 | | 2/20/2014 | | OVMI303 | OVEN, MICROWAVE | 1 | VV | | 1 | |
| 436 | Ambulatory Care - Primary | OFDC4 | 1 | Lactation | 3D150 | | 1/31/2014 | 2/20/2014 | REUC315 | REFRIGERATOR, UNDERCOUNTER, ADA | 1 | VV | | 1 | |
| 437 | Ambulatory Care - Primary | OFDC4 | 1 | Lactation | 3D150 | | 1/31/2014 | | REUC315A | TEMPERATURE ALARM WITH PROBE | 1 | VV | | 1 | 1 |
| 438 | Ambulatory Care - Primary | OFDC4 | 1 | Lactation | 3D150 | | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | 1 | 1 |
| 439 | Ambulatory Care - Primary | OFDC4 | 1 | Lactation | 3D150 | | | | FURN434 | ROUND TABLE | 2 | VV | F | 2 | |
| 440 | Ambulatory Care - Primary | OFDC4 | 1 | Lactation | 3D150 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | 1 | |
| 441 | Ambulatory Care - Specialty | MEDP1 | 3 | Medication Room | | | | | | | | | | | |
| 442 | Ambulatory Care - Specialty | MEDP1 | 3 | Medication Room | 3A209, 3B219, 3C235 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 3 | |
| 443 | Ambulatory Care - Specialty | MEDP1 | 3 | Medication Room | 3A209, 3B219, 3C235 | | 2/20/2014 | | COSH321 | CONTAINER, SHARPS, 2 GALLON | 1 | VC | TWO MODELS LISTED, PLEASE CONFIRM WE ARE USING 8509SA (W/O GLOVE BOX) NEED PRODUCT WEIGHT | 3 | 0 |
| 444 | Ambulatory Care - Specialty | MEDP1 | 3 | Medication Room | 3A209, 3B219, 3C235 | | 2/20/2014 | | DIGL300 | DISPENSER, GLOVE, 3 BOX | 1 | VC | | 3 | |
| 445 | Ambulatory Care - Specialty | MEDP1 | 3 | Medication Room | 3A209, 3B219, 3C235 | | 1/31/2014 | | MEST330 | MEDICATION, STATION | 1 | VC | WHAT IS THE MODEL NUMBER FOR THE SECOND PIECE OF EQUIPMENT AS INDICATED? | 3 | |
| 446 | Ambulatory Care - Specialty | MEDP1 | 3 | Medication Room | 3A209, 3B219, 3C235 | | | | MEST330A | SEISMIC BRACKET FOR ACUDOSE RX | 1 | VC | - | 3 | 1 |
| 447 | Ambulatory Care - Specialty | MEDP1 | 3 | Medication Room | 3A209, 3B219, 3C235 | | 1/31/2014 | 2/20/2014 | REUC315 | REFRIGERATOR, UNDERCOUNTER, ADA | 1 | VV | | 3 | 1 |
| 448 | Ambulatory Care - Specialty | MEDP1 | 3 | Medication Room | 3A209, 3B219, 3C235 | | 1/31/2014 | | REUC315A | TEMPERATURE ALARM WITH PROBE | 1 | VV | | 3 | |
| 449 | Ambulatory Care - Specialty | MEDP1 | 3 | Medication Room | 3A209, 3B219, 3C235 | | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | 3 | |
| 450 | Ambulatory Care - Specialty | MEDP1 | 3 | Medication Room | 3A209, 3B219, 3C235 | | 1/31/2014 | | SYME300 | OMNIRX ONE CELL / SUPPLIER | 1 | VV | Received 2 different sets of cut sheets, both for Omnicell, but one was labeled with SYSM Equipment code - is this mislabeled and both are for SYME300-302? The only specific product number called out is for a 2-cell unit (with the SYSM Equip no.), what are the product numbers & specifications for the preferred one and three cell units? | 3 | |
| 451 | Ambulatory Care - Specialty | MEDP1 | 3 | Medication Room | 3A209, 3B219, 3C235 | | | | SYME300A | INSTALLATION, SEISMIC RESTRAINT | 1 | VV | - | 3 | 0 |
| 452 | Ambulatory Care - Specialty | MEDP1 | 3 | Medication Room | 3A209, 3B219, 3C235 | | 2/20/2014 | | WAPH300 | WASTE, PHARMACEUTICAL, 2 GAL | 1 | VC | NEED DIMENSIONS & WEIGHT | 3 | 0 |
| 453 | Ambulatory Care - Specialty | MEDP1 | 3 | Medication Room | 3A209, 3B219, 3C235 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | 3 | 0 |
| 454 | Ambulatory Care - Specialty | OFAO2 | 1 | Clerical Office | | | | | | | | | | | 0 |
| 455 | Ambulatory Care - Specialty | OFAO2 | 1 | Clerical Office | 3D101 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | 1 |
| 456 | Ambulatory Care - Specialty | OFAO2 | 1 | Clerical Office | 3D101 | | 1/31/2014 | | PRMF301 | PRINTER, MULTI-FUNCTION | 1 | VV | PRMF301 & COP1300 LISTED ON SAME CUT SHEET WITH ONLY ONE XEROX MODEL CALLED OUT - SIZE DOES NOT WORK IN MOST PRMF301 LOCATIONS | 1 | |
| 457 | Ambulatory Care - Specialty | OFAO2 | 1 | Clerical Office | 3D101 | | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | 1 | |
| 458 | Ambulatory Care - Specialty | OFAO2 | 1 | Clerical Office | 3D101 | | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 1 | VV | F | 1 | |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|-----------------------------|--------------|----------|---------------------|------------|---------------------|--------------------|------------------|---|--------------|--------------------------|----------------------|--|-----------|-----------------------|
| 459 | Ambulatory Care - Specialty | OFA02 | 1 | Clerical Office | 3D101 | | | FURN110 | CHAIR, NO ARMS | 2 | VV | F | | 2 | 0 |
| 460 | Ambulatory Care - Specialty | OFA02 | 1 | Clerical Office | 3D101 | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 1 | VV | F | | 1 | 0 |
| 461 | Ambulatory Care - Specialty | OFA02 | 1 | Clerical Office | 3D101 | | 2/20/2014 | CLWA801 | CLOCK | 1 | VV | | | 1 | 0 |
| 462 | Ambulatory Care - Specialty | OFDC1 | 12 | Consult Room | | | | | | | | | Room 3A203, 3A205, 3A207, 3A211, 3A215, 3A215, 3C228, 3C230, 3C232, 3C237, 3C238, 3C239 (PREVIOUSLY 6 - CHANGED WITH ADDITION OF 5TH MODULE) | | 0 |
| 463 | Ambulatory Care - Specialty | OFDC1 | 6 | Consult Room | | | 2/20/2014 | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 6 | 0 |
| 464 | Ambulatory Care - Specialty | OFDC1 | 6 | Consult Room | | | 2/20/2014 | COST305 | COMPUTER STATION, WALL MOUNT | 1 | VC | | WAITING ON PRODUCT SELECTION - NEED DIMENSIONS, WEIGHT, AND POWER / DATA REQUIREMENTS | 6 | 1 |
| 464 | Ambulatory Care - Specialty | OFDC1 | 6 | Consult Room | | | 2/20/2014 | COST320 | MOBILE WORKSTATION, KIDNEY SHAPED TABLE | 1 | VV | | | 6 | 0 |
| 465 | Ambulatory Care - Specialty | OFDC1 | 6 | Consult Room | | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 1 | VV | F | | 6 | |
| 466 | Ambulatory Care - Specialty | OFDC1 | 6 | Consult Room | | | | FURN110B | CHAIR, NO ARMS | 4 | VV | F | | 24 | |
| 467 | Ambulatory Care - Specialty | OFDC1 | 6 | Consult Room | | | | FURN152 | LOVESEAT | 1 | VV | F | | 6 | |
| 468 | Ambulatory Care - Specialty | OFDC1 | 6 | Consult Room | | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 1 | VV | F | | 1 | 0 |
| 469 | Ambulatory Care - Specialty | OFDC1 | 6 | Consult Room | | | | FURN500 | FILE CABINET, LOCKABLE | 2 | VV | F | | 12 | 1 |
| 470 | Ambulatory Care - Specialty | OFDC1 | 6 | Consult Room | | | 2/20/2014 | CLWA801 | CLOCK | 1 | VV | | | 6 | 0 |
| 470 | Ambulatory Care - Specialty | OFDC1 | 6 | Consult Room | | | | MOVI300 | V-TEL SYSTEM - SMART TV / MONITOR WITH CISCO SYSTEM | 1 | VV | | | 6 | 0 |
| 471 | Ambulatory Care - Specialty | OFDO3 | 1 | Office (north wall) | | | | | | | | | | | 0 |
| 472 | Ambulatory Care - Specialty | OFDO3 | 1 | Office (north wall) | 3C328 | | 2/20/2014 | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | 1 |
| 473 | Ambulatory Care - Specialty | OFDO3 | 1 | Office (north wall) | 3C328 | | 1/31/2014 | PRMF301 | PRINTER, MULTI-FUNCTION | 1 | VV | | PRMF301 & COPI300 LISTED ON SAME CUT SHEET WITH ONLY ONE XEROX MODEL CALLED OUT - SIZE DOES NOT WORK IN MOST PRMF301 LOCATIONS | 1 | |
| 474 | Ambulatory Care - Specialty | OFDO3 | 1 | Office (north wall) | 3C328 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 1 | 1 |
| 475 | Ambulatory Care - Specialty | OFDO3 | 1 | Office (north wall) | 3C328 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 1 | VV | F | | 1 | |
| 476 | Ambulatory Care - Specialty | OFDO3 | 1 | Office (north wall) | 3C328 | | | FURN110 | CHAIR, NO ARMS | 2 | VV | F | | 2 | |
| 477 | Ambulatory Care - Specialty | OFDO3 | 1 | Office (north wall) | 3C328 | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 1 | VV | F | | 1 | |
| 478 | Ambulatory Care - Specialty | OFDO3 | 1 | Office (north wall) | 3C328 | | 2/20/2014 | CLWA801 | CLOCK | 1 | VV | | | 1 | 0 |
| 479 | Ambulatory Care - Specialty | RECP1 | 1 | Central Reception | | | | | | | | | | | 0 |
| 480 | Ambulatory Care - Specialty | RECP1 | 1 | Central Reception | 3D100 | | 2/20/2014 | BISH300 | BIN, SHRED | 2 | VV | | | 2 | 1 |
| 481 | Ambulatory Care - Specialty | RECP1 | 1 | Central Reception | 3D100 | | 2/20/2014 | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 5 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 5 | |
| 482 | Ambulatory Care - Specialty | RECP1 | 1 | Central Reception | 3D100 | | 2/20/2014 | COPY310 | COPIER, HIGH VOLUME | 1 | VV | | | 1 | |
| 483 | Ambulatory Care - Specialty | RECP1 | 1 | Central Reception | 3D100 | | 1/31/2014 | PRMF301 | PRINTER, MULTI-FUNCTION | 1 | VV | | PRMF301 & COPI300 LISTED ON SAME CUT SHEET WITH ONLY ONE XEROX MODEL CALLED OUT - SIZE DOES NOT WORK IN MOST PRMF301 LOCATIONS | 1 | |
| 484 | Ambulatory Care - Specialty | RECP1 | 1 | Central Reception | 3D100 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 5 | VV | No | | 5 | |
| 485 | Ambulatory Care - Specialty | RECP1 | 1 | Central Reception | 3D100 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 4 | VV | F | | 5 | |
| 486 | Ambulatory Care - Specialty | RECP1 | 1 | Central Reception | 3D100 | | 2/20/2014 | CLWA801 | CLOCK | 1 | VV | | | 1 | 0 |
| 486 | Ambulatory Care - Specialty | RECP1 | 1 | Central Reception | 3D100 | | | KIC1300 | KIOSK, CHECK-IN | 3 | VV | | NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN** | 3 | 0 |
| 487 | Ambulatory Care - Specialty | SL001 | 1 | Staff Break Room | | | | | | | | | | | |
| 488 | Ambulatory Care - Specialty | SL001 | 1 | Staff Break Room | 3A300 | | 2/20/2014 | COMA309 | COFFEE MAKER, PLUMBED | 2 | VC | | | 4 | 0 |
| 489 | Ambulatory Care - Specialty | SL001 | 1 | Staff Break Room | 3A300 | | 2/20/2014 | OVMI303 | OVEN, MICROWAVE | 2 | VV | | | 4 | 0 |
| 490 | Ambulatory Care - Specialty | SL001 | 1 | Staff Break Room | 3A300 | | 2/20/2014 | REFR311 | REFRIGERATOR/FREEZER, 21 CU FT W/ ICE MAKER | 3 | VV | | | 6 | 1 |
| 491 | Ambulatory Care - Specialty | SL001 | 1 | Staff Break Room | 3A300 | | | REWA303 | RECEPTACLE, WASTE, 23 GAL, SLIM JIM | 2 | VV | NO | | 4 | |
| 492 | Ambulatory Care - Specialty | SL001 | 1 | Staff Break Room | 3A300 | | | REWA303A | SWING TOP | 2 | VV | - | | 4 | |
| 493 | Ambulatory Care - Specialty | SL001 | 1 | Staff Break Room | 3A300 | | 2/20/2014 | TELE312 | TELEVISION, FLAT PANEL, 52" LCD | 1 | VC | | WE RECEIVED ONE CUT SHEET WITH TWO EQUIPMENT NUMBERS AND ONLY ONE MODEL INDICATED - ARE THEY TO BE THE SAME SIZE? | 2 | |
| 494 | Ambulatory Care - Specialty | SL001 | 1 | Staff Break Room | 3A300 | | | FURN312 | TABLE, ROUND, 4 PERSON | 3 | VV | F | | 6 | |
| 495 | Ambulatory Care - Specialty | SL001 | 1 | Staff Break Room | 3A300 | | | FURN112 | CHAIR, NO ARMS | 12 | VV | F | | 24 | 0 |
| 496 | Ambulatory Care - Specialty | SL001 | 1 | Staff Break Room | 3A300 | | 2/20/2014 | CLWA801 | CLOCK | 1 | VV | | | 2 | 0 |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|-----------------------------|--------------|----------|-----------------------------|---------------------|---------------------|--------------------|------------------|---|--------------|--------------------------|----------------------|--|-----------|-----------------------|
| 497 | Ambulatory Care - Specialty | SL001 | 1 | Staff Break Room | | | | | | | | | | | |
| 498 | Ambulatory Care - Specialty | SL001 | 1 | Staff Break Room | 3C332 | 2/20/2014 | | COMA309 | COFFEE MAKER, PLUMBED | 2 | VC | | | 4 | 0 |
| 499 | Ambulatory Care - Specialty | SL001 | 1 | Staff Break Room | 3C332 | 2/20/2014 | | OVM303 | OVEN, MICROWAVE | 2 | VV | | | 4 | 0 |
| 500 | Ambulatory Care - Specialty | SL001 | 1 | Staff Break Room | 3C332 | 2/20/2014 | | REFR311 | REFRIGERATOR/FREEZER, 21 CU FT W/ ICE MAKER | 3 | VV | | | 6 | 1 |
| 501 | Ambulatory Care - Specialty | SL001 | 1 | Staff Break Room | 3C332 | | | REWA303 | RECEPTACLE, WASTE, 23 GAL, SLIM JIM | 2 | VV | NO | | 4 | |
| 502 | Ambulatory Care - Specialty | SL001 | 1 | Staff Break Room | 3C332 | | | REWA303A | SWING TOP | 2 | VV | - | | 4 | |
| 503 | Ambulatory Care - Specialty | SL001 | 1 | Staff Break Room | 3C332 | 2/20/2014 | | TELE312 | TELEVISION, FLAT PANEL, 52" LCD | 1 | VC | | WE RECEIVED ONE CUT SHEET WITH TWO EQUIPMENT NUMBERS AND ONLY ONE MODEL INDICATED - ARE THEY TO BE THE SAME SIZE? | 2 | |
| 504 | Ambulatory Care - Specialty | SL001 | 1 | Staff Break Room | 3C332 | | | FURN312 | TABLE, ROUND, 4 PERSON | 2 | VV | F | | 6 | |
| 505 | Ambulatory Care - Specialty | SL001 | 1 | Staff Break Room | 3C332 | | | FURN112 | CHAIR, NO ARMS | 10 | VV | F | | 24 | 0 |
| 506 | Ambulatory Care - Specialty | SL001 | 1 | Staff Break Room | 3C332 | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 2 | 0 |
| 507 | Ambulatory Care - Specialty | SL002 | 2 | Teamlet Workroom | | | | | | | | | | 0 | |
| 508 | Ambulatory Care - Specialty | SL002 | 2 | Teamlet Workroom | 3D301, 3F336 | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 24 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 48 | 1 |
| 508 | Ambulatory Care - Specialty | SL002 | 2 | Teamlet Workroom | 3D301, 3F336 | | | MOPT300 | MONITOR, PATIENT TRACKING | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 509 | Ambulatory Care - Specialty | SL002 | 2 | Teamlet Workroom | 3D301, 3F336 | | | HAMP301 | HAMPER, WITH LID, 32" | 6 | VV | No | | 12 | |
| 510 | Ambulatory Care - Specialty | SL002 | 2 | Teamlet Workroom | 3D301, 3F336 | 1/31/2014 | | PRMF301 | PRINTER, MULTI-FUNCTION | 2 | VV | | PRMF301 & COPI300 LISTED ON SAME CUT SHEET WITH ONLY ONE XEROX MODEL CALLED OUT - SIZE DOES NOT WORK IN MOST PRMF301 LOCATIONS | 4 | |
| 511 | Ambulatory Care - Specialty | SL002 | 2 | Teamlet Workroom | 3D301, 3F336 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 12 | VV | No | | 24 | 0 |
| 512 | Ambulatory Care - Specialty | SL002 | 2 | Teamlet Workroom | 3D301, 3F336 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 24 | VV | F | | 48 | 0 |
| 513 | Ambulatory Care - Specialty | SL002 | 2 | Teamlet Workroom | 3D301, 3F336 | | | FURN240 | WORKSTATION, 2'-0" X 4'-0" | 24 | VV | F | | 48 | 0 |
| 514 | Ambulatory Care - Specialty | SL002 | 2 | Teamlet Workroom | 3D301, 3F336 | 2/20/2014 | | CLWA801 | CLOCK | 2 | VV | | | 4 | 1 |
| 515 | Ambulatory Care - Specialty | SL002 | 1 | Teamlet Workroom | | | | | | | | | | | |
| 516 | Ambulatory Care - Specialty | SL002 | 1 | Teamlet Workroom | 3E315 | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 20 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 20 | |
| 516 | Ambulatory Care - Specialty | SL002 | 1 | Teamlet Workroom | 3E315 | | | MOPT300 | MONITOR, PATIENT TRACKING | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | 0 |
| 517 | Ambulatory Care - Specialty | SL002 | 1 | Teamlet Workroom | 3E315 | | | HAMP301 | HAMPER, WITH LID, 32" | 6 | VV | No | | 6 | |
| 518 | Ambulatory Care - Specialty | SL002 | 1 | Teamlet Workroom | 3E315 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 12 | VV | No | | 12 | |
| 519 | Ambulatory Care - Specialty | SL002 | 1 | Teamlet Workroom | 3E315 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 20 | VV | F | | 20 | 0 |
| 520 | Ambulatory Care - Specialty | SL002 | 1 | Teamlet Workroom | 3E315 | | | FURN240 | WORKSTATION, 2'-0" X 4'-0" | 20 | VV | F | | 20 | 0 |
| 521 | Ambulatory Care - Specialty | SL002 | 1 | Teamlet Workroom | 3E315 | 2/20/2014 | | CLWA801 | CLOCK | 2 | VV | | | 2 | 0 |
| 522 | Ambulatory Care - Specialty | | 3 | Print | | | | | | | | | | | |
| 523 | Ambulatory Care - Specialty | | 3 | Print | 3A304, 3B318, 3C333 | 1/31/2014 | | PRMF301 | PRINTER, MULTI-FUNCTION | 2 | VV | | PRMF301 & COPI300 LISTED ON SAME CUT SHEET WITH ONLY ONE XEROX MODEL CALLED OUT - SIZE DOES NOT WORK IN MOST PRMF301 LOCATIONS | 10 | |
| 524 | Ambulatory Care - Specialty | | 3 | Print | 3A304, 3B318, 3C333 | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 1 | VV | F | | | |
| 525 | Ambulatory Care - Specialty | SL002B | 3 | Team Work Area (north wall) | | | | | | | | | | | |
| 526 | Ambulatory Care - Specialty | SL002B | 3 | Team Work Area (north wall) | 3A306, 3B321, 3C331 | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 6 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 18 | |
| 527 | Ambulatory Care - Specialty | SL002B | 3 | Team Work Area (north wall) | 3A306, 3B321, 3C331 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 10 | VV | F | | 18 | |
| 528 | Ambulatory Care - Specialty | SL002B | 3 | Team Work Area (north wall) | 3A306, 3B321, 3C331 | | | FURN240 | WORKSTATION, 2'-0" X 4'-0" | 6 | VV | F | | 18 | 1 |
| 529 | Ambulatory Care - Specialty | SL002B | 3 | Team Work Area (north wall) | 3A306, 3B321, 3C331 | | | FURN430 | TABLE, ROUND | 1 | VV | F | | | 0 |
| 530 | Ambulatory Care - Specialty | SRSO1 | 1 | Storage, Medical Equipment | | | | | | | | | | | |
| 531 | Ambulatory Care - Specialty | SRSO1 | 1 | Storage, Medical Equipment | 3C327 | | | CASU313 | CART, SUPPLY 48X24 | 6 | VV | NO | | 6 | 0 |
| 532 | Ambulatory Care - Specialty | SRSO1 | 1 | Storage, Medical Equipment | 3C327 | 2/20/2014 | | LIEX310 | LIGHT, EXAM MOBILE | 4 | VV | | | 4 | |
| 533 | Ambulatory Care - Specialty | SRSO1 | 1 | Storage, Medical Equipment | 3C327 | | | STMA300 | STAND, MAYO | 4 | VV | No | | 4 | 0 |
| 534 | Ambulatory Care - Specialty | SRSO1 | 1 | Storage, Medical Equipment | 3C327 | 3/7/2014 | | SYEA300 | SYSTEM, EAR WASH | 2 | VV | | NEED PRODUCT DIMENSIONS, WEIGHT, AND POWER REQUIREMENTS | 2 | |
| 535 | Ambulatory Care - Specialty | TLTU1 | 1 | Toilet, Public | | | | | | | | | | | 0 |
| 536 | Ambulatory Care - Specialty | TLTU1 | 1 | Toilet, Public | 3E153 | 2/20/2014 | | BACH300 | BABY CHANGING STATION | 1 | VV | | REFER TO SCHEDULE B | 1 | |
| 537 | Ambulatory Care - Specialty | TLTU1 | 1 | Toilet, Public | 3E153 | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | | 1 | 1 |
| 538 | Ambulatory Care - Specialty | TLTU1 | 7 | Toilet, Patient | | | | | | | | | | | 1 |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/ Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|-----------------------------|--------------|----------|---------------------------------------|---|---------------------|--------------------|------------------|---|--------------|---------------------------|----------------------|---|-----------|-----------------------|
| 539 | Ambulatory Care - Specialty | TLTU1 | 7 | Toilet, Patient | 3A202, 3A217, 3A216, 3B218, 3B221, 3C236, 3C233 | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | | 7 | |
| 540 | Ambulatory Care - Specialty | TLTU1 | 4 | Toilet, Staff | | | | | | | | | | | |
| 541 | Ambulatory Care - Specialty | TLTU1 | 4 | Toilet, Staff | 3A305, 3A203, 3C329, 3C330 | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | | 4 | |
| 542 | Ambulatory Care - Specialty | TRGS1 | 1 | Dermatology Procedure/Treatment Room, | | | | | | | | | | | |
| 543 | Ambulatory Care - Specialty | TRGS1 | 1 | Dermatology Procedure/Treatment Room, | 3B224 | | 2/20/2014 | BUK1300 | BUCKET, KICK | 1 | VV | | | 1 | |
| 544 | Ambulatory Care - Specialty | TRGS1 | 1 | Dermatology Procedure/Treatment Room, | 3B224 | | 2/20/2014 | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | |
| 545 | Ambulatory Care - Specialty | TRGS1 | 1 | Dermatology Procedure/Treatment Room, | 3B224 | | 2/20/2014 | COSH321 | CONTAINER, SHARPS, 2 GALLON | 1 | VC | | TWO MODELS LISTED, PLEASE CONFIRM WE ARE USING 8509SA (W/O GLOVE BOX) NEED PRODUCT WEIGHT | 1 | 3 |
| 546 | Ambulatory Care - Specialty | TRGS1 | 1 | Dermatology Procedure/Treatment Room, | 3B224 | | 2/20/2014 | DIGL300 | DISPENSER, GLOVE, 3 BOX | 1 | VC | | | 1 | |
| 547 | Ambulatory Care - Specialty | TRGS1 | 1 | Dermatology Procedure/Treatment Room, | 3B224 | | | ELUN304 | ELECTROSURGICAL UNIT, BIPOLAR | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 548 | Ambulatory Care - Specialty | TRGS1 | 1 | Dermatology Procedure/Treatment Room, | 3B224 | | 2/20/2014 | ELUN305 | ELECTROSURGICAL UNIT | 1 | VV | | | 1 | |
| 549 | Ambulatory Care - Specialty | TRGS1 | 1 | Dermatology Procedure/Treatment Room, | 3B224 | | 2/20/2014 | ELUN310 | CART, EQUIPMENT, ELECTROSURGICAL UNIT | 1 | VV | | | 1 | 0 |
| 550 | Ambulatory Care - Specialty | TRGS1 | 1 | Dermatology Procedure/Treatment Room, | 3B224 | | | EQRA300 | EQUIPMENT RAIL, WALL MOUNT | 1 | VC | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 551 | Ambulatory Care - Specialty | TRGS1 | 1 | Dermatology Procedure/Treatment Room, | 3B224 | | | HAMP301 | HAMPER, WITH LID, 32" | 1 | VV | No | | 1 | |
| 552 | Ambulatory Care - Specialty | TRGS1 | 1 | Dermatology Procedure/Treatment Room, | 3B224 | | 1/31/2014 | LIPA305 | LIFT, PATIENT, BARIATRIC | 1 | VC | | | 1 | 0 |
| 553 | Ambulatory Care - Specialty | TRGS1 | 1 | Dermatology Procedure/Treatment Room, | 3B224 | | 1/31/2014 | LISU303 | LIGHT, SURGERY, DUAL, CEILING MOUNT | 1 | VC | | | 1 | |
| 554 | Ambulatory Care - Specialty | TRGS1 | 1 | Dermatology Procedure/Treatment Room, | 3B224 | | 1/31/2014 | OTOP300 | OPHTHALMOSCOPE/OTOSCOPE, WALL BOARD | 1 | VC | | WHICH MODEL NUMBER AND ACCESSORY MODULES? (SEE EQRA300 FOR MOUNTING) | 1 | 0 |
| 555 | Ambulatory Care - Specialty | TRGS1 | 1 | Dermatology Procedure/Treatment Room, | 3B224 | | 2/20/2014 | OXPU303 | OXIMETER, PULSE | 1 | VV | | | 1 | 1 |
| 556 | Ambulatory Care - Specialty | TRGS1 | 1 | Dermatology Procedure/Treatment Room, | 3B224 | | 1/31/2014 | PRIN300 | PRINTER, LASER | 1 | VV | | ORIGINAL CUT SHEET RECEIVED LATER DECIDED WAS INCORRECT | 1 | |
| 557 | Ambulatory Care - Specialty | TRGS1 | 1 | Dermatology Procedure/Treatment Room, | 3B224 | | | REWA313 | RECEPTACLE, WASTE, XL, 23 GAL, MOBILE | 1 | VV | No | | 1 | |
| 558 | Ambulatory Care - Specialty | TRGS1 | 1 | Dermatology Procedure/Treatment Room, | 3B224 | | | REWB301 | RECEPTACLE, WASTE, BIOHAZARD, SML, 8 GAL | 1 | VV | No | | 1 | 1 |
| 559 | Ambulatory Care - Specialty | TRGS1 | 1 | Dermatology Procedure/Treatment Room, | 3B224 | | | STDO350 | STOOL, DR. WITHOUT ARMS, ADJUSTABLE | 1 | VV | No | | 1 | 1 |
| 560 | Ambulatory Care - Specialty | TRGS1 | 1 | Dermatology Procedure/Treatment Room, | 3B224 | | 2/20/2014 | TAIN302 | TABLE, INSTRUMENT | 1 | VV | | | 1 | |
| 561 | Ambulatory Care - Specialty | TRGS1 | 1 | Dermatology Procedure/Treatment Room, | 3B224 | | 1/31/2014 | TAPR302 | TABLE, PROCEDURE, POWER | 1 | VV | | | 1 | |
| 562 | Ambulatory Care - Specialty | TRGS1 | 1 | Dermatology Procedure/Treatment Room, | 3B224 | | 2/20/2014 | TAUT300 | TABLE, UTILITY WITH DRAWERS | 1 | VV | | | 1 | 1 |
| 563 | Ambulatory Care - Specialty | TRGS1 | 1 | Dermatology Procedure/Treatment Room, | 3B224 | | 2/20/2014 | CLWA801 | CLOCK | 1 | VV | | | 1 | |
| 563 | Ambulatory Care - Specialty | TRGS1 | 1 | Dermatology Procedure/Treatment Room, | 3B224 | | | MOVI300 | V-TEL SYSTEM - SMART TV / MONITOR WITH CISCO SYSTEM | 1 | VV | | | 1 | |
| 563 | Ambulatory Care - Specialty | | 5 | Patient Corridor | 3A405, 3B407 | | 2/20/2014 | SCWC300 | WHEELCHAIR SCALE | 1 | | | NEED PRODUCT WEIGHT, POWER & DATA REQUIREMENTS - only in 2 corridors | 2 | |
| 563 | Ambulatory Care - Specialty | | 5 | Patient Corridor | | | | | | | | | | | |
| 564 | Ambulatory Care - Specialty | TRGM1 | 1 | Procedure Room | | | | | | | | | | | 0 |
| 565 | Ambulatory Care - Specialty | TRGM1 | 1 | Procedure Room | 3A214 | | 2/20/2014 | CASP306 | CART, SPECIALTY | 1 | VV | No | CUT SHEET IS FROM 2001, IS THE INFORMATION STILL ACCURATE? | 1 | |
| 565 | Ambulatory Care - Specialty | TRGM1 | 1 | Procedure Room | 3A214 | | 2/20/2014 | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | |
| 565 | Ambulatory Care - Specialty | TRGM1 | 1 | Procedure Room | 3A214 | | 2/20/2014 | COST300 | COMPUTER STATION, WALL MOUNT | 1 | VC | | WAITING ON PRODUCT SELECTION - NEED DIMENSIONS, WEIGHT, AND POWER / DATA REQUIREMENTS | 1 | |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|-----------------------------|--------------|----------|--------------------------|---------------------|---------------------|--------------------|------------------|-----------|---|--------------------------|----------------------|---|-----------|-----------------------|
| 565 | Ambulatory Care - Specialty | TRGM1 | 1 | Procedure Room | 3A214 | | 2/20/2014 | | COST320 | MOBILE WORKSTATION, KIDNEY SHAPED TABLE | 1 | VV | | 1 | 0 |
| 566 | Ambulatory Care - Specialty | TRGM1 | 1 | Procedure Room | 3A214 | | 2/20/2014 | | COSH321 | CONTAINER, SHARPS, 2 GALLON | 1 | VC | TWO MODELS LISTED, PLEASE CONFIRM WE ARE USING 8509SA (W/O GLOVE BOX) NEED PRODUCT WEIGHT | 1 | |
| 567 | Ambulatory Care - Specialty | TRGM1 | 1 | Procedure Room | 3A214 | | 2/20/2014 | | DIGL300 | DISPENSER, GLOVE, 3 BOX | 1 | VC | | 1 | 0 |
| 568 | Ambulatory Care - Specialty | TRGM1 | 1 | Procedure Room | 3A214 | | | | EQRA300 | EQUIPMENT RAIL, WALL MOUNT | 1 | VC | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 569 | Ambulatory Care - Specialty | TRGM1 | 1 | Procedure Room | 3A214 | | | | HAMP301 | HAMPER, WITH LID, 32" | 1 | VV | No | 1 | |
| 570 | Ambulatory Care - Specialty | TRGM1 | 1 | Procedure Room | 3A214 | | 2/20/2014 | 3/25/2014 | LIEX305 | LIGHT, EXAM, CEILING HUNG | 1 | VC | | 1 | |
| 571 | Ambulatory Care - Specialty | TRGM1 | 1 | Procedure Room | 3A214 | | 1/31/2014 | | LIPA305 | LIFT, PATIENT, BARIATRIC | 1 | VC | | 1 | |
| 572 | Ambulatory Care - Specialty | TRGM1 | 1 | Procedure Room | 3A214 | | 2/20/2014 | | MOBP302 | MONITOR WITH STAND, BLOOD PRESSURE | 1 | VV | NEED DIMENSIONS, WEIGHT, POWER REQUIREMENTS | 1 | |
| 573 | Ambulatory Care - Specialty | TRGM1 | 1 | Procedure Room | 3A214 | | 2/20/2014 | | MOBP305 | MONITOR, BLOOD PRESSURE, WALL MOUNTED | 1 | VV | NEED DIMENSIONS, WEIGHT, POWER REQUIREMENTS | 1 | 0 |
| 574 | Ambulatory Care - Specialty | TRGM1 | 1 | Procedure Room | 3A214 | | 1/31/2014 | | OTOP300 | OPHTHALMOSCOPE/OTOSCOPE, WALL BOARD | 1 | VC | WHICH MODEL NUMBER AND ACCESSORY MODULES? (SEE EQRA300 FOR MOUNTING) | 1 | 1 |
| 575 | Ambulatory Care - Specialty | TRGM1 | 1 | Procedure Room | 3A214 | | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | 1 | |
| 576 | Ambulatory Care - Specialty | TRGM1 | 1 | Procedure Room | 3A214 | | | | STDO350 | STOOL, DR. WITHOUT ARMS, ADJUSTABLE | 1 | VV | No | 1 | |
| 577 | Ambulatory Care - Specialty | TRGM1 | 1 | Procedure Room | 3A214 | | | | STMA300 | STAND, MAYO | 1 | VV | No | 1 | |
| 578 | Ambulatory Care - Specialty | TRGM1 | 1 | Procedure Room | 3A214 | | 1/31/2014 | | SYME300 | OMNIRX ONE CELL / SUPPLIER | 1 | VV | Received 2 different sets of cut sheets, both for Omnicell, but one was labeled with SYSM Equipment code - is this mislabeled and both are for SYME300-302? The only specific product number called out is for a 2-cell unit (with the SYSM Equip no.), what are the product numbers & specifications for the preferred one and three cell units? | 1 | |
| 579 | Ambulatory Care - Specialty | TRGM1 | 1 | Procedure Room | 3A214 | | | | SYME300A | INSTALLATION, SEISMIC RESTRAINT | 1 | VV | - | 1 | |
| 580 | Ambulatory Care - Specialty | TRGM1 | 1 | Procedure Room | 3A214 | | 1/31/2014 | | TAPR302 | TABLE, PROCEDURE, POWER | 1 | VV | | 1 | |
| 581 | Ambulatory Care - Specialty | TRGM1 | 1 | Procedure Room | 3A214 | | 2/20/2014 | | TAUT300 | TABLE, UTILITY WITH DRAWERS | 1 | VV | | 1 | 1 |
| 582 | Ambulatory Care - Specialty | TRGM1 | 1 | Procedure Room | 3A214 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | 1 | |
| 582 | Ambulatory Care - Specialty | TRGM1 | 1 | Procedure Room | 3A214 | | | | MOVI300 | V-TEL SYSTEM - SMART TV / MONITOR WITH CISCO SYSTEM | 1 | VV | | 1 | |
| 583 | Ambulatory Care - Specialty | UCCL1 | 1 | Clean Utility Room | | | | | | | | | | | |
| 584 | Ambulatory Care - Specialty | UCCL1 | 1 | Clean Utility Room | 3B320 | | | | CACS300 | CART, COLLECTION, SPD | 1 | VV | NO | 1 | |
| 585 | Ambulatory Care - Specialty | UCCL1 | 1 | Clean Utility Room | 3B320 | | | | CAST303 | CABINET, STORAGE, 18" DEEP | 1 | VC | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 586 | Ambulatory Care - Specialty | UCCL1 | 1 | Clean Utility Room | 3B320 | | | | CAUT315 | CART, UTILITY | 1 | VV | NO | 1 | |
| 587 | Ambulatory Care - Specialty | UCCL1 | 1 | Clean Utility Room | 3B320 | | | | HALI301 | HAMPER/CART, LINEN | 1 | VV | No | 1 | |
| 588 | Ambulatory Care - Specialty | UCCL1 | 1 | Clean Utility Room | 3B320 | | 1/31/2014 | 2/20/2014 | SYME302 | OMNIRX THREE CELL / SUPPLIER | 1 | VV | NEED MODEL NUMBER | 1 | 1 |
| 589 | Ambulatory Care - Specialty | UCCL1 | 1 | Clean Utility Room | 3B320 | | | | SYME302A | INSTALLATION, SEISMIC RESTRAINT | 1 | VV | - | 1 | 1 |
| 590 | Ambulatory Care - Specialty | USCL1 | 3 | Soiled Utility Room | | | | | | | | | | | |
| 591 | Ambulatory Care - Specialty | USCL1 | 3 | Soiled Utility Room | 3A210, 3B220, 3C234 | | | | CACS300 | CART, COLLECTION, SPD | 1 | VV | NO | 3 | |
| 592 | Ambulatory Care - Specialty | USCL1 | 3 | Soiled Utility Room | 3A210, 3B220, 3C234 | | | | CAUT300 | CART, UTILITY | 1 | VV | NO | 3 | |
| 593 | Ambulatory Care - Specialty | USCL1 | 3 | Soiled Utility Room | 3A210, 3B220, 3C234 | | | | CONT300 | CONTAINER, BRUTE 32 GAL. | 1 | VV | No | 3 | 0 |
| 594 | Ambulatory Care - Specialty | USCL1 | 3 | Soiled Utility Room | 3A210, 3B220, 3C234 | | | | CONT300A | FLAT TOP FOR BRUTE, 32 GAL | 1 | VV | - | 3 | 0 |
| 595 | Ambulatory Care - Specialty | USCL1 | 3 | Soiled Utility Room | 3A210, 3B220, 3C234 | | | | CONT300B | DOLLY FOR BRUTE, 32 GAL | 1 | VV | - | 3 | 0 |
| 596 | Ambulatory Care - Specialty | USCL1 | 3 | Soiled Utility Room | 3A210, 3B220, 3C234 | | 2/20/2014 | | COSH321 | CONTAINER, SHARPS, 2 GALLON | 1 | VC | TWO MODELS LISTED, PLEASE CONFIRM WE ARE USING 8509SA (W/O GLOVE BOX) NEED PRODUCT WEIGHT | 3 | 0 |
| 597 | Ambulatory Care - Specialty | USCL1 | 3 | Soiled Utility Room | 3A210, 3B220, 3C234 | | 2/20/2014 | | DIGL300 | DISPENSER, GLOVE, 3 BOX | 1 | VC | | 3 | 0 |
| 598 | Ambulatory Care - Specialty | USCL1 | 3 | Soiled Utility Room | 3A210, 3B220, 3C234 | | | | REWB307 | RECEPTACLE, WASTE, BIOHAZARD, 44 GAL | 1 | VV | No | 3 | |
| 599 | Ambulatory Care - Specialty | USCL1 | 3 | Soiled Utility Room | 3A210, 3B220, 3C234 | | | | REWB307A | RECEPTACLE LID | 1 | VV | No | 3 | 0 |
| 600 | Ambulatory Care - Specialty | WRCO1 | 1 | Waiting Area (at Atrium) | | | | | | | | | | | |
| 601 | Ambulatory Care - Specialty | WRCO1 | 1 | Waiting Area (at Atrium) | 3E400 | | | | REWA320 | RECEPTACLE, WASTE, OFFICE, 28 QT, PUBLIC ZONE | 4 | VV | No | 4 | 0 |
| 602 | Ambulatory Care - Specialty | WRCO1 | 1 | Waiting Area (at Atrium) | 3E400 | | | | FURN150 | CHAIR, WAITING ROOM | 24 | VV | F | 20 | 0 |
| 603 | Ambulatory Care - Specialty | WRCO1 | 1 | Waiting Area (at Atrium) | 3E400 | | | | FURN142 | CHAIR, BARIATRIC / LOVE SEAT | 4 | VV | F | 4 | 0 |
| 604 | Ambulatory Care - Specialty | WRCO1 | 1 | Waiting Area (at Atrium) | 3E400 | | | | FURN420 | TABLE, OVAL | 4 | VV | F | 5 | |
| 605 | Ambulatory Care - Specialty | WRCO1 | 1 | Waiting Area (at Atrium) | 3E400 | | | | FURN430 | TABLE, ROUND | 3 | VV | F | 2 | |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/ Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|--------------------------------|--------------|----------|------------------------------|-----------------------------------|---------------------|--------------------|------------------|---|--------------|---------------------------|----------------------|--|-----------|-----------------------|
| 606 | Ambulatory Care - Specialty | WRC01 | 1 | Waiting Area (E) | | | | | | | | | | | |
| 607 | Ambulatory Care - Specialty | WRC01 | 1 | Waiting Area (E) | 3F411 | | | REWA320 | RECEPTACLE, WASTE, OFFICE, 28 QT, PUBLIC ZONE | 9 | VV | No | | 9 | 0 |
| 608 | Ambulatory Care - Specialty | WRC01 | 1 | Waiting Area (E) | 3F411 | | | TELE320 | TELEVISION, FLAT PANEL, 52" LCD | 4 | VV | | WE RECEIVED ONE CUT SHEET WITH TWO EQUIPMENT NUMBERS AND ONLY ONE MODEL INDICATED - ARE THEY TO BE THE SAME SIZE? | 4 | |
| 609 | Ambulatory Care - Specialty | WRC01 | 1 | Waiting Area (E) | 3F411 | | | FURN150 | CHAIR, WAITING ROOM | 38 | VV | F | | 38 | 0 |
| 610 | Ambulatory Care - Specialty | WRC01 | 1 | Waiting Area (E) | 3F411 | | | FURN142 | CHAIR, BARIATRIC / LOVE SEAT | 5 | VV | F | | 5 | 0 |
| 611 | Ambulatory Care - Specialty | WRC01 | 1 | Waiting Area (E) | 3F411 | | | FURN400 | TABLE, SIDE | 11 | VV | F | | 11 | 1 |
| 612 | Ambulatory Care - Specialty | CRA01 | 1 | Conference/Classroom | | | | | | | | | | | |
| 613 | Ambulatory Care - Specialty | CRA01 | 1 | Conference/Classroom | 3E337 | | 2/20/2014 | BOSM300 | BOARD, SMART, INTERACTIVE | 1 | CC | | VA HAS SUPPLIED CUT SHEETS - IS THIS CONTRACTOR ACQUIRED / CONTRACTOR INSTALLED AS INDICATED? | 1 | |
| 614 | Ambulatory Care - Specialty | CRA01 | 1 | Conference/Classroom | 3E337 | | | CACC300 | CAMERA, PORTABLE, CCTV WITH RECORDER, CEILING MOUNT | 1 | VV | | **NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN** | 1 | |
| 616 | Ambulatory Care - Specialty | CRA01 | 1 | Conference/Classroom | 3E337 | | 3/7/2014 | PRLC300 | PROJECTOR, LCD, DIGITAL | 1 | VV | | | 1 | |
| 616 | Ambulatory Care - Specialty | CRA01 | 1 | Conference/Classroom | 3E337 | | 2/20/2014 | SCPR300 | SCREEN, PROJECTOR | 1 | VV | | CEILING OR WALL MOUNTED? NEED POWER REQUIREMENTS | 1 | |
| 616 | Ambulatory Care - Specialty | CRA01 | 1 | Conference/Classroom | 3E337 | | 2/20/2014 | TELE312 | TELEVISION, FLAT PANEL, 52" LCD | 1 | VC | | WE RECEIVED ONE CUT SHEET WITH TWO EQUIPMENT NUMBERS AND ONLY ONE MODEL INDICATED - ARE THEY TO BE THE SAME SIZE? | 1 | |
| 617 | Ambulatory Care - Specialty | CRA01 | 1 | Conference/Classroom | 3E337 | | | FURN340 | TABLE, CONFERENCE, 12 PERSON | 1 | VV | F | | 1 | |
| 618 | Ambulatory Care - Specialty | CRA01 | 1 | Conference/Classroom | 3E337 | | | FURN104 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 12 | VV | F | | 12 | |
| 619 | Ambulatory Care - Specialty | CRA01 | 1 | Conference/Classroom | 3E337 | | 2/20/2014 | CLWA801 | CLOCK | 1 | VV | | | 1 | |
| 620 | Ambulatory Care - Specialty | | 2 | Alcove, Omnicell | | | | | | | | | | | |
| 621 | Ambulatory Care - Specialty | | 2 | Alcove, Omnicell | 3A212, 3C334 | | 1/31/2014 | SYME302 | OMNIRX THREE CELL / SUPPLIER | 4 | VV | | NEED MODEL NUMBER | 8 | |
| 622 | Ambulatory Care - Specialty | | 2 | Alcove, Omnicell | 3A212, 3C334 | | | SYME302A | INSTALLATION, SEISMIC RESTRAINT | 4 | VV | - | | 8 | |
| 623 | Ambulatory Care - Specialty | | 1 | Alcove, Omnicell | | | | | | | | | | | |
| 624 | Ambulatory Care - Specialty | | 1 | Alcove, Omnicell | 3B317 | | 1/31/2014 | SYME302 | OMNIRX THREE CELL / SUPPLIER | 2 | VV | | NEED MODEL NUMBER | 2 | |
| 625 | Ambulatory Care - Specialty | | 1 | Alcove, Omnicell | 3B317 | | | SYME302A | INSTALLATION, SEISMIC RESTRAINT | 2 | VV | - | | 2 | |
| 626 | Ambulatory Care - Specialty | | 1 | Alcove | | | | | | | | | | | |
| 627 | Ambulatory Care - Specialty | | 1 | Alcove | 3B316 | | 1/31/2014 | SYME302 | OMNIRX THREE CELL / SUPPLIER | 2 | VV | | NEED MODEL NUMBER | 2 | |
| 628 | Ambulatory Care - Specialty | | 1 | Alcove | 3B316 | | | SYME302A | INSTALLATION, SEISMIC RESTRAINT | 2 | VV | - | | 2 | |
| 629 | Ambulatory Care - Specialty | | 1 | Alcove | 3B316 | | 1/31/2014 | PRMF301 | PRINTER, MULTI-FUNCTION | 2 | VV | | PRMF301 & C0PI300 LISTED ON SAME CUT SHEET WITH ONLY ONE XEROX MODEL CALLED OUT - SIZE DOES NOT WORK IN MOST PRMF301 LOCATIONS | 2 | |
| 629 | Ambulatory Care - Specialty | | 1 | Corridor | | | | | | | | | Room 3B319 | | |
| 630 | Audiology and Speech Pathology | | | | | | | | | | | | | | |
| 631 | Audiology (AUD) | EXVE1 | 1 | Vestibular Services - Future | | | | | | | | | Room 2D502 | 0 | |
| 632 | Audiology (AUD) | EXEN1 | 1 | Rotary Chair | | | | | | | | | ROOM OMITTED BY VA | 0 | |
| 639 | Audiology (AUD) | EXEN1 | 1 | Rotary Chair | 2D503 | | | FURN116 | CHAIR, WITH ARMS | 2 | VV | F | | | |
| 640 | Audiology (AUD) | EXEN1 | 1 | Rotary Chair | 2D503 | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 1 | VV | F | | | |
| 641 | Audiology (AUD) | | 1 | Alcove, Omnicell | | | | | | | | | | | |
| 642 | Audiology (AUD) | | 1 | Alcove, Omnicell | 2G513 | | 1/31/2014 | SYME301 | OMNIRX TWO CELL / SUPPLIER | 1 | VV | | NEED MODEL NUMBER | 1 | |
| 643 | Audiology (AUD) | | 1 | Print/Copy | | | | | | | | | | | |
| 644 | Audiology (AUD) | | 1 | Print/Copy | 2G516 | | 2/20/2014 | PMRF301 | PRINTER, MULTI-FUNCTION | 1 | VV | | | 1 | 0 |
| 645 | Audiology (AUD) | | 1 | Print/Copy | 2G516 | | | REFR315 | REFRIGERATOR/FREEZER, 21 CU FT, W/ ICE MAKER | 1 | VV | | **NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN** | 1 | 0 |
| 646 | Audiology (AUD) | | 1 | Print/Copy | 2G516 | | 1/31/2014 | REUC315 | REFRIGERATOR, UNDERCOUNTER, ADA | 1 | VV | | | 1 | 0 |
| 647 | Audiology (AUD) | EXOS1 | 5 | Treatment / Office | | | | | | | | | (PREVIOUSLY 6 - 1 ROOM CHANGED TO SHARED ADMIN.) | 0 | |
| 648 | Audiology (AUD) | EXOS1 | 5 | Treatment / Office | 2G505, 2G517, 2G518, 2G520, 2G521 | | 2/20/2014 | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 6 | 0 |
| 650 | Audiology (AUD) | EXOS1 | 5 | Treatment / Office | 2G505, 2G517, 2G518, 2G520, 2G521 | | 1/31/2014 | PRIN300 | PRINTER, LASER | 1 | VV | | ORIGINAL CUT SHEET RECEIVED LATER DECIDED WAS INCORRECT | 6 | |
| 652 | Audiology (AUD) | EXOS1 | 5 | Treatment / Office | 2G505, 2G517, 2G518, 2G520, 2G521 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 6 | |
| 653 | Audiology (AUD) | EXOS1 | 5 | Treatment / Office | 2G505, 2G517, 2G518, 2G520, 2G521 | | | FURN116 | CHAIR, WITH ARMS | 3 | VV | F | | 18 | |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/ Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|-----------------|--------------|----------|--------------------------|-----------------------------------|---------------------|--------------------|------------------|---|--------------|---------------------------|----------------------|---|-----------|-----------------------|
| 654 | Audiology (AUD) | EXOS1 | 5 | Treatment / Office | 2G505, 2G517, 2G518, 2G520, 2G521 | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 1 | VV | F | | 6 | |
| 655 | Audiology (AUD) | EXOS1 | 5 | Treatment / Office | 2G505, 2G517, 2G518, 2G520, 2G521 | | | FURN250 | WORKSTATION, 2'-0" X 3'-0" | 1 | VV | F | | 6 | |
| 656 | Audiology (AUD) | EXOS1 | 5 | Treatment / Office | 2G505, 2G517, 2G518, 2G520, 2G521 | | | FURN520 | CABINET, STORAGE, 1'-6" X 3'-0" | 1 | VV | F | | 6 | 1 |
| 651 | Audiology (AUD) | EXOS1 | 5 | Treatment / Office | 2G505, 2G517, 2G518, 2G520, 2G521 | | | REVO300 | RECORDER, VOICE DIGITAL | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 6 | |
| 657 | Audiology (AUD) | EXOS1 | 5 | Treatment / Office | 2G505, 2G517, 2G518, 2G520, 2G521 | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 6 | |
| 657 | Audiology (AUD) | EXOS1 | 5 | Treatment / Office | 2G505, 2G517, 2G518, 2G520, 2G521 | | | MOVI300 | V-TEL SYSTEM - SMART TV / MONITOR WITH CISCO SYSTEM | 1 | VV | | WILL THESE BE ADDED TO TREATMENT ROOMS? | 6 | |
| 658 | Audiology (AUD) | OPMH1 | 1 | Ear Mold Lab | | | | | | | | | | | |
| 659 | Audiology (AUD) | OPMH1 | 1 | Ear Mold Lab | 2G514 | | | CAST303 | CABINET, STORAGE, 18" DEEP | 4 | VC | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 4 | |
| 660 | Audiology (AUD) | OPMH1 | 1 | Ear Mold Lab | 2G514 | | | CLUL304 | ULTRASONIC WATER BATH | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 661 | Audiology (AUD) | OPMH1 | 1 | Ear Mold Lab | 2G514 | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | 0 |
| 662 | Audiology (AUD) | OPMH1 | 1 | Ear Mold Lab | 2G514 | | | HEAI300 | HEARING AID RESTORATION SYSTEM | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 663 | Audiology (AUD) | OPMH1 | 1 | Ear Mold Lab | 2G514 | | | LATH302 | LATHE | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 664 | Audiology (AUD) | OPMH1 | 4 | Ear Mold Lab | 2G514 | | | QTVI300 | OTOSCOPE, DIGITAL | 4 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 4 | 4 |
| 665 | Audiology (AUD) | OPMH1 | 1 | Ear Mold Lab | 2G514 | 1/31/2014 | | PRIN300 | PRINTER, LASER | 1 | VV | | ORIGINAL CUT SHEET RECEIVED LATER DECIDED WAS INCORRECT | 1 | |
| 666 | Audiology (AUD) | OPMH1 | 1 | Ear Mold Lab | 2G514 | 3/7/2014 | | PRLC300 | PROJECTOR, LCD, DIGITAL | 1 | VC | | | 1 | |
| 667 | Audiology (AUD) | OPMH1 | 1 | Ear Mold Lab | 2G514 | 1/31/2014 | 2/20/2014 | REUC315 | REFRIGERATOR, UNDERCOUNTER, ADA | 1 | VV | | | 1 | |
| 669 | Audiology (AUD) | OPMH1 | 1 | Ear Mold Lab | 2G514 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 1 | 0 |
| 670 | Audiology (AUD) | OPMH1 | 1 | Ear Mold Lab | 2G514 | | | STDO310 | STOOL, DOCTOR, W/O CASTERS | 1 | VV | No | | 1 | |
| 671 | Audiology (AUD) | OPMH1 | 1 | Ear Mold Lab | 2G514 | | | STDO350 | STOOL, DR. WITHOUT ARMS, ADJUSTABLE | 2 | VV | No | | 2 | |
| 668 | Audiology (AUD) | OPMH1 | 1 | Ear Mold Lab | 2G514 | 1/31/2014 | | REUC315A | TEMPERATURE ALARM WITH PROBE | 1 | VV | | | 1 | |
| 672 | Audiology (AUD) | OPMH1 | 1 | Ear Mold Lab | 2G514 | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | |
| 673 | Audiology (AUD) | PEHS4 | 3 | Audiometric Exam | | | | | | | | | | | 0 |
| 674 | Audiology (AUD) | PEHS4 | 3 | Audiometric Exam | 2G506, 2G509, 2G511 | | | ANHE304 | HEARING AID TEST SYSTEM | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 3 | 0 |
| 675 | Audiology (AUD) | PEHS4 | 3 | Audiometric Exam | 2G506, 2G509, 2G511 | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 3 | |
| 677 | Audiology (AUD) | PEHS4 | 3 | Audiometric Exam | 2G506, 2G509, 2G511 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 3 | |
| 678 | Audiology (AUD) | PEHS4 | 3 | Audiometric Exam | 2G506, 2G509, 2G511 | | | STDO350 | STOOL, DR. WITHOUT ARMS, ADJUSTABLE | 1 | VV | No | | 3 | |
| 676 | Audiology (AUD) | PEHS4 | 3 | Audiometric Exam | 2G506, 2G509, 2G511 | 1/31/2014 | | PRIN300 | PRINTER, LASER | 1 | VV | | ORIGINAL CUT SHEET RECEIVED LATER DECIDED WAS INCORRECT | 3 | |
| 679 | Audiology (AUD) | PEHS4 | 3 | Audiometric Exam | 2G506, 2G509, 2G511 | | | TAEQ301 | TABLE, EQUIPMENT, ADJUSTABLE | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 3 | |
| 681 | Audiology (AUD) | PEHS4 | 3 | Audiometric Exam | 2G506, 2G509, 2G511 | | | FURN260 | WORKSTATION, 2'-0" X 5'-0" | 1 | VV | F | | 3 | |
| 682 | Audiology (AUD) | PEHS4 | 3 | Audiometric Exam | 2G506, 2G509, 2G511 | | | FURN116 | CHAIR, WITH ARMS | 2 | VV | F | | 6 | |
| 680 | Audiology (AUD) | PEHS4 | 3 | Audiometric Exam | 2G506, 2G509, 2G511 | | | TYAU300 | TYMPANOMETER, AUDIOMETER | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 3 | |
| 683 | Audiology (AUD) | PEHS4 | 3 | Audiometric Control Room | | | | | | | | | | | |
| 684 | Audiology (AUD) | PEHS4 | 3 | Audiometric Control Room | 2G508, 2G507, 2G512 | | | ANMI300 | ANALYZER, MIDDLE EAR | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 3 | 0 |
| 685 | Audiology (AUD) | PEHS4 | 3 | Audiometric Control Room | 2G508, 2G507, 2G512 | | | AUDI300 | AUDIOMETER WITH CD PLAYER | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 3 | |
| 686 | Audiology (AUD) | PEHS4 | 3 | Audiometric Control Room | 2G508, 2G507, 2G512 | 10/8/2013 | | BOCO500 | BOOTH CONTROL, AUDIOMETRIC | 1 | CC | | audio booth, double wall, 2 room (exam & control) | 3 | 0 |
| 687 | Audiology (AUD) | PEHS4 | 3 | Audiometric Control Room | 2G508, 2G507, 2G512 | | | CAST303 | CABINET, STORAGE, 18" DEEP | 1 | VC | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 3 | 0 |
| 689 | Audiology (AUD) | PEHS4 | 3 | Audiometric Control Room | 2G508, 2G507, 2G512 | | | DVDP301 | PLAYER, DVD | 1 | VV | NO | | 3 | |
| 688 | Audiology (AUD) | PEHS4 | 3 | Audiometric Control Room | 2G508, 2G507, 2G512 | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 3 | 0 |
| 690 | Audiology (AUD) | PEHS4 | 3 | Audiometric Control Room | 2G508, 2G507, 2G512 | 1/31/2014 | | PRIN300 | PRINTER, LASER | 1 | VV | | ORIGINAL CUT SHEET RECEIVED LATER DECIDED WAS INCORRECT | 3 | |
| 692 | Audiology (AUD) | PEHS4 | 3 | Audiometric Control Room | 2G508, 2G507, 2G512 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 3 | |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|-----------------|--------------|----------|---------------------------------|---------------------|---------------------|--------------------|------------------|-------------------------------------|---------------------------|--------------------------|----------------------|--|-----------|-----------------------|
| 693 | Audiology (AUD) | PEHS4 | 3 | Audiometric Control Room | 2G508, 2G507, 2G512 | | | STDO350 | STOOL, DR. WITHOUT ARMS, ADJUSTABLE | 2 | VV | No | | 6 | |
| 694 | Audiology (AUD) | PEHS4 | 3 | Audiometric Control Room | 2G508, 2G507, 2G512 | | | FURN260 | WORKSTATION, 2'-0" X 5'-0" | 1 | VV | F | | 3 | 0 |
| 695 | Audiology (AUD) | PEHS4 | 3 | Audiometric Control Room | 2G508, 2G507, 2G512 | | | FURN250 | WORKSTATION, 2'-0" X 3'-0" | 1 | VV | F | | 3 | |
| 696 | Audiology (AUD) | PEHS4 | 3 | Audiometric Control Room | 2G508, 2G507, 2G512 | | | FURN116 | CHAIR, WITH ARMS | 1 | VV | F | | 3 | |
| 691 | Audiology (AUD) | PEHS4 | 3 | Audiometric Control Room | 2G508, 2G507, 2G512 | | | REVO300 | RECORDER, VOICE DIGITAL | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 3 | |
| 697 | Audiology (AUD) | SECO1 | 1 | Voice Lab | | | | | | | | | | | |
| 698 | Audiology (AUD) | SECO1 | 1 | Voice Lab | 2G510 | | | ANOT300 | ANALYZER, OTOLARYNGOLOGIC, VISIPTCH | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 699 | Audiology (AUD) | SECO1 | 1 | Voice Lab | 2G510 | | | ANOT302 | ANALYZER, OTOLARYNGOLOGIC, SPEECH | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 700 | Audiology (AUD) | SECO1 | 1 | Voice Lab | 2G510 | | | CAST303 | CABINET, STORAGE, 18" DEEP | 3 | VC | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" ventilated for scopes | 3 | 0 |
| 702 | Audiology (AUD) | SECO1 | 1 | Voice Lab | 2G510 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 1 | |
| 701 | Audiology (AUD) | SECO1 | 1 | Voice Lab | 2G510 | | 2/20/2014 | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | 1 |
| 704 | Audiology (AUD) | SECO1 | 1 | Voice Lab | 2G510 | | | SCFL310A | LIGHT SOURCE | 1 | VV | - | | 1 | |
| 703 | Audiology (AUD) | SECO1 | 1 | Voice Lab | 2G510 | | | SCFL310 | SCOPE, FLEXIBLE | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | 0 |
| 706 | Audiology (AUD) | SECO1 | 1 | Voice Lab | 2G510 | | | STDO310 | STOOL, DOCTOR, W/O CASTERS | 2 | VV | No | | 2 | |
| 705 | Audiology (AUD) | SECO1 | 1 | Voice Lab | 2G510 | | | STD1300 | STROBOSCOPY, DIGITAL VIDEO | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 708 | Audiology (AUD) | SECO1 | 1 | Voice Lab | 2G510 | | | FURN116 | CHAIR, WITH ARMS | 3 | VV | F | | 3 | |
| 707 | Audiology (AUD) | SECO1 | 1 | Voice Lab | 2G510 | | | STUN500 | STROBOSCOPY UNIT, VOICE BOX VIDEO | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 707 | Audiology (AUD) | SECO1 | 1 | Voice Lab | 2G510 | | 2/20/2014 | CLWA801 | CLOCK | 1 | VV | | | 1 | 0 |
| 708 | Audiology (AUD) | CRA201 | 2 | Voice Lab | | | | | | | | | | | |
| 709 | Audiology (AUD) | CRA01 | 2 | Group Room | 2D503, 2D502 | | 3/7/2014 | PRLC300 | PROJECTOR, LCD, DIGITAL | 1 | VV | | | 2 | |
| 709 | Audiology (AUD) | CRA01 | 2 | Group Room | 2D503, 2D502 | | 2/20/2014 | SCPR300 | SCREEN, PROJECTOR | 1 | VV | | CEILING OR WALL MOUNTED? NEED POWER REQUIREMENTS | 2 | 1 |
| 709 | Audiology (AUD) | CRA01 | 2 | Group Room | 2D503, 2D502 | | | CACO301 | CART, COMPUTER, POWERED | 1 | | | | 2 | |
| 709 | Audiology (AUD) | CRA01 | 2 | Group Room | 2D503, 2D502 | | 2/20/2014 | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 2 | |
| 709 | Audiology (AUD) | CRA01 | 2 | Group Room | 2D503, 2D502 | | 2/20/2014 | 3/10/2014 | BOSM300 | BOARD, SMART, INTERACTIVE | 1 | CC | VA HAS SUPPLIED CUT SHEETS - IS THIS CONTRACTOR ACQUIRED / CONTRACTOR INSTALLED AS INDICATED? | 2 | |
| 711 | Audiology (AUD) | TLTU1 | 1 | Toilet, Patient | 2G515 | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | | 1 | 0 |
| 710 | Audiology (AUD) | TLTU1 | 1 | Toilet, Patient | | | | | | | | | | 0 | |
| 712 | Business Office | | | | | | | | | | | | | 0 | |
| 713 | Business Office | MRSO1 | 2 | FU Storage | | | | | | | | | Room 1G706, 1G709 | 0 | |
| 714 | Business Office | OFAO2 | 2 | Office, VOA | | | | | | | | | | 1 | |
| 715 | Business Office | OFAO2 | 2 | Office, VOA | 1G706, 1G709 | | 2/20/2014 | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 2 | |
| 717 | Business Office | OFAO2 | 2 | Office, VOA | 1G706, 1G709 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 2 | 0 |
| 718 | Business Office | OFAO2 | 2 | Office, VOA | 1G706, 1G709 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 1 | VV | F | | 2 | 0 |
| 719 | Business Office | OFAO2 | 2 | Office, VOA | 1G706, 1G709 | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 1 | VV | F | | 2 | 0 |
| 720 | Business Office | OFAO2 | 2 | Office, VOA | 1G706, 1G709 | | | FURN530 | FILE, 15" X 36" | 1 | VV | F | | 2 | 0 |
| 721 | Business Office | OFAO2 | 2 | Office, VOA | 1G706, 1G709 | | | FURN110 | CHAIR, NO ARMS | 2 | VV | F | | 4 | |
| 716 | Business Office | OFAO2 | 2 | Office, VOA | 1G706, 1G709 | | 1/31/2014 | PRMF301 | PRINTER, MULTI-FUNCTION | 1 | VV | | PRMF301 & C0P1300 LISTED ON SAME CUT SHEET WITH ONLY ONE XEROX MODEL CALLED OUT - SIZE DOES NOT WORK IN MOST PRMF301 LOCATIONS | 2 | |
| 722 | Business Office | OFAO2 | 2 | Office, VOA | 1G706, 1G709 | | 2/20/2014 | CLWA801 | CLOCK | 1 | VV | | | 2 | |
| 723 | Business Office | OFAO2 | 1 | Office, Health Benefits Advisor | | | | | | | | | | | |
| 725 | Business Office | OFAO2 | 1 | Office, Health Benefits Advisor | 1G708 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 2 | VV | No | | 1 | 0 |
| 726 | Business Office | OFAO2 | 1 | Office, Health Benefits Advisor | 1G708 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 2 | VV | F | | 1 | 0 |
| 727 | Business Office | OFAO2 | 1 | Office, Health Benefits Advisor | 1G708 | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 2 | VV | F | | 1 | 0 |
| 728 | Business Office | OFAO2 | 1 | Office, Health Benefits Advisor | 1G708 | | | FURN110 | CHAIR, NO ARMS | 4 | VV | F | | 2 | 0 |
| 724 | Business Office | OFAO2 | 1 | Office, Health Benefits Advisor | 1G708 | | 2/20/2014 | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 2 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | 0 |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|-----------------|--------------|----------|----------------------------------|------------|---------------------|--------------------|------------------|-------------------------------------|--------------|--------------------------|----------------------|--|-----------|-----------------------|
| 729 | Business Office | OFA02 | 1 | Office, MAS Supervisor | | | | | | | | | | 1 | |
| 730 | Business Office | OFA02 | 1 | Office, MAS Supervisor | 1G705 | | 2/20/2014 | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | |
| 732 | Business Office | OFA02 | 1 | Office, MAS Supervisor | 1G705 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 1 | 0 |
| 733 | Business Office | OFA02 | 1 | Office, MAS Supervisor | 1G705 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 1 | VV | F | | 1 | 0 |
| 734 | Business Office | OFA02 | 1 | Office, MAS Supervisor | 1G705 | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 1 | VV | F | | 1 | 0 |
| 735 | Business Office | OFA02 | 1 | Office, MAS Supervisor | 1G705 | | | FURN530 | BOOKCASE, 15" X 36" | 1 | VV | F | | 1 | 0 |
| 736 | Business Office | OFA02 | 1 | Office, MAS Supervisor | 1G705 | | | FURN110 | CHAIR, NO ARMS | 2 | VV | F | | 2 | |
| 731 | Business Office | OFA02 | 1 | Office, MAS Supervisor | 1G705 | | 1/31/2014 | PRMF301 | PRINTER, MULTI-FUNCTION | 1 | VV | | PRMF301 & COPI300 LISTED ON SAME CUT SHEET WITH ONLY ONE XEROX MODEL CALLED OUT - SIZE DOES NOT WORK IN MOST PRMF301 LOCATIONS | 1 | |
| 737 | Business Office | OFA02 | 1 | Office, MAS Supervisor | 1G705 | | 2/20/2014 | CLWA801 | CLOCK | 1 | VV | | | 1 | |
| 738 | Business Office | OFA03 | 1 | Interview Room/Clerical Stations | | | | | | | | | | 0 | |
| 740 | Business Office | OFA03 | 1 | Interview Room/Clerical Stations | 1G710 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 2 | VV | No | | 1 | 0 |
| 741 | Business Office | OFA03 | 1 | Interview Room/Clerical Stations | 1G710 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 2 | VV | F | | 1 | 1 |
| 742 | Business Office | OFA03 | 1 | Interview Room/Clerical Stations | 1G710 | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 2 | VV | F | | 1 | |
| 743 | Business Office | OFA03 | 1 | Interview Room/Clerical Stations | 1G710 | | | FURN110 | CHAIR, NO ARMS | 4 | VV | F | | 2 | |
| 739 | Business Office | OFA03 | 1 | Interview Room/Clerical Stations | 1G710 | | 2/20/2014 | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 2 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | 0 |
| 744 | Business Office | OFA03 | 1 | Shared Workstation Referral | | | | | | | | | | | |
| 746 | Business Office | OFA03 | 1 | Shared Workstation Referral | 1G711 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 3 | VV | No | | 3 | 0 |
| 747 | Business Office | OFA03 | 1 | Shared Workstation Referral | 1G711 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 3 | VV | F | | 3 | 0 |
| 748 | Business Office | OFA03 | 1 | Shared Workstation Referral | 1G711 | | | FURN270 | WORKSTATION, 2'-0" X 11'-0" | 2 | VV | F | | 2 | 0 |
| 745 | Business Office | OFA03 | 1 | Shared Workstation Referral | 1G711 | | 2/20/2014 | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 3 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 3 | 0 |
| 749 | Business Office | OFA03 | 1 | Shared Workstation Referral | 1G711 | | 2/20/2014 | CLWA801 | CLOCK | 1 | VV | | | 1 | 0 |
| 750 | Business Office | OFA03 | 1 | Office, Clinic Nurse/Tricare | | | | | | | | | | 1 | |
| 751 | Business Office | OFA03 | 1 | Office, Clinic Nurse/Tricare | 1G713 | | 2/20/2014 | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | |
| 753 | Business Office | OFA03 | 1 | Office, Clinic Nurse/Tricare | 1G713 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 1 | |
| 754 | Business Office | OFA03 | 1 | Office, Clinic Nurse/Tricare | 1G713 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 1 | VV | F | | 1 | |
| 755 | Business Office | OFA03 | 1 | Office, Clinic Nurse/Tricare | 1G713 | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 1 | VV | F | | 1 | 0 |
| 756 | Business Office | OFA03 | 1 | Office, Clinic Nurse/Tricare | 1G713 | | | FURN110 | CHAIR, NO ARMS | 2 | VV | F | | 2 | |
| 757 | Business Office | OFA03 | 1 | Office, Clinic Nurse/Tricare | 1G713 | | | FURN530 | FILE, 15" X 36" | 1 | VV | F | | 0 | |
| 752 | Business Office | OFA03 | 1 | Office, Clinic Nurse/Tricare | 1G713 | | 1/31/2014 | PRMF301 | PRINTER, MULTI-FUNCTION | 1 | VV | | PRMF301 & COPI300 LISTED ON SAME CUT SHEET WITH ONLY ONE XEROX MODEL CALLED OUT - SIZE DOES NOT WORK IN MOST PRMF301 LOCATIONS | 1 | 1 |
| 758 | Business Office | OFA03 | 1 | Office, Clinic Nurse/Tricare | 1G713 | | 2/20/2014 | CLWA801 | CLOCK | 1 | VV | | | 1 | |
| 759 | Business Office | SECO1 | 1 | Support, Copy Room | | | | | | | | | | 0 | |
| 760 | Business Office | SECO1 | 1 | Support, Copy Room | 1G707 | | 2/20/2014 | BISH300 | BIN, SHRED | 1 | VV | | | 1 | 0 |
| 763 | Business Office | SECO1 | 1 | Support, Copy Room | 1G707 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 1 | 0 |
| 761 | Business Office | SECO1 | 1 | Support, Copy Room | 1G707 | | 2/20/2014 | COPY310 | COPIER, HIGH VOLUME | 1 | VV | | | 1 | 0 |
| 765 | Business Office | WRCO1 | 1 | Waiting Area | 1G702 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 1 | |
| 764 | Business Office | WRCO1 | 1 | Waiting Area | | | | | | | | | | | |
| 767 | Business Office | WRCO1 | 1 | Waiting Area | 1G702 | | | FURN150 | CHAIR, WAITING ROOM | 12 | VV | F | | 12 | |
| 768 | Business Office | WRCO1 | 1 | Waiting Area | 1G702 | | | FURN142 | CHAIR, BARIATRIC | 3 | VV | F | | 3 | 0 |
| 769 | Business Office | WRCO1 | 1 | Waiting Area | 1G702 | | | FURN430 | SIDE TABLE | 5 | VV | F | | 5 | 0 |
| 766 | Business Office | WRCO1 | 1 | Waiting Area | 1G702 | | 2/20/2014 | TELE312 | TELEVISION, FLAT PANEL, 52" LCD | 1 | VC | | WE RECEIVED ONE CUT SHEET WITH TWO EQUIPMENT NUMBERS AND ONLY ONE MODEL INDICATED - ARE THEY TO BE THE SAME SIZE? | 1 | |
| 770 | Canteen | | | | | | | | | | | | | | |
| 771 | Canteen Service | | 1 | Storage | | | | | | | | | Room 1G106 | | |
| 773 | Canteen Service | BXOO1 | 1 | Vending Machine Area and Seating | 1G610 | | | NOEQ300 | NO MEDICAL EQUIPMENT REQUIRED | | | NO | No Medical Equipment Required | 0 | |
| 772 | Canteen Service | BXOO1 | 1 | Vending Machine Area and Seating | | | | | | | | | | | |
| 775 | Canteen Service | FSCD1 | 1 | Canteen Dining & Cashier | 1G609 | | | NOEQ300 | NO MEDICAL EQUIPMENT REQUIRED | | | NO | No Medical Equipment Required | | |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|-----------------------------|--------------|----------|---------------------------------|------------|---------------------|--------------------|------------------|---|--------------|--------------------------|----------------------|--|-----------|-----------------------|
| 776 | Canteen Service | FSCD1 | 1 | Canteen Dining & Cashier | 1G609 | | | FURN112 | CHAIR, NO ARMS | 56 | VV | F | | | 0 |
| 777 | Canteen Service | FSCD1 | 1 | Canteen Dining & Cashier | 1G609 | | | FURN312 | TABLE, ROUND, 4 PERSON | 14 | VV | F | | | 1 |
| 778 | Canteen Service | FSCD1 | 1 | Canteen Dining & Cashier | | | | | | | | | | | 1 |
| 779 | Canteen Service | PRCO3 | 1 | Canteen Kitchen | 1G119 | | | NOEQ300 | NO MEDICAL EQUIPMENT REQUIRED | | | NO | No Medical Equipment Required | | |
| 778 | Canteen Service | PRCO3 | 1 | Canteen Kitchen | | | | | | | | | | | |
| 781 | Canteen Service | TLTU1 | 1 | Female Toilet, Public | 1G114 | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | | 1 | |
| 780 | Canteen Service | TLTU1 | 1 | Female Toilet, Public | | | | | | | | | | | 0 |
| 782 | Canteen Service | TLTU1 | 1 | Female Toilet, Public | 1G114 | | 2/20/2014 | BACH300 | BABY CHANGING STATION | 1 | VV | | REFER TO SCHEDULE B | 1 | |
| 784 | Canteen Service | TLTU1 | 1 | Male Toilet, Public | 1G115 | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | | 1 | 1 |
| 783 | Canteen Service | TLTU1 | 1 | Male Toilet, Public | | | | | | | | | | | 1 |
| 785 | Canteen Service | TLTU1 | 1 | Male Toilet, Public | 1G115 | | 2/20/2014 | BACH300 | BABY CHANGING STATION | 1 | VV | | REFER TO SCHEDULE B | 1 | |
| 786 | Cardiovascular Laboratories | | | | | | | | | | | | | | |
| 787 | Cardiology | OPHM1 | 1 | Holter Monitor Tech Room (VISN) | | | | | | | | | | | |
| 788 | Cardiology | OPHM1 | 1 | Holter Monitor Tech Room (VISN) | 3B502 | | 2/20/2014 | CASP306 | CART, SPECIALTY | 1 | VV | | CUT SHEET IS FROM 2001, IS THE INFORMATION STILL ACCURATE? | 1 | |
| 789 | Cardiology | OPHM1 | 1 | Holter Monitor Tech Room (VISN) | 3B502 | | 2/20/2014 | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | 0 |
| 790 | Cardiology | OPHM1 | 1 | Holter Monitor Tech Room (VISN) | 3B502 | | 2/20/2014 | COST300 | COMPUTER STATION, WALL MOUNT | 1 | VC | | WAITING ON PRODUCT SELECTION - NEED DIMENSIONS, WEIGHT, AND POWER / DATA REQUIREMENTS | 1 | |
| 791 | Cardiology | OPHM1 | 1 | Holter Monitor Tech Room (VISN) | 3B502 | | 2/20/2014 | COSH321 | CONTAINER, SHARPS, 2 GALLON | 1 | VC | | TWO MODELS LISTED, PLEASE CONFIRM WE ARE USING 8509SA (W/O GLOVE BOX) NEED PRODUCT WEIGHT | 1 | |
| 792 | Cardiology | OPHM1 | 1 | Holter Monitor Tech Room (VISN) | 3B502 | | 2/20/2014 | DIGL300 | DISPENSER, GLOVE, 3 BOX | 1 | VC | | | 1 | |
| 794 | Cardiology | OPHM1 | 1 | Holter Monitor Tech Room (VISN) | 3B502 | | | HAMP301 | HAMPER, WITH LID, 32" | 1 | VV | No | | 1 | |
| 793 | Cardiology | OPHM1 | 1 | Holter Monitor Tech Room (VISN) | 3B502 | | | EQRA300 | EQUIPMENT RAIL, WALL MOUNT | 1 | VC | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 795 | Cardiology | OPHM1 | 1 | Holter Monitor Tech Room (VISN) | 3B502 | | 1/31/2014 | PRMF301 | PRINTER, MULTI-FUNCTION | 1 | VV | | PRMF301 & COPS300 LISTED ON SAME CUT SHEET WITH ONLY ONE XEROX MODEL CALLED OUT - SIZE DOES NOT WORK IN MOST PRMF301 LOCATIONS | 1 | |
| 797 | Cardiology | OPHM1 | 1 | Holter Monitor Tech Room (VISN) | 3B502 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 1 | |
| 796 | Cardiology | OPHM1 | 1 | Holter Monitor Tech Room (VISN) | 3B502 | | | RAAC301 | RAIL, ACCESSORY MOUNTING | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 798 | Cardiology | OPHM1 | 1 | Holter Monitor Tech Room (VISN) | 3B502 | M4100 | | SPHY400 | SPHYGMOMANOMETER, ANEROID, WALL MOUNTED | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 800 | Cardiology | OPHM1 | 1 | Holter Monitor Tech Room (VISN) | 3B502 | | | STDO350 | STOOL, DR. WITHOUT ARMS, ADJUSTABLE | 1 | VV | No | | 1 | |
| 799 | Cardiology | OPHM1 | 1 | Holter Monitor Tech Room (VISN) | 3B502 | M4116 | | SPHY410 | SPHYGMOMANOMETER, ELECTRONIC, MOBILE | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 801 | Cardiology | OPHM1 | 1 | Holter Monitor Tech Room (VISN) | 3B502 | | 2/20/2014 | STRE312 | STRETCHER, TRANSPORT | 1 | VV | | NEED PRODUCT WEIGHT | 1 | |
| 810 | Cardiology | OPHM1 | 1 | Holter Monitor Tech Room (VISN) | 3B502 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 1 | VV | F | | 1 | |
| 811 | Cardiology | OPHM1 | 1 | Holter Monitor Tech Room (VISN) | 3B502 | | | FURN140 | CHAIR, BARIATRIC | 1 | VV | F | | 1 | 1 |
| 809 | Cardiology | OPHM1 | 1 | Holter Monitor Tech Room (VISN) | 3B502 | | | NUCA400 | NURSE CALL | 1 | CC | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | 1 |
| 812 | Cardiology | OPHM1 | 1 | Holter Monitor Tech Room (VISN) | 3B502 | | 2/20/2014 | CLWA801 | CLOCK | 1 | VV | | | 1 | |
| 813 | Cardiology | OPTM1 | 1 | Treadmill | | | | | | | | | | | |
| 814 | Cardiology | OPTM1 | 1 | Treadmill | 3B503 | | | CACR301 | CART, CRASH | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 815 | Cardiology | OPTM1 | 1 | Treadmill | 3B503 | | 2/20/2014 | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | |
| 816 | Cardiology | OPTM1 | 1 | Treadmill | 3B503 | | 2/20/2014 | COST300 | COMPUTER STATION, WALL MOUNT | 1 | VC | | WAITING ON PRODUCT SELECTION - NEED DIMENSIONS, WEIGHT, AND POWER / DATA REQUIREMENTS | 1 | |
| 817 | Cardiology | OPTM1 | 1 | Treadmill | 3B503 | | 2/20/2014 | COSH321 | CONTAINER, SHARPS, 2 GALLON | 1 | VC | | TWO MODELS LISTED, PLEASE CONFIRM WE ARE USING 8509SA (W/O GLOVE BOX) NEED PRODUCT WEIGHT | 1 | |
| 818 | Cardiology | OPTM1 | 1 | Treadmill | 3B503 | M7650 | | DEFI400 | DEFIBRILLATOR/MONITOR, PORTABLE | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | 0 |
| 819 | Cardiology | OPTM1 | 1 | Treadmill | 3B503 | | 2/20/2014 | DIGL300 | DISPENSER, GLOVE, 3 BOX | 1 | VC | | | 1 | |
| 820 | Cardiology | OPTM1 | 1 | Treadmill | 3B503 | | | EQRA300 | EQUIPMENT RAIL, WALL MOUNT | 1 | VC | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 822 | Cardiology | OPTM1 | 1 | Treadmill | 3B503 | | | HAMP301 | HAMPER, WITH LID, 32" | 1 | VV | No | | 1 | |
| 821 | Cardiology | OPTM1 | 1 | Treadmill | 3B503 | M8133 | 3/7/2014 | ERGO400 | ERGOMETER, UPPER BODY | 1 | VV | | | 1 | |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| | EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/ Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|-----|--|-----------|--------------|-----------|--------------|------------|---------------------|--------------------|------------------|---|--------------|---------------------------|----------------------|---|-----------|-----------------------|
| 823 | Cardiology | OPTM1 | 1 | Treadmill | 3B503 | | 1/31/2014 | | PRMF301 | PRINTER, MULTI-FUNCTION | 1 | VV | | PRMF301 & COPI300 LISTED ON SAME CUT SHEET WITH ONLY ONE XEROX MODEL CALLED OUT - SIZE DOES NOT WORK IN MOST PRMF301 LOCATIONS | 1 | |
| 824 | Cardiology | OPTM1 | 1 | Treadmill | 3B503 | M4266 | 3/7/2014 | | PUIN400 | PUMP, VOLUMETRIC INFUSION | 1 | VV | | IS THIS WALL MOUNTED OR COUNTERTOP? | 1 | |
| 826 | Cardiology | OPTM1 | 1 | Treadmill | 3B503 | | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 1 | |
| 827 | Cardiology | OPTM1 | 1 | Treadmill | 3B503 | | | | STDO350 | STOOL, DR. WITHOUT ARMS, ADJUSTABLE | 1 | VV | No | | 1 | |
| 825 | Cardiology | OPTM1 | 1 | Treadmill | 3B503 | | | | RAAC301 | RAIL, ACCESSORY MOUNTING | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 828 | Cardiology | OPTM1 | 1 | Treadmill | 3B503 | | 3/7/2014 | | TREA400 | TREADMILL WITH STRESS TEST SYSTEM | 1 | VV | | NEED MODEL NUMBER - MULTIPLE LISTED IN PROVIDED CUT SHEETS | 1 | |
| 837 | Cardiology | OPTM1 | 1 | Treadmill | 3B503 | | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 1 | VV | F | | 1 | |
| 838 | Cardiology | OPTM1 | 1 | Treadmill | 3B503 | | | | FURN140 | CHAIR, BARIATRIC | 1 | VV | F | | 1 | |
| 836 | Cardiology | OPTM1 | 1 | Treadmill | 3B503 | | | | NUCA400 | NURSE CALL | 1 | CC | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | 1 |
| 839 | Cardiology | OPTM1 | 1 | Treadmill | 3B503 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | |
| 840 | Cardiology | OPPE1 | 1 | Echo Room | | | | | | | | | | | | |
| 841 | Cardiology | OPPE1 | 1 | Echo Room | 3B504 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | |
| 842 | Cardiology | OPPE1 | 1 | Echo Room | 3B504 | | 2/20/2014 | | COST300 | COMPUTER STATION, WALL MOUNT | 1 | VC | | WAITING ON PRODUCT SELECTION - NEED DIMENSIONS, WEIGHT, AND POWER / DATA REQUIREMENTS | 1 | |
| 843 | Cardiology | OPPE1 | 1 | Echo Room | 3B504 | | 2/20/2014 | | COSH321 | CONTAINER, SHARPS, 2 GALLON | 1 | VC | | TWO MODELS LISTED, PLEASE CONFIRM WE ARE USING 8509SA (W/O GLOVE BOX) NEED PRODUCT WEIGHT | 1 | |
| 844 | Cardiology | OPPE1 | 1 | Echo Room | 3B504 | | 2/20/2014 | | DIGL300 | DISPENSER, GLOVE, 3 BOX | 1 | VC | | | 1 | |
| 845 | Cardiology | OPPE1 | 1 | Echo Room | 3B504 | M7008 | 3/7/2014 | | ECHO300 | ECHO BED, POWERED | 1 | VV | | NEED PRODUCT WEIGHT | 1 | |
| 846 | Cardiology | OPPE1 | 1 | Echo Room | 3B504 | M7710 | | | ELCA300 | ELECTROCARDIOGRAPH, 12 LEAD, PORTABLE | 1 | VV | | WILL THIS INCLUDE THE CART? IF SO, WE NEED THE CART'S DIMENSIONS | 1 | |
| 848 | Cardiology | OPPE1 | 1 | Echo Room | 3B504 | | | | HAMP301 | HAMPER, WITH LID, 32" | 1 | VV | No | | 1 | |
| 847 | Cardiology | OPPE1 | 1 | Echo Room | 3B504 | | | | EQRA300 | EQUIPMENT RAIL, WALL MOUNT | 1 | VC | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | 0 |
| 850 | Cardiology | OPPE1 | 1 | Echo Room | 3B504 | | | | MEST330A | SEISMIC BRACKET FOR ACUDOSE RX | 1 | VV | - | | 1 | |
| 849 | Cardiology | OPPE1 | 1 | Echo Room | 3B504 | | 1/31/2014 | | MEST330 | MEDICATION, STATION | 1 | VV | | WHAT IS THE MODEL NUMBER FOR THE SECOND PIECE OF EQUIPMENT AS INDICATED? | 1 | |
| 851 | Cardiology | OPPE1 | 1 | Echo Room | 3B504 | | 1/31/2014 | | PRMF301 | PRINTER, MULTI-FUNCTION | 1 | VV | | PRMF301 & COPI300 LISTED ON SAME CUT SHEET WITH ONLY ONE XEROX MODEL CALLED OUT - SIZE DOES NOT WORK IN MOST PRMF301 LOCATIONS | 1 | |
| 852 | Cardiology | OPPE1 | 1 | Echo Room | 3B504 | | | | RAAC301 | RAIL, ACCESSORY MOUNTING | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 853 | Cardiology | OPPE1 | 1 | Echo Room | 3B504 | | 1/31/2014 | 2/20/2014 | REUC315 | REFRIGERATOR, UNDERCOUNTER, ADA | 1 | VV | | | 1 | |
| 855 | Cardiology | OPPE1 | 1 | Echo Room | 3B504 | | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 1 | |
| 854 | Cardiology | OPPE1 | 1 | Echo Room | 3B504 | | 1/31/2014 | | REUC315A | TEMPERATURE ALARM WITH PROBE | 1 | VV | | | 1 | |
| 856 | Cardiology | OPPE1 | 1 | Echo Room | 3B504 | X2105 | | | SCUL400 | SCANNER, ULTRASOUND, CARDIAC | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 857 | Cardiology | OPPE1 | 1 | Echo Room | 3B504 | M4100 | | | SPHY400 | SPHYGMOMANOMETER, ANEROID, WALL MOUNTED | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 859 | Cardiology | OPPE1 | 1 | Echo Room | 3B504 | | | | STDO350 | STOOL, DR. WITHOUT ARMS, ADJUSTABLE | 1 | VV | No | | 1 | |
| 858 | Cardiology | OPPE1 | 1 | Echo Room | 3B504 | M4116 | | | SPHY410 | SPHYGMOMANOMETER, ELECTRONIC, MOBILE | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 861 | Cardiology | OPPE1 | 1 | Echo Room | 3B504 | | | | SYME300A | INSTALLATION, SEISMIC RESTRAINT | 1 | VV | - | | 1 | |
| 860 | Cardiology | OPPE1 | 1 | Echo Room | 3B504 | | 1/31/2014 | | SYME300 | OMNIRX ONE CELL / SUPPLIER | 1 | VV | | Received 2 different sets of cut sheets, both for Omnicell, but one was labeled with SYSM Equipment code - is this mislabeled and both are for SYME300-302? The only specific product number called out is for a 2-cell unit (with the SYSM Equip no.), what are the product numbers & specifications for the preferred one and three cell units? | 1 | |
| 869 | Cardiology | OPPE1 | 1 | Echo Room | 3B504 | | | | NUCA400 | NURSE CALL | 1 | CC | NO | | 1 | 1 |
| 870 | Cardiology | OPPE1 | 1 | Echo Room | 3B504 | | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 1 | VV | F | Not shown, may not fit | 1 | 1 |
| 871 | Cardiology | OPPE1 | 1 | Echo Room | 3B504 | | | | FURN200 | WORKSTATION, 2'-6" X 4'-0" | 1 | VV | F | | 1 | |
| 872 | Cardiology | OPPE1 | 1 | Echo Room | 3B504 | | | | FURN140 | CHAIR, BARIATRIC | 1 | VV | F | | 1 | 1 |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/ Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|-------------------|--------------|----------|--------------|-----------------------------------|---------------------|--------------------|------------------|---|--------------|---------------------------|----------------------|---|-----------|-----------------------|
| 873 | Cardiology | OPPE1 | 1 | Echo Room | 3B504 | | 2/20/2014 | CLWA801 | CLOCK | 1 | VV | | | 1 | |
| 873 | Cardiology | OPPE1 | 1 | Echo Room | 3B504 | | | MOVI300 | V-TEL SYSTEM - SMART TV / MONITOR WITH CISCO SYSTEM | 1 | VV | | | 1 | |
| 874 | Cardiology | OPEC1 | 1 | ECG / Exam | | | | | | | | | | | |
| 875 | Cardiology | OPEC1 | 1 | ECG / Exam | 3B505 | | 2/20/2014 | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | |
| 876 | Cardiology | OPEC1 | 1 | ECG / Exam | 3B505 | | 2/20/2014 | COST300 | COMPUTER STATION, WALL MOUNT | 1 | VC | | WAITING ON PRODUCT SELECTION - NEED DIMENSIONS, WEIGHT, AND POWER / DATA REQUIREMENTS | 1 | |
| 877 | Cardiology | OPEC1 | 1 | ECG / Exam | 3B505 | | 2/20/2014 | COSH321 | CONTAINER, SHARPS, 2 GALLON | 1 | VC | | TWO MODELS LISTED, PLEASE CONFIRM WE ARE USING 8509SA (W/O GLOVE BOX) NEED PRODUCT WEIGHT | 1 | 0 |
| 878 | Cardiology | OPEC1 | 1 | ECG / Exam | 3B505 | | 2/20/2014 | DIGL300 | DISPENSER, GLOVE, 3 BOX | 1 | VC | | | 1 | |
| 879 | Cardiology | OPEC1 | 1 | ECG / Exam | 3B505 | M7008 | 3/7/2014 | ECHO300 | ECHO BED, POWERED | 1 | VV | | NEED PRODUCT WEIGHT | 1 | |
| 880 | Cardiology | OPEC1 | 1 | ECG / Exam | 3B505 | M7710 | | ELCA300 | ELECTROCARDIOGRAPH, 12 LEAD, PORTABLE | 1 | VV | | WILL THIS INCLUDE THE CART? IF SO, WE NEED THE CART'S DIMENSIONS | 1 | |
| 882 | Cardiology | OPEC1 | 1 | ECG / Exam | 3B505 | | | HAMP301 | HAMPER, WITH LID, 32" | 1 | VV | No | | 1 | |
| 881 | Cardiology | OPEC1 | 1 | ECG / Exam | 3B505 | | | EQRA300 | EQUIPMENT RAIL, WALL MOUNT | 1 | VC | | **NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN** | 1 | |
| 883 | Cardiology | OPEC1 | 1 | ECG / Exam | 3B505 | | 1/31/2014 | PRMF301 | PRINTER, MULTI-FUNCTION | 1 | VV | | PRMF301 & C0PI300 LISTED ON SAME CUT SHEET WITH ONLY ONE XEROX MODEL CALLED OUT - SIZE DOES NOT WORK IN MOST PRMF301 LOCATIONS | 1 | |
| 885 | Cardiology | OPEC1 | 1 | ECG / Exam | 3B505 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 1 | |
| 884 | Cardiology | OPEC1 | 1 | ECG / Exam | 3B505 | | | RAAC301 | RAIL, ACCESSORY MOUNTING | 1 | VV | | **NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN** | 1 | |
| 886 | Cardiology | OPEC1 | 1 | ECG / Exam | 3B505 | M4100 | | SPHY400 | SPHYGMOMANOMETER, ANEROID, WALL MOUNTED | 1 | VV | | **NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN** | 1 | |
| 887 | Cardiology | OPEC1 | 1 | ECG / Exam | 3B505 | M4116 | | SPHY410 | SPHYGMOMANOMETER, ELECTRONIC, MOBILE | 1 | VV | | **NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN** | 1 | |
| 889 | Cardiology | OPEC1 | 1 | ECG / Exam | 3B505 | | | SYME300A | INSTALLATION, SEISMIC RESTRAINT | 1 | VV | - | | 1 | |
| 888 | Cardiology | OPEC1 | 1 | ECG / Exam | 3B505 | | 1/31/2014 | SYME300 | OMNIRX ONE CELL / SUPPLIER | 1 | VV | | Received 2 different sets of cut sheets, both for Omnicell, but one was labeled with SYSM Equipment code - is this mislabeled and both are for SYME300-302? The only specific product number called out is for a 2-cell unit (with the SYSM Equip no.), what are the product numbers & specifications for the preferred one and three cell units? | 1 | |
| 897 | Cardiology | OPEC1 | 1 | ECG / Exam | 3B505 | | | NUCA400 | NURSE CALL | 1 | CC | NO | | 1 | |
| 898 | Cardiology | OPEC1 | 1 | ECG / Exam | 3B505 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 1 | VV | F | | 1 | 0 |
| 899 | Cardiology | OPEC1 | 1 | ECG / Exam | 3B505 | | | FURN210 | WORKSTATION, 2'-6" X 4'-0" | 1 | VV | F | Not shown, may not fit | 1 | 0 |
| 900 | Cardiology | OPEC1 | 1 | ECG / Exam | 3B505 | | | FURN140 | CHAIR, BARIATRIC | 1 | VV | F | | 1 | 1 |
| 901 | Cardiology | OPEC1 | 1 | ECG / Exam | 3B505 | | 2/20/2014 | CLWA801 | CLOCK | 1 | VV | | | 1 | 0 |
| 901 | Cardiology | OPEC1 | 1 | ECG / Exam | 3B505 | | | MOVI300 | V-TEL SYSTEM - SMART TV / MONITOR WITH CISCO SYSTEM | 1 | VV | | | 1 | 0 |
| 902 | Clinic Management | | | | | | | | | | | | | | 1 |
| 903 | Clinic Management | OFA02 | 5 | Office | | | | | | | | | | | |
| 904 | Clinic Management | OFA02 | 5 | Office | 2G603, 2G604, 2G606, 2G609, 2G613 | | 2/20/2014 | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 5 | |
| 906 | Clinic Management | OFA02 | 5 | Office | 2G603, 2G604, 2G606, 2G609, 2G613 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 5 | 0 |
| 907 | Clinic Management | OFA02 | 5 | Office | 2G603, 2G604, 2G606, 2G609, 2G613 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 1 | VV | F | | 5 | 0 |
| 908 | Clinic Management | OFA02 | 5 | Office | 2G603, 2G604, 2G606, 2G609, 2G613 | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 1 | VV | F | | 5 | 0 |
| 909 | Clinic Management | OFA02 | 5 | Office | 2G603, 2G604, 2G606, 2G609, 2G613 | | | FURN110 | CHAIR, NO ARMS | 2 | VV | F | | 10 | 1 |
| 905 | Clinic Management | OFA02 | 5 | Office | 2G603, 2G604, 2G606, 2G609, 2G613 | | 1/31/2014 | PRMF301 | PRINTER, MULTI-FUNCTION | 1 | VV | | PRMF301 & C0PI300 LISTED ON SAME CUT SHEET WITH ONLY ONE XEROX MODEL CALLED OUT - SIZE DOES NOT WORK IN MOST PRMF301 LOCATIONS | 5 | |
| 910 | Clinic Management | OFA02 | 5 | Office | 2G603, 2G604, 2G606, 2G609, 2G613 | | 2/20/2014 | CLWA801 | CLOCK | 1 | VV | | | 5 | |
| 911 | Clinic Management | OFC02 | 3 | Admin Shared | | | | | | | | | | | |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| | EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/ Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|-----|--|-----------|--------------|-----------------|---------------------|------------|---------------------|--------------------|------------------|---|--------------|---------------------------|----------------------|--|-----------|-----------------------|
| 912 | Clinic Management | OFC02 | 3 | Admin Shared | 2G608, 2G605, 2G611 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 2 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 8 | |
| 914 | Clinic Management | OFC02 | 3 | Admin Shared | 2G608, 2G605, 2G611 | | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 4 | 0 |
| 915 | Clinic Management | OFC02 | 3 | Admin Shared | 2G608, 2G605, 2G611 | | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 2 | VV | F | | 8 | 0 |
| 916 | Clinic Management | OFC02 | 3 | Admin Shared | 2G608, 2G605, 2G611 | | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 2 | VV | F | | 8 | 1 |
| 913 | Clinic Management | OFC02 | 3 | Admin Shared | 2G608, 2G605, 2G611 | | 1/31/2014 | | PRMF301 | PRINTER, MULTI-FUNCTION | 1 | VV | | PRMF301 & C0P1300 LISTED ON SAME CUT SHEET WITH ONLY ONE XEROX MODEL CALLED OUT - SIZE DOES NOT WORK IN MOST PRMF301 LOCATIONS | 4 | 0 |
| 917 | Clinic Management | OFC02 | 3 | Admin Shared | 2G608, 2G605, 2G611 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 4 | |
| 918 | Clinic Management | OFC02 | 1 | Admin Shared | | | | | | | | | | | | 0 |
| 919 | Clinic Management | OFC02 | 1 | Admin Shared | 2G602 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 4 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 8 | |
| 921 | Clinic Management | OFC02 | 1 | Admin Shared | 2G602 | | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 4 | |
| 922 | Clinic Management | OFC02 | 1 | Admin Shared | 2G602 | | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 4 | VV | F | | 8 | 1 |
| 923 | Clinic Management | OFC02 | 1 | Admin Shared | 2G602 | | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 4 | VV | F | | 8 | |
| 920 | Clinic Management | OFC02 | 1 | Admin Shared | 2G602 | | 1/31/2014 | | PRMF301 | PRINTER, MULTI-FUNCTION | 1 | VV | | PRMF301 & C0P1300 LISTED ON SAME CUT SHEET WITH ONLY ONE XEROX MODEL CALLED OUT - SIZE DOES NOT WORK IN MOST PRMF301 LOCATIONS | 4 | |
| 924 | Clinic Management | OFC02 | 1 | Admin Shared | 2G602 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 4 | |
| 926 | Clinic Management | PRC03 | 1 | Kitchenette | 2G612 | | | | REWA303 | RECEPTACLE, WASTE, 23 GAL, SLIM JIM | 1 | VV | NO | | 1 | |
| 925 | Clinic Management | PRC03 | 1 | Kitchenette | | | | | | | | | | | | |
| 927 | Clinic Management | PRC03 | 1 | Kitchenette | 2G612 | | 2/20/2014 | | COMA309 | COFFEE MAKER, PLUMBED | 1 | VC | | | 1 | |
| 928 | Clinic Management | PRC03 | 1 | Kitchenette | 2G612 | | 2/20/2014 | | OVMI303 | OVEN, MICROWAVE | 1 | VV | | | 1 | 0 |
| 929 | Clinic Management | PRC03 | 1 | Kitchenette | 2G612 | | 2/20/2014 | | REFR311 | REFRIGERATOR/FREEZER, 21 CU FT W/ ICE MAKER | 1 | VV | | | 1 | |
| 930 | Clinic Management | PRC03 | 1 | Kitchenette | 2G612 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | 0 |
| 931 | Clinic Management | CRA01 | 1 | Conference | | | | | | | | | | | | 0 |
| 932 | Clinic Management | CRA01 | 1 | Conference | 2G600 | | | | CAC0301 | CART, COMPUTER, POWERED | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | 1 |
| 933 | Clinic Management | CRA01 | 1 | Conference | 2G600 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | |
| 934 | Clinic Management | CRA01 | 1 | Conference | 2G600 | | 3/7/2014 | | PRLC300 | PROJECTOR, LCD, DIGITAL | 1 | VC | | | 1 | 1 |
| 936 | Clinic Management | CRA01 | 1 | Conference | 2G600 | | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 1 | |
| 935 | Clinic Management | CRA01 | 1 | Conference | 2G600 | | | | PSFR300 | PROJECTION SCREEN, FLUSH CEILING RECESSED | 1 | CC | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 938 | Clinic Management | CRA01 | 1 | Conference | 2G600 | | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 12 | VV | F | | 12 | |
| 939 | Clinic Management | CRA01 | 1 | Conference | 2G600 | | | | FURN360 | CONFERENCE TABLE, 14 PERSON | 1 | VV | F | | 1 | |
| 937 | Clinic Management | CRA01 | 1 | Conference | 2G600 | | 2/20/2014 | | TELE312 | TELEVISION, FLAT PANEL, 52" LCD | 1 | VC | | WE RECEIVED ONE CUT SHEET WITH TWO EQUIPMENT NUMBERS AND ONLY ONE MODEL INDICATED - ARE THEY TO BE THE SAME SIZE? | 1 | 0 |
| 940 | Clinic Management | CRA01 | 1 | Conference | 2G600 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | |
| 941 | Clinic Management | SRSE1 | 1 | Document Center | | | | | | | | | | | | |
| 942 | Clinic Management | SRSE1 | 1 | Document Center | 2G607 | | 2/20/2014 | | BISH300 | BIN, SHRED | 1 | VV | | | 1 | |
| 943 | Clinic Management | SRSE1 | 1 | Document Center | 2G607 | | 2/20/2014 | | COPY310 | COPIER, HIGH VOLUME | 1 | VV | | | 1 | |
| 945 | Clinic Management | SRSE1 | 1 | Document Center | 2G607 | | | | REWA305 | RECEPTACLE, WASTE, 14 QT | 1 | VV | No | | 1 | |
| 944 | Clinic Management | SRSE1 | 1 | Document Center | 2G607 | | | | MASY300 | MAIL SYSTEM | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 946 | Engineering Bio Med | | | | | | | | | | | | | | | |
| 947 | Engineering BioMed | BMER1 | 1 | VA Storage | | | | | | | | | | | | |
| 948 | Engineering BioMed | BMER1 | 1 | VA Storage | 1B901 | T8045 | | | OSCI400 | OSCILLOSCOPE, WITH ACCESSORIES | 2 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 2 | |
| 949 | Engineering BioMed | BMER1 | 1 | VA Storage | 1B901 | T0015 | | | DEAN400 | DEFIBRILLATOR ANALYZER, AUTOMATIC, PORTABLE | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 950 | Engineering BioMed | BMER1 | 1 | VA Storage | 1B901 | T0020 | | | STTE400 | STAND, TEST, RADIOLOGICAL COMPLIANCE | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 951 | Engineering BioMed | BMER1 | 1 | VA Storage | 1B901 | T0030 | | | RAAN400 | RADIATION-LIGHT FIELD ANALYZER | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 952 | Engineering BioMed | BMER1 | 1 | VA Storage | 1B901 | T0801 | | | W0BE800 | WORKBENCH, ELECTRIC, 2'-6"x6'-0" | 3 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 3 | |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/ Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|------------------------------|--------------|----------|--------------------------------|---|---------------------|--------------------|------------------|--|--------------|---------------------------|----------------------|--|-----------|-----------------------|
| 953 | Engineering BioMed | BMER1 | 1 | VA Storage | 1B901 | T0815 | | CAAU400 | CALIBRATOR, AUDIOMETER | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | 0 |
| 954 | Engineering BioMed | BMER1 | 1 | VA Storage | 1B901 | T8020 | | GEPU400 | GENERATOR, PULSE | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | 0 |
| 955 | Engineering BioMed | BMER1 | 1 | VA Storage | 1B901 | T8025 | | GEFU400 | GENERATOR, FUNCTION | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | 0 |
| 956 | Engineering BioMed | BMER1 | 1 | VA Storage | 1B901 | T8055 | | WAUL400 | WATTMETER, ULTRASONIC | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | 0 |
| 957 | Engineering BioMed | BMER1 | 1 | VA Storage | 1B901 | | 2/20/2014 | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | 0 |
| 959 | Engineering BioMed | BMER1 | 1 | VA Storage | 1B901 | | | SHEL301 | SHELVING, 18" DEEP | 2 | VV | No | | 2 | 1 |
| 960 | Engineering BioMed | BMER1 | 1 | VA Storage | 1B901 | | | STDO350 | STOOL, DR. WITHOUT ARMS, ADJUSTABLE | 3 | VV | No | | 3 | |
| 961 | Engineering BioMed | BMER1 | 1 | VA Storage | 1B901 | | | FURN530 | BOOKCASE, 15" X 36" | 1 | VV | F | | 1 | |
| 962 | Engineering BioMed | BMER1 | 1 | VA Storage | 1B901 | | | FURN590 | TOOL CABINET | 1 | VV | F | | 1 | |
| 963 | Engineering BioMed | BMER1 | 1 | VA Storage | 1B901 | | | FURN575 | FLAMMABLE CABINET | 1 | VV | F | | 1 | |
| 964 | Engineering BioMed | BMER1 | 1 | VA Storage | 1B901 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 1 | VV | F | | 1 | |
| 965 | Engineering BioMed | BMER1 | 1 | VA Storage | 1B901 | | | FURN110 | CHAIR, NO ARMS | 1 | VV | F | | 1 | |
| 966 | Engineering BioMed | BMER1 | 1 | VA Storage | 1B901 | | | FURN214 | WORKSTATION, 2'-6" X 3'-6" | 1 | VV | F | | 1 | |
| 958 | Engineering BioMed | BMER1 | 1 | VA Storage | 1B901 | | 1/31/2014 | PRIN300 | PRINTER, LASER | 1 | VV | | ORIGINAL CUT SHEET RECEIVED LATER DECIDED WAS INCORRECT | 1 | 0 |
| 967 | Engineering BioMed | BMER1 | 1 | VA Storage | 1B901 | F3200 | 2/20/2014 | CLWA801 | CLOCK | 2 | VV | | | 2 | |
| 969 | BioMed Storage | BMER1 | 1 | VA Storage | 1A900 | | | SHEL301 | SHELVING, 18" DEEP | 3 | VC | No | | 3 | |
| 968 | BioMed Storage | BMER1 | 1 | VA Storage | | | | | | | | | | | 0 |
| 970 | Environment Management (EMS) | | | | | | | | | | | | | | |
| 972 | EMS | JANC1 | 7 | Housekeeping Aids Closet (HAC) | 1B955, 1F957, 1G958, 2A950, 2G953, 3A950, 3G953 | | | CAHO301 | CART, HOUSEKEEPING | 1 | VV | NO | | 7 | |
| 973 | EMS | JANC1 | 7 | Housekeeping Aids Closet (HAC) | 1B955, 1F957, 1G958, 2A950, 2G953, 3A950, 3G953 | | | CLVA300 | CLEANER, VACUUM | 1 | VV | NO | | 7 | |
| 971 | EMS | JANC1 | 7 | Housekeeping Aids Closet (HAC) | | | | | | | | | | | |
| 975 | EMS | JANC1 | 7 | Housekeeping Aids Closet (HAC) | 1B955, 1F957, 1G958, 2A950, 2G953, 3A950, 3G953 | | | RAMO301 | RACK, MOP/BROOM | 1 | VC | NO | | 7 | 0 |
| 976 | EMS | JANC1 | 7 | Housekeeping Aids Closet (HAC) | 1B955, 1F957, 1G958, 2A950, 2G953, 3A950, 3G953 | | | REWA318 | RECEPTACLE, WASTE, METAL, 40 GAL | 1 | VV | No | | 7 | 0 |
| 974 | EMS | JANC1 | 7 | Housekeeping Aids Closet (HAC) | 1B955, 1F957, 1G958, 2A950, 2G953, 3A950, 3G953 | | | DICH300 | DISPENSER, CHEMICAL, EVS | 1 | VC | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 7 | |
| 978 | EMS | LCCL1 | 1 | Storage, Clean Linen Cart | 1A953 | | | CAL1303 | CART, LINEN 48" X 24" WITH VINYL COVER | 8 | VV | No | | 8 | 0 |
| 977 | EMS | LCCL1 | 1 | Storage, Clean Linen Cart | | | | | | | | | | | 0 |
| 979 | EMS | LCCL1 | 1 | Storage, Soiled Linen Cart | | | | | | | | | Room 1B956 | | 1 |
| 980 | EMS | OFAO2 | 1 | Office, Supervisor | | | | | | | | | Room 1A951 | | |
| 981 | EMS | OFAO2 | 1 | Office, Supervisor | 1A951 | | 2/20/2014 | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | |
| 983 | EMS | OFAO2 | 1 | Office, Supervisor | 1A951 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 1 | 0 |
| 984 | EMS | OFAO2 | 1 | Office, Supervisor | 1A951 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 1 | VV | F | | 1 | 0 |
| 985 | EMS | OFAO2 | 1 | Office, Supervisor | 1A951 | | | FURN110 | CHAIR, NO ARMS | 2 | VV | F | | 2 | 0 |
| 986 | EMS | OFAO2 | 1 | Office, Supervisor | 1A951 | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 1 | VV | F | | 1 | 1 |
| 982 | EMS | OFAO2 | 1 | Office, Supervisor | 1A951 | | 1/31/2014 | PRMF301 | PRINTER, MULTI-FUNCTION | 1 | VV | | PRMF301 & COP1300 LISTED ON SAME CUT SHEET WITH ONLY ONE XEROX MODEL CALLED OUT - SIZE DOES NOT WORK IN MOST PRMF301 LOCATIONS | 1 | |
| 987 | EMS | OFAO2 | 1 | Office, Supervisor | 1A951 | | 2/20/2014 | CLWA801 | CLOCK | 1 | VV | | | 1 | |
| 988 | EMS | | 1 | Office, Shared | | | | | | | | | | | |
| 989 | EMS | | 1 | Office, Shared | 1A952 | | 2/20/2014 | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 2 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 2 | |
| 991 | EMS | | 1 | Office, Shared | 1A952 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 2 | VV | No | | 2 | |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|------------|--------------|--------------------------------------|--------------|------------|---------------------|--------------------|------------------|--|--------------|--------------------------|----------------------|--|-----------|-----------------------|
| 992 | EMS | 1 | Office, Shared | 1A952 | | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 2 | VV | F | | 2 | |
| 993 | EMS | 1 | Office, Shared | 1A952 | | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 2 | VV | F | | 2 | |
| 990 | EMS | 1 | Office, Shared | 1A952 | | 1/31/2014 | | PRMF301 | PRINTER, MULTI-FUNCTION | 1 | VV | | PRMF301 & COPI300 LISTED ON SAME CUT SHEET WITH ONLY ONE XEROX MODEL CALLED OUT - SIZE DOES NOT WORK IN MOST PRMF301 LOCATIONS | 1 | |
| 994 | EMS | 1 | Office, Shared | 1A952 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | 1 |
| 995 | EMS | SRSE1 | Storage, EMS/Large Equipment | | | | | | | | | | | 1 | |
| 996 | EMS | SRSE1 | Storage, EMS/Large Equipment | 1A954 | | | | SHWI404 | SHELVING, WIRE MESH | 17 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 17 | |
| 997 | Eye Clinic | | | | | | | | | | | | | | |
| 998 | Eye Clinic | 1 | Low Vision/Exam Treatment | | | | | | | | | | | | |
| 999 | Eye Clinic | 1 | Low Vision/Exam Treatment | 3C610 | | | | CAET300 | CABINET, ETDERS ILLUMINATOR | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | 0 |
| 1000 | Eye Clinic | 1 | Low Vision/Exam Treatment | 3C610 | | 2/20/2014 | 3/10/2014 | CHEX304 | CHAIR, EXAM, TREATMENT | 1 | VV | | | 1 | |
| 1001 | Eye Clinic | 1 | Low Vision/Exam Treatment | 3C610 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | |
| 1002 | Eye Clinic | 1 | Low Vision/Exam Treatment | 3C610 | | 2/20/2014 | | COSH321 | CONTAINER, SHARPS, 2 GALLON | 1 | VC | | TWO MODELS LISTED, PLEASE CONFIRM WE ARE USING 8509SA (W/O GLOVE BOX) NEED PRODUCT WEIGHT | 1 | |
| 1003 | Eye Clinic | 1 | Low Vision/Exam Treatment | 3C610 | | 2/20/2014 | | DIGL300 | DISPENSER, GLOVE, 3 BOX | 1 | VC | | | 1 | |
| 1004 | Eye Clinic | 1 | Low Vision/Exam Treatment | 3C610 | | | | LASL303 | LAMP, SLIT, PORTABLE | 2 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 2 | |
| 1005 | Eye Clinic | 1 | Low Vision/Exam Treatment | 3C610 | | | | LIMA306 | LIGHT, MAGNIFIER | 2 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 2 | |
| 1007 | Eye Clinic | 1 | Low Vision/Exam Treatment | 3C610 | | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | | 1 | 0 |
| 1008 | Eye Clinic | 1 | Low Vision/Exam Treatment | 3C610 | | | | REWB301 | RECEPTACLE, WASTE, BIOHAZARD, SML, 8 GAL | 1 | VV | No | | 1 | 1 |
| 1006 | Eye Clinic | 1 | Low Vision/Exam Treatment | 3C610 | | | | MALC300 | MAGNIFIER, LCD | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 1009 | Eye Clinic | 1 | Low Vision/Exam Treatment | 3C610 | | 1/31/2014 | | PRMF301 | PRINTER, MULTI-FUNCTION | 1 | VV | | PRMF301 & COPI300 LISTED ON SAME CUT SHEET WITH ONLY ONE XEROX MODEL CALLED OUT - SIZE DOES NOT WORK IN MOST PRMF301 LOCATIONS | 1 | |
| 1011 | Eye Clinic | 1 | Low Vision/Exam Treatment | 3C610 | | | | STDO350 | STOOL, DR. WITHOUT ARMS, ADJUSTABLE | 1 | VV | No | | 1 | |
| 1010 | Eye Clinic | 1 | Low Vision/Exam Treatment | 3C610 | | | | SCSA300 | SCANNER, SARA | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 1012 | Eye Clinic | 1 | Low Vision/Exam Treatment | 3C610 | | | | KEMA400 | MANUAL KERATOMETER | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 1013 | Eye Clinic | 1 | Low Vision/Exam Treatment | 3C610 | | | | STIN301 | STAND, INSTRUMENT, WITH WHEELS | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 1015 | Eye Clinic | 1 | Low Vision/Exam Treatment | 3C610 | | | | FURN102 | CHAIR, WITH ARMS | 1 | VV | F | | 1 | 1 |
| 1014 | Eye Clinic | 1 | Low Vision/Exam Treatment | 3C610 | | | | VIIN300 | VIEWER, INSTRUMENT, CONTRAST SENSITIVITY FUNCTION | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 1016 | Eye Clinic | 1 | Low Vision/Exam Treatment | 3C610 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | 1 |
| 1016 | Eye Clinic | 1 | Low Vision/Exam Treatment | 3C610 | | | | MOVI300 | V-TEL SYSTEM - SMART TV / MONITOR WITH CISCO SYSTEM | 1 | VV | | | 6 | 1 |
| 1017 | Eye Clinic | 1 | Anterior Segment photo/ testing room | | | | | | | | | | | | |
| 1018 | Eye Clinic | 1 | Anterior Segment photo/ testing room | 3C617 | | | | ANSE300 | IMAGING, ANTERIOR SEGMENT (OCT) | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | 0 |
| 1019 | Eye Clinic | 1 | Anterior Segment photo/ testing room | 3C617 | | | | ANOP301 | ANALYZER, OPHTHALMIC, CORNEAL TOPOGRAPHY/ PACHYMETRY | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 1020 | Eye Clinic | 1 | Anterior Segment photo/ testing room | 3C617 | | 2/20/2014 | 3/10/2014 | CHEX304 | CHAIR, EXAM, TREATMENT | 1 | VV | | | 1 | |
| 1021 | Eye Clinic | 1 | Anterior Segment photo/ testing room | 3C617 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | |
| 1022 | Eye Clinic | 1 | Anterior Segment photo/ testing room | 3C617 | | 2/20/2014 | | COST300 | COMPUTER STATION, WALL MOUNT | 1 | VC | | WAITING ON PRODUCT SELECTION - NEED DIMENSIONS, WEIGHT, AND POWER / DATA REQUIREMENTS | 1 | |
| 1023 | Eye Clinic | 1 | Anterior Segment photo/ testing room | 3C617 | | 2/20/2014 | | COSH321 | CONTAINER, SHARPS, 2 GALLON | 1 | VC | | TWO MODELS LISTED, PLEASE CONFIRM WE ARE USING 8509SA (W/O GLOVE BOX) NEED PRODUCT WEIGHT | 1 | |
| 1023 | Eye Clinic | 1 | Anterior Segment photo/ testing room | 3C617 | | 2/20/2014 | | COST320 | MOBILE WORKSTATION, KIDNEY SHAPED TABLE | 1 | VV | | | 1 | 0 |
| 1024 | Eye Clinic | 1 | Anterior Segment photo/ testing room | 3C617 | | 2/20/2014 | | DIGL300 | DISPENSER, GLOVE, 3 BOX | 1 | VC | | | 1 | 1 |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|------------|--------------|---------------------------------------|--------------|------------|---------------------|--------------------|------------------|--|--------------|--------------------------|----------------------|---|-----------|-----------------------|
| 1026 | Eye Clinic | 1 | Anterior Segment photo/ testing room | 3C617 | | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 1 | |
| 1025 | Eye Clinic | 1 | Anterior Segment photo/ testing room | 3C617 | | 1/31/2014 | | GLCH301 | CHAIR GLIDE | 1 | VV | | NEED PRODUCT HEIGHT, WEIGHT, AND POWER REQUIREMENTS | 1 | |
| 1027 | Eye Clinic | 1 | Anterior Segment photo/ testing room | 3C617 | | | | SCCO300 | SCANNER, CORNEAL | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 1029 | Eye Clinic | 1 | Anterior Segment photo/ testing room | 3C617 | | | | STDO350 | STOOL, DR. WITHOUT ARMS, ADJUSTABLE | 2 | VV | No | | 2 | |
| 1028 | Eye Clinic | 1 | Anterior Segment photo/ testing room | 3C617 | | | | SPMI500 | SPECULAR MICROSCOPY | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 1030 | Eye Clinic | 1 | Anterior Segment photo/ testing room | 3C617 | | | | TAEQ301 | TABLE, EQUIPMENT, ADJUSTABLE | 2 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 2 | |
| 1031 | Eye Clinic | 1 | Anterior Segment photo/ testing room | 3C617 | | | | ULBI500 | ULTRASONIC BIOMICROSCOPY | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 1032 | Eye Clinic | 1 | Anterior Segment photo/ testing room | 3C617 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | |
| 1033 | Eye Clinic | 1 | Anterior Segment photo/ testing room | 3C617 | | | | EYEA100 | Anterior segment camera | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 1034 | Eye Clinic | 1 | Anterior Segment photo/ testing room | 3C617 | | | | EYEA101 | Anterior segment OCT/UBM | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 1035 | Eye Clinic | 1 | Anterior Segment photo/ testing room | 3C617 | | | | EYEA102 | IOLMaster/Lenstar | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 1036 | Eye Clinic | 1 | Anterior Segment photo/ testing room | 3C617 | | | | EYEA103 | Corneal Topography | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 1037 | Eye Clinic | 1 | Anterior Segment photo/ testing room | 3C617 | | | | EYEA104 | OCT, portable | 2 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" portable to other rooms | 2 | 1 |
| 1038 | Eye Clinic | 1 | Anterior Segment photo/ testing room | 3C617 | | | | EYEA105 | Auto refractor | 4 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" portable to other rooms | 4 | 1 |
| 1038 | Eye Clinic | 1 | Anterior Segment photo/ testing room | 3C617 | | | | MOVI300 | V-TEL SYSTEM - SMART TV / MONITOR WITH CISCO SYSTEM | 1 | VV | | | 6 | 1 |
| 1039 | Eye Clinic | 1 | Posterior Segment photo/ testing room | | | | | | | | | | | | |
| 1040 | Eye Clinic | 1 | Posterior Segment photo/ testing room | 3B605 | | | | ANSE300 | IMAGING, ANTERIOR SEGMENT (OCT) | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | 0 |
| 1041 | Eye Clinic | 1 | Posterior Segment photo/ testing room | 3B605 | | 4/15/2014 | | ANOP301 | ANALYZER, OPHTHALMIC, CORNEAL TOPOGRAPHY/ PACHYMETRY | 1 | VV | | | 1 | |
| 1042 | Eye Clinic | 1 | Posterior Segment photo/ testing room | 3B605 | | 2/20/2014 | 3/10/2014 | CHEX304 | CHAIR, EXAM, TREATMENT | 1 | VV | | | 1 | |
| 1043 | Eye Clinic | 1 | Posterior Segment photo/ testing room | 3B605 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | |
| 1044 | Eye Clinic | 1 | Posterior Segment photo/ testing room | 3B605 | | 2/20/2014 | | COST300 | COMPUTER STATION, WALL MOUNT | 1 | VC | | WAITING ON PRODUCT SELECTION - NEED DIMENSIONS, WEIGHT, AND POWER / DATA REQUIREMENTS | 1 | |
| 1045 | Eye Clinic | 1 | Posterior Segment photo/ testing room | 3B605 | | 2/20/2014 | | COSH321 | CONTAINER, SHARPS, 2 GALLON | 1 | VC | | TWO MODELS LISTED, PLEASE CONFIRM WE ARE USING 8509SA (W/O GLOVE BOX) NEED PRODUCT WEIGHT | 1 | |
| 1046 | Eye Clinic | 1 | Posterior Segment photo/ testing room | 3B605 | | 2/20/2014 | | DIGL300 | DISPENSER, GLOVE, 3 BOX | 1 | VC | | | 1 | 1 |
| 1048 | Eye Clinic | 1 | Posterior Segment photo/ testing room | 3B605 | | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 1 | |
| 1047 | Eye Clinic | 1 | Posterior Segment photo/ testing room | 3B605 | | 1/31/2014 | | GLCH301 | CHAIR GLIDE | 1 | VV | | NEED PRODUCT HEIGHT, WEIGHT, AND POWER REQUIREMENTS | 1 | |
| 1049 | Eye Clinic | 1 | Posterior Segment photo/ testing room | 3B605 | | | | SCCO300 | SCANNER, CORNEAL | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 1051 | Eye Clinic | 1 | Posterior Segment photo/ testing room | 3B605 | | | | STDO350 | STOOL, DR. WITHOUT ARMS, ADJUSTABLE | 2 | VV | No | | 2 | 1 |
| 1050 | Eye Clinic | 1 | Posterior Segment photo/ testing room | 3B605 | | | | SPMI500 | SPECULAR MICROSCOPY | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 1052 | Eye Clinic | 1 | Posterior Segment photo/ testing room | 3B605 | | | | TAEQ301 | TABLE, EQUIPMENT, ADJUSTABLE | 2 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 2 | |
| 1053 | Eye Clinic | 1 | Posterior Segment photo/ testing room | 3B605 | | | | ULBI500 | ULTRASONIC BIOMICROSCOPY | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 1054 | Eye Clinic | 1 | Posterior Segment photo/ testing room | 3B605 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | |
| 1055 | Eye Clinic | 1 | Posterior Segment photo/ testing room | 3B605 | | | | EYEA106 | Fundus photography camera & fluorescein angiography | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | 1 |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/ Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|-----------|--------------|---------------------------------------|--|------------|---------------------|--------------------|------------------|---|--------------|---------------------------|----------------------|---|-----------|-----------------------|
| 1056 Eye Clinic | | 1 | Posterior Segment photo/ testing room | 3B605 | | | | EYEA107 | Fundus autofluorescence | 1 | VV | | **NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN** | 1 | |
| 1056 Eye Clinic | | 1 | Posterior Segment photo/ testing room | 3B605 | | | | MOVI300 | V-TEL SYSTEM - SMART TV / MONITOR WITH CISCO SYSTEM | 1 | VV | | | 6 | 0 |
| 1057 Eye Clinic | | 1 | Laser Room | | | | | | | | | | | | |
| 1058 Eye Clinic | | 1 | Laser Room | 3C616 | | 2/20/2014 | 3/10/2014 | CHEX304 | CHAIR, EXAM, TREATMENT | 1 | VV | | | 1 | |
| 1059 Eye Clinic | | 1 | Laser Room | 3C616 | | 2/20/2014 | | DIGL300 | DISPENSER, GLOVE, 3 BOX | 1 | VC | | | 1 | 0 |
| 1060 Eye Clinic | | 1 | Laser Room | 3C616 | | | | LAAR300 | LASER, ARGON | 1 | VV | | **NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN** (PASCAL MFG. is optimedica) | 1 | 1 |
| 1061 Eye Clinic | | 1 | Laser Room | 3C616 | | | | LAPH300 | LASER, PHOTOCOAGULATOR | 1 | VV | | **NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN** | 1 | |
| 1062 Eye Clinic | | 1 | Laser Room | 3C616 | | | | LASE310 | LASER, GLAUCOMA, OPHTHALMIC | 1 | VV | | **NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN** SLT laser (glaucoma) | 1 | |
| 1064 Eye Clinic | | 1 | Laser Room | 3C616 | | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 1 | |
| 1065 Eye Clinic | | 1 | Laser Room | 3C616 | | | | STDO350 | STOOL, DR. WITHOUT ARMS, ADJUSTABLE | 2 | VV | No | | 2 | |
| 1063 Eye Clinic | | 1 | Laser Room | 3C616 | | 3/7/2014 | | LASE315 | YAG laser | 1 | VV | | | 1 | |
| 1067 Eye Clinic | | 1 | Laser Room | 3C616 | | | | FURN102 | CHAIR, WITH ARMS | 2 | VV | F | | 2 | |
| 1066 Eye Clinic | | 1 | Laser Room | 3C616 | | 2/20/2014 | | TELE312 | TELEVISION, FLAT PANEL, 52" LCD | 2 | VC | | WE RECEIVED ONE CUT SHEET WITH TWO EQUIPMENT NUMBERS AND ONLY ONE MODEL INDICATED - ARE THEY TO BE THE SAME SIZE? | 2 | |
| 1068 Eye Clinic | | 1 | Laser Room | 3C616 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | 1 |
| 1070 Eye Clinic | | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | | | | CALS300 | CART, L STYLE | 1 | VV | NO | | 6 | |
| 1069 Eye Clinic | | 8 | Eye Exam/Treatment Room | | | | | | | | | | (PREVIOUSLY 6 - CHANGED WITH ADDITION OF 5TH MODULE) | | 1 |
| 1070 Eye Clinic | | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | | | | CAME306 | CABINET, MEDICATION | 1 | VC | | **NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN** | 6 | 0 |
| 1070 Eye Clinic | | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | | 2/20/2014 | | CASP306 | CART, SPECIALTY | 1 | VV | | CUT SHEET IS FROM 2001, IS THE INFORMATION STILL ACCURATE? | 6 | |
| 1072 Eye Clinic | | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | M5600 | | | CHEX304A | CHAIR, EXAM, TREATMENT CUSHION SET | 1 | VV | - | Reliance 7000 Cushion Set | 6 | |
| 1071 Eye Clinic | | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | M5600 | 2/20/2014 | 3/10/2014 | CHEX304 | CHAIR, EXAM, TREATMENT | 1 | VV | | Reliance 7000-LFC Chair | 6 | |
| 1074 Eye Clinic | | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | M1801 | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 6 | 0 |
| 1075 Eye Clinic | | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | | 2/20/2014 | | COST300 | COMPUTER STATION, WALL MOUNT | 1 | VC | | WAITING ON PRODUCT SELECTION - NEED DIMENSIONS, WEIGHT, AND POWER / DATA REQUIREMENTS | 6 | 1 |
| 1076 Eye Clinic | | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | A5108 | 2/20/2014 | | COSH321 | CONTAINER, SHARPS, 2 GALLON | 1 | VC | | TWO MODELS LISTED, PLEASE CONFIRM WE ARE USING 8509SA (W/O GLOVE BOX) NEED PRODUCT WEIGHT | 6 | |
| 1077 Eye Clinic | | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | A5107 | 2/20/2014 | | DIGL300 | DISPENSER, GLOVE, 3 BOX | 1 | VC | | | 6 | |
| 1078 Eye Clinic | | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | M5600 | 1/31/2014 | | GLCH301 | CHAIR GLIDE | 1 | VV | | Reliance 940 Chair Glide System -NEED PRODUCT HEIGHT, WEIGHT, AND POWER REQUIREMENTS | 6 | |
| 1080 Eye Clinic | | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | | 6 | |
| 1081 Eye Clinic | | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | | | | REWB301 | RECEPTACLE, WASTE, BIOHAZARD, SML, 8 GAL | 1 | VV | No | | 6 | |
| 1082 Eye Clinic | | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | | | | STDO350 | STOOL, DR. WITHOUT ARMS, ADJUSTABLE | 1 | VV | No | Reliance 5346 Pneumatic Stool | 6 | |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|------------|--------------|-------------------------|--|------------|---------------------|--------------------|------------------|--|--------------|--------------------------|----------------------|--|-----------|-----------------------|
| 1079 | Eye Clinic | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | | | | OPHT350 | OPHTHALMOSCOPE, INDIRECT, BINOCULAR | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 6 | |
| 1084 | Eye Clinic | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | | | | FURN102 | CHAIR, WITH ARMS | 1 | VV | F | | 6 | |
| 1083 | Eye Clinic | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | M5730 | 1/31/2014 | | STIN304 | STAND, OPHTHALMIC, INSTRUMENT | 1 | VV | | Reliance 7800-IC Floor Unit | 6 | |
| 1086 | Eye Clinic | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | | | | STIN304A | Reichert 11637 Plus Cylinder Black Illuminated Ultramatic RxMaster Phoropter Refractor | 1 | VV | - | Equipment for Stand STIN304 | 6 | |
| 1087 | Eye Clinic | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | | | | STIN304B | Haag-Streit 900 BQ (Slit Lamp) Unit Model | 1 | VV | - | Equipment for Stand STIN304 | 6 | |
| 1088 | Eye Clinic | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | | | | STIN304C | Haag-Streit BP/BQ/BX Applanation Tonometer | 1 | VV | - | Equipment for Stand STIN304 | 6 | |
| 1085 | Eye Clinic | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 6 | |
| 1089 | Eye Clinic | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | | | | EYEA110 | Keeler Vantage Plus LED Wireless Indirect with Slimline Charging System | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" Hand/Head Held Equipment | 6 | |
| 1090 | Eye Clinic | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | | | | EYEA111 | Welch Allyn 11720 3.5v Halogen Coaxial Ophthalmoscope | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" Hand/Head Held Equipment | 6 | |
| 1091 | Eye Clinic | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | | | | EYEA112 | Welch Allyn 18245 Elite Streak Retinoscope | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" Hand/Head Held Equipment | 6 | |
| 1092 | Eye Clinic | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | | | | EYEA113 | Welch Allyn 41100 3.5v Halogen Finnoff Transilluminator | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" Hand/Head Held Equipment | 6 | |
| 1093 | Eye Clinic | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | | | | EYEA114 | Welch Allyn 71670 3.5v NiCad | 3 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" Hand/Head Held Equipment | 18 | |
| 1094 | Eye Clinic | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | | | | EYEA115 | Sonomed Master-Vu Portable Ophthalmic B-scan & case | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" Hand/Head Held Equipment | 6 | |
| 1095 | Eye Clinic | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | | | | EYEA116 | Topcon CL-200 Computerized Lensmeter with Printer | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" Room Equipment | 6 | |
| 1096 | Eye Clinic | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | | | | EYEA117 | Lombart CVS iMac Acuity System | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" Room Equipment | 6 | |
| 1097 | Eye Clinic | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | | | | EYEA118 | DGH 550 Pachymeter: Pachette 2 | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" Room Equipment | 6 | |
| 1098 | Eye Clinic | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | | | | EYEA120 | Marco Corrected Curve Custom Deluxe Trial Lens Set with Plus Cylinders Only | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" Lenses | 6 | |
| 1099 | Eye Clinic | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | | | | EYEA121 | Metal Trail Frame | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" Lenses | 6 | |
| 1100 | Eye Clinic | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | | | | EYEA122 | Volk 20D Large Aspheric LensClear (50mm) | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" Lenses | 6 | |
| 1101 | Eye Clinic | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | | | | EYEA123 | Volk 60D Small Aspheric Lens Clear (31mm) | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" Lenses | 6 | |
| 1102 | Eye Clinic | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | | | | EYEA124 | Volk 78D Small Aspheric LensClear (31mm) | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" Lenses | 6 | |
| 1103 | Eye Clinic | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | | | | EYEA125 | Volk Digital Wide Field Lens | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" Lenses | 6 | |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|------------|--------------|----------|-----------------------------|--|---------------------|--------------------|------------------|--|--------------|--------------------------|----------------------|---|-----------|-----------------------|
| 1104 | Eye Clinic | | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | | | EYEA126 | Volk VG4LNF 4 Mirror Glass Hand Held Gonio Lens, (29.5mm) Large Ring, No Flange-No Fluid | 3 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" Lenses | 18 | |
| 1105 | Eye Clinic | | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | | | EYEA127 | Volk VG3 3 Mirror Glass Gonio Fundus Laser Lens, Glass Flange | 3 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" Lenses | 18 | |
| 1106 | Eye Clinic | | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | | | EYEA128 | Haag-Streit Fundus Lens (901) | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" Lenses | 6 | |
| 1107 | Eye Clinic | | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | | | EYEA129 | Luneau Retinoscopy Rack | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" Lenses | 6 | |
| 1108 | Eye Clinic | | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | | | EYEA130 | Vertical Prism Bar | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" Lenses | 6 | |
| 1109 | Eye Clinic | | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | | | EYEA131 | Horizontal Prism Bar | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" Lenses | 6 | 1 |
| 1110 | Eye Clinic | | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | | | EYEA132 | 16 Loose Prism Set | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" Lenses | 6 | 1 |
| 1111 | Eye Clinic | | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | | | EYEA135 | RANDOT Stereo Randot Test | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" Other | 6 | |
| 1111 | Eye Clinic | | 8 | Eye Exam/Treatment Room | 3B600, 3B601, 3B602, 3B603, 3B604, 3B611, 3B613, 3B614 | | | MOVI300 | V-TEL SYSTEM - SMART TV / MONITOR WITH CISCO SYSTEM | 1 | VV | | | 6 | 0 |
| 1186 | Eye Clinic | EYFD1 | 1 | Fitting and Dispensing Room | | | | | | | | | | | |
| 1191 | Eye Clinic | EYFD1 | 1 | Fitting and Dispensing Room | 1E600 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 1 | VV | F | | 1 | 0 |
| 1192 | Eye Clinic | EYFD1 | 1 | Fitting and Dispensing Room | 1E600 | | | FURN110 | CHAIR, NO ARMS | 2 | VV | F | | 2 | 1 |
| 1193 | Eye Clinic | EYFD1 | 1 | Fitting and Dispensing Room | 1E600 | | | FURN210 | WORKSTATION, 2'-6" X 4'-0" | 1 | VV | F | | 1 | |
| 1187 | Eye Clinic | EYFD1 | 1 | Fitting and Dispensing Room | 1E600 | A5025 | | BERE400 | BENCH, REPAIR | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" JSN #: A5025 | 1 | 1 |
| 1194 | Eye Clinic | EYFD1 | 1 | Fitting and Dispensing Room | 1E600 | | 2/20/2014 | CLWA801 | CLOCK | 1 | VV | | | 1 | 1 |
| 1195 | Eye Clinic | EYVF1 | 1 | Visual Fields Room | | | | | | | | | | | 0 |
| 1196 | Eye Clinic | EYVF1 | 1 | Visual Fields Room | 3C612 | M1801 | 2/20/2014 | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 6 | 0 |
| 1196 | Eye Clinic | EYVF1 | 1 | Visual Fields Room | 3C612 | | 2/20/2014 | COST300 | COMPUTER STATION, WALL MOUNT | 1 | VC | | WAITING ON PRODUCT SELECTION - NEED DIMENSIONS, WEIGHT, AND POWER / DATA REQUIREMENTS | 6 | 1 |
| 1196 | Eye Clinic | EYVF1 | 1 | Visual Fields Room | 3C612 | | 2/20/2014 | COST320 | MOBILE WORKSTATION, KIDNEY SHAPED TABLE | 1 | VV | | | 1 | 0 |
| 1196 | Eye Clinic | EYVF1 | 1 | Visual Fields Room | 3C612 | | 4/15/2014 | ANFI300 | ANALYZER, FIELD | 4 | VV | | | 4 | |
| 1197 | Eye Clinic | EYVF1 | 1 | Visual Fields Room | 3C612 | | | CATR326 | CABINET, TRIAL LENS | 3 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 1199 | Eye Clinic | EYVF1 | 1 | Visual Fields Room | 3C612 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 1 | |
| 1200 | Eye Clinic | EYVF1 | 1 | Visual Fields Room | 3C612 | | | STDO350 | STOOL, DR. WITHOUT ARMS, ADJUSTABLE | 4 | VV | No | | 2 | 0 |
| 1198 | Eye Clinic | EYVF1 | 1 | Visual Fields Room | 3C612 | | 2/20/2014 | DIGL300 | DISPENSER, GLOVE, 3 BOX | 1 | VC | | | 1 | |
| 1202 | Eye Clinic | EYVF1 | 1 | Visual Fields Room | 3C612 | | | FURN116 | CHAIR, WITH ARMS | 1 | VV | F | | 2 | 0 |
| 1201 | Eye Clinic | EYVF1 | 1 | Visual Fields Room | 3C612 | | | TRLE300 | TRIAL LENS SET, OPHTHALMIC | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | 0 |
| 1203 | Eye Clinic | EYVF1 | 1 | Visual Fields Room | 3C612 | | 2/20/2014 | CLWA801 | CLOCK | 1 | VV | | | 1 | 1 |
| 1204 | Eye Clinic | SECO1 | 1 | Subwaiting Area (Dilation) | | | | | | | | | | | |
| 1206 | Eye Clinic | SECO1 | 1 | Subwaiting Area (Dilation) | 3C408 | | | FURN110 | CHAIR, NO ARMS | 6 | VV | F | | 6 | 0 |
| 1205 | Eye Clinic | SECO1 | 1 | Subwaiting Area (Dilation) | 3C408 | | 2/20/2014 | CLWA801 | CLOCK | 1 | VV | | | 1 | 0 |
| 1207 | Eye Clinic | SL002 | 1 | Teamlet Workroom | | | | | | | | | | | 0 |
| 1208 | Eye Clinic | SL002 | 1 | Teamlet Workroom | 3F322 | | 2/20/2014 | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 22 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 22 | 0 |
| 1209 | Eye Clinic | SL002 | 1 | Teamlet Workroom | 3F322 | | | HAMP301 | HAMPER, WITH LID, 32" | 6 | VV | No | | 6 | |
| 1208 | Eye Clinic | SL002 | 1 | Teamlet Workroom | 3F322 | | | MOPT300 | MONITOR, PATIENT TRACKING | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | 1 |
| 1211 | Eye Clinic | SL002 | 1 | Teamlet Workroom | 3F322 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 12 | VV | No | | 12 | |
| 1212 | Eye Clinic | SL002 | 1 | Teamlet Workroom | 3F322 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 22 | VV | F | | 22 | |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|-----------------------------|--------------|----------|-------------------------------------|--------------|---------------------|--------------------|------------------|-------------------------------------|--------------|--------------------------|----------------------|--|-----------|-----------------------|
| 1213 | Eye Clinic | SL002 | 1 | Teamlet Workroom | 3F322 | | | FURN240 | WORKSTATION, 2'-0" X 4'-0" | 22 | VV | F | | 22 | |
| 1210 | Eye Clinic | SL002 | 1 | Teamlet Workroom | 3F322 | 1/31/2014 | | PRMF301 | PRINTER, MULTI-FUNCTION | 1 | VV | | PRMF301 & COPI300 LISTED ON SAME CUT SHEET WITH ONLY ONE XEROX MODEL CALLED OUT - SIZE DOES NOT WORK IN MOST PRMF301 LOCATIONS | 1 | |
| 1214 | Eye Clinic | SL002 | 1 | Teamlet Workroom | 3F322 | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | |
| 1216 | Eye Clinic | SL002A | 1 | Team Work Area | 3C326 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 1 | |
| 1217 | Eye Clinic | SL002A | 1 | Team Work Area | 3C326 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 10 | VV | F | | 8 | |
| 1218 | Eye Clinic | SL002A | 1 | Team Work Area | 3C326 | | | FURN240 | WORKSTATION, 2'-0" X 4'-0" | 6 | VV | F | | 1 | 0 |
| 1219 | Eye Clinic | SL002A | 1 | Team Work Area | 3C326 | | | FURN430 | TABLE, ROUND | 1 | VV | F | | | |
| 1215 | Eye Clinic | SL002A | 1 | Team Work Area | | | | | | | | | | | |
| 1220 | Eye Clinic | SL002A | 1 | Team Work Area | 3C326 | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | 1 |
| 1221 | Eye Clinic | | 1 | Alcove, Omni Cell | | | | | | | | | | 0 | |
| 1223 | Eye Clinic | | 1 | Alcove, Omni Cell | 3C324 | | | SYME302A | INSTALLATION, SEISMIC RESTRAINT | 4 | VV | - | | 4 | 0 |
| 1222 | Eye Clinic | | 1 | Alcove, Omni Cell | 3C324 | 1/31/2014 | 2/20/2014 | SYME302 | OMNIRX THREE CELL / SUPPLIER | 4 | VV | | NEED MODEL NUMBER | 4 | |
| 1224 | Eye Clinic | | 1 | Alcove | | | | | | | | | | | |
| 1225 | Eye Clinic | | 1 | Alcove | 3C323 | 1/31/2014 | | PRMF301 | PRINTER, MULTI-FUNCTION | 2 | VV | | PRMF301 & COPI300 LISTED ON SAME CUT SHEET WITH ONLY ONE XEROX MODEL CALLED OUT - SIZE DOES NOT WORK IN MOST PRMF301 LOCATIONS | 2 | 0 |
| 1227 | Eye Clinic | | 1 | Alcove | 3C323 | | | SYME302A | INSTALLATION, SEISMIC RESTRAINT | 2 | VV | - | | 2 | |
| 1226 | Eye Clinic | | 1 | Alcove | 3C323 | 1/31/2014 | 2/20/2014 | SYME302 | OMNIRX THREE CELL / SUPPLIER | 2 | VV | | NEED MODEL NUMBER | 2 | |
| 1228 | Eye Clinic | | 1 | Print | | | | | | | | | | | |
| 1230 | Eye Clinic | | 1 | Print | 3C325 | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 1 | VV | F | | | |
| 1229 | Eye Clinic | | 1 | Print | 3C325 | 1/31/2014 | | PRMF301 | PRINTER, MULTI-FUNCTION | 2 | VV | | PRMF301 & COPI300 LISTED ON SAME CUT SHEET WITH ONLY ONE XEROX MODEL CALLED OUT - SIZE DOES NOT WORK IN MOST PRMF301 LOCATIONS | 2 | |
| 1231 | Eye Clinic | TLTU1 | 2 | Toilet, Public | | | | | | | | | | | |
| 1233 | Eye Clinic | TLTU1 | 2 | Toilet, Public | 3F155, 3F156 | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | | 2 | 0 |
| 1232 | Eye Clinic | TLTU1 | 2 | Toilet, Public | 3F155, 3F156 | 2/20/2014 | | BACH300 | BABY CHANGING STATION | 1 | VV | | REFER TO SCHEDULE B | 2 | 0 |
| 1235 | Eye Clinic | TLTU1 | 2 | Toilet, Patient | 3C609, 3C236 | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | | 2 | |
| 1234 | Eye Clinic | TLTU1 | 2 | Toilet, Patient | | | | | | | | | | | 1 |
| 1237 | Ambulatory Care - Specialty | | 1 | Corridor | | | | FURN500 | FILE CABINET, LOCKABLE | 9 | VV | F | | 0 | |
| 1238 | Lobby | | | | | | | | | | | | | 0 | |
| 1239 | Lobby | | 1 | Lactation Room | | | | | | | | | | | |
| 1240 | Lobby | | 1 | Lactation Room | 1B706 | | | CHGL300 | CHAIR, GLIDER | 2 | VV | No | | 2 | |
| 1241 | Lobby | | 1 | Lactation Room | 1B706 | 2/20/2014 | | OVM1303 | OVEN, MICROWAVE | 1 | VV | | | 1 | 0 |
| 1242 | Lobby | | 1 | Lactation Room | 1B706 | 1/31/2014 | 2/20/2014 | REUC315 | REFRIGERATOR, UNDERCOUNTER, ADA | 1 | VV | | | 1 | |
| 1243 | Lobby | | 1 | Lactation Room | 1B706 | 1/31/2014 | | REUC315A | TEMPERATURE ALARM WITH PROBE | 1 | VV | | | 1 | 0 |
| 1244 | Lobby | | 1 | Lactation Room | 1B706 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 1 | 0 |
| 1245 | Lobby | | 1 | Lactation Room | 1B706 | | | FURN434 | ROUND TABLE | 2 | VV | F | | 2 | 0 |
| 1246 | Lobby | | 1 | Lactation Room | 1B706 | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | 0 |
| 1247 | Lobby | RECP3 | 1 | Information Desk | | | | | | | | | INCREASED TO 3 WORKSTATIONS | 0 | |
| 1248 | Lobby | RECP3 | 1 | Information Desk | 1E100 | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 3 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 3 | 0 |
| 1249 | Lobby | RECP3 | 1 | Information Desk | 1E100 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 3 | VV | No | | 3 | 1 |
| 1250 | Lobby | RECP3 | 1 | Information Desk | 1E100 | | | FURN106 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 3 | VV | F | | 3 | |
| 1251 | Lobby | LIBV1 | 1 | Patient Information Resource Center | | | | | | | | | | | |
| 1252 | Lobby | LIBV1 | 1 | Patient Information Resource Center | 1B705 | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 6 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 6 | |
| 1253 | Lobby | LIBV1 | 1 | Patient Information Resource Center | 1B705 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 6 | VV | No | | 6 | 1 |
| 1254 | Lobby | LIBV1 | 1 | Patient Information Resource Center | 1B705 | 2/20/2014 | | TELE312 | TELEVISION, FLAT PANEL, 52" LCD | 1 | VC | | WE RECEIVED ONE CUT SHEET WITH TWO EQUIPMENT NUMBERS AND ONLY ONE MODEL INDICATED - ARE THEY TO BE THE SAME SIZE? | 1 | 0 |
| 1255 | Lobby | LIBV1 | 1 | Patient Information Resource Center | 1B705 | | | FURN204 | WORKSTATION, 2'-6" X 7'-0" | 1 | VV | F | | 1 | |
| 1256 | Lobby | LIBV1 | 1 | Patient Information Resource Center | 1B705 | | | FURN265 | WORKSTATION, 2'-0" X 25'-0" | 3 | VV | F | | 1 | 1 |
| 1257 | Lobby | LIBV1 | 1 | Patient Information Resource Center | 1B705 | | | FURN302 | TABLE, 2 PERSON | 5 | VV | F | | 3 | 0 |
| 1258 | Lobby | LIBV1 | 1 | Patient Information Resource Center | 1B705 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 7 | VV | F | | 6 | |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|-----------|--------------|-------------------------------------|----------------------------|------------|---------------------|--------------------|------------------|---------------------------------------|--------------|--------------------------|----------------------|---|-----------|-----------------------|
| 1259 Lobby | LIBV1 | 1 | Patient Information Resource Center | 1B705 | | | | FURN110 | CHAIR, NO ARMS | 10 | VV | F | | 4 | 1 |
| 1260 Lobby | LIBV1 | 1 | Patient Information Resource Center | 1B705 | | | | FURN534 | BOOKCASE, 15" X 48" | 6 | VV | F | | 6 | 0 |
| 1261 Lobby | LIBV1 | 1 | Patient Information Resource Center | 1B705 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | 0 |
| 1262 Lobby | SRLW1 | 1 | Storage, Wheelchair | | | | | | | | | | | 0 | |
| 1263 Lobby | SRLW1 | 1 | Storage, Wheelchair | 1E159 | | | | WHST400 | WHEELCHAIR, STACKABLE TRANSPORT CHAIR | 20 | VV | NO | | 20 | 0 |
| 1264 Lobby | TLTU1 | 1 | Family/Assisted Toilet | | | | | | | | | | | 0 | |
| 1265 Lobby | TLTU1 | 1 | Family/Assisted Toilet | 1D157 | | 2/20/2014 | | BACH300 | BABY CHANGING STATION | 1 | VV | | REFER TO SCHEDULE B | 1 | |
| 1266 Lobby | TLTU1 | 1 | Family/Assisted Toilet | 1D157 | | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | | 1 | |
| 1267 Lobby | TLTU1 | 4 | Female Toilet, Public | | | | | | | | | | | 0 | |
| 1268 Lobby | TLTU1 | 4 | Female Toilet, Public | 1D156, 1G114, 2G164, 3G164 | | 2/20/2014 | | BACH300 | BABY CHANGING STATION | 1 | VV | | REFER TO SCHEDULE B | 4 | |
| 1269 Lobby | TLTU1 | 4 | Female Toilet, Public | 1D156, 1G114, 2G164, 3G164 | | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | | 4 | |
| 1270 Lobby | TLTU1 | 4 | Male Toilet, Public | | | | | | | | | | | | |
| 1271 Lobby | TLTU1 | 4 | Male Toilet, Public | 1D158, 1G114, 2G165, 3G165 | | 2/20/2014 | | BACH300 | BABY CHANGING STATION | 1 | VV | | REFER TO SCHEDULE B | 4 | |
| 1272 Lobby | TLTU1 | 4 | Male Toilet, Public | 1D158, 1G114, 2G165, 3G165 | | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | | 4 | |
| 1273 Lobby | WRCO1 | 1 | Waiting Area | | | | | | | | | | no room number | | |
| 1274 Lobby | WRCO1 | 1 | Waiting Area | | | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 1 | |
| 1275 Lobby | WRCO1 | 1 | Waiting Area | | | | | FURN152 | CHAIR, LOUNGE | 13 | VV | F | | 10 | |
| 1276 Lobby | WRCO1 | 1 | Waiting Area | | | | | FURN432 | TABLE, ROUND | 3 | VV | F | | 3 | |
| 1277 Lobby | WRCO1 | 2 | Vestibule | | | | | | | | | | | 0 | |
| 1278 Lobby | WRCO1 | 2 | Vestibule | 1D152, 1F150 | | | | WHST400 | WHEELCHAIR, STACKABLE TRANSPORT CHAIR | 4 | VV | NO | | 8 | |
| 1279 Lobby | WRCO1 | 2 | Vestibule | 1D152, 1F150 | | | | FURN154 | BENCH SEATING | 2 | VV | F | | 4 | |
| 1280 Lobby | CRA01 | 2 | CONFERENCE / CLASSROOM | | | | | | | | | | | | |
| 1281 Lobby | CRA01 | 2 | CONFERENCE / CLASSROOM | 3G102, 3G104 | | 3/7/2014 | | PRLC300 | PROJECTOR, LCD, DIGITAL | 1 | VV | | | 1 | |
| 1281 Lobby | CRA01 | 2 | CONFERENCE / CLASSROOM | 3G102, 3G104 | | 2/20/2014 | | SCPR300 | SCREEN, PROJECTOR | 1 | VV | | CEILING OR WALL MOUNTED? NEED POWER REQUIREMENTS | 1 | 1 |
| 1281 Lobby | CRA01 | 2 | CONFERENCE / CLASSROOM | 3G102, 3G104 | | 2/20/2014 | | TELE312 | | 1 | | | WE RECEIVED ONE CUT SHEET WITH TWO EQUIPMENT NUMBERS AND ONLY ONE MODEL INDICATED - ARE THEY TO BE THE SAME SIZE? | 2 | 0 |
| 1282 Lobby | CRA01 | 2 | CONFERENCE / CLASSROOM | 3G102, 3G104 | | | | CACO301 | CART, COMPUTER, POWERED | 1 | | | | 2 | |
| 1282 Lobby | CRA01 | 2 | CONFERENCE / CLASSROOM | 3G102, 3G104 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION. MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | |
| 1283 Lobby | CRA01 | 2 | CONFERENCE / CLASSROOM | 3G102, 3G104 | | | | | FLIP TOP TABLES 60" | 1 | | | | 12 | |
| 1284 Lobby | CRA01 | 2 | CONFERENCE / CLASSROOM | 3G102, 3G104 | | | | | CHAIR, TASK ARMS | 20 | | | | 40 | |
| 1285 Lobby | | 1 | KITCHEN | | | | | | | | | | | | |
| 1286 Lobby | | 1 | KITCHEN | 3G106 | | 2/20/2014 | | COMA309 | | 1 | | | | 1 | |
| 1287 Lobby | | 1 | KITCHEN | 3G106 | | 2/20/2014 | | OVM1303 | | 1 | | | | 1 | 0 |
| 1288 Lobby | | 1 | KITCHEN | 3G106 | | 2/20/2014 | | REFR311 | | 1 | | | | 1 | 1 |
| 1289 Lobby | | 1 | KITCHEN | 3G106 | | | | REWA303 | | 1 | | NO | | 1 | |
| 1290 Lockers | | | | | | | | | | | | | | | |
| 1291 Lockers | | 1 | Male Locker Room | | | | | | | | | | | | |
| 1292 Lockers | | 1 | Male Locker Room | 1C807 | | | | HAMP301 | HAMPER, WITH LID, 32" | 1 | VV | No | | 1 | |
| 1293 Lockers | | 1 | Male Locker Room | 1C807 | | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | | 1 | |
| 1294 Lockers | | 1 | Male Locker Room | 1C807 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | |
| 1295 Lockers | | 1 | Male Shower | | | | | | | | | | | | |
| 1296 Lockers | | 1 | Male Shower | 1C805 | | | | SHSE400 | SHOWER SEAT, FOLDING, WALL MOUNT | 1 | VC | NO | SCHEDULE B | 1 | 1 |
| 1297 Lockers | | 1 | Female Locker Room | | | | | | | | | | | | |
| 1298 Lockers | | 1 | Female Locker Room | 1C801 | | | | HAMP301 | HAMPER, WITH LID, 32" | 1 | VV | No | | 1 | |
| 1299 Lockers | | 1 | Female Locker Room | 1C801 | | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | | 1 | |
| 1300 Lockers | | 1 | Female Locker Room | 1C801 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | |
| 1301 Lockers | | 1 | Female Shower | | | | | | | | | | | 0 | |
| 1302 Lockers | | 1 | Female Shower | 1C803 | | | | SHSE400 | SHOWER SEAT, FOLDING, WALL MOUNT | 1 | VC | NO | SCHEDULE B | 1 | 0 |
| 1303 Lockers | | 1 | Staff Fitness Room | | | | | | | | | | | | |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|-----------|--------------|---------------------------------------|--------------|------------|---------------------|--------------------|------------------|--|--------------|--------------------------|----------------------|--|-----------|-----------------------|
| 1304 | Lockers | 1 | Staff Fitness Room | 1C808 | | 12/19/2013 | | EXAP400 | EXERCISE APPARATUS, WEIGHT TRAINING, MULTI-STATION (TOTAL GYM) | 1 | VV | | | 1 | 0 |
| 1305 | Lockers | 1 | Staff Fitness Room | 1C808 | | 2/20/2014 | | EXB1125 | EXERCISE BIKE, UPRIGHT | 2 | VV | | | 2 | 0 |
| 1306 | Lockers | 1 | Staff Fitness Room | 1C808 | | 12/19/2013 | | EXBR400 | EXERCISE BIKE, RECUMBENT | 1 | VV | | NEED POWER & DATA REQUIREMENTS | 1 | 1 |
| 1307 | Lockers | 1 | Staff Fitness Room | 1C808 | | 2/20/2014 | | TRPT420 | TREADMILL | 2 | VV | | NEED PRODUCT WEIGHT & HEIGHT | 2 | |
| 1308 | Lockers | 1 | Staff Fitness Room | 1C808 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | 0 |
| 1309 | Lockers | 1 | Staff Lounge | | | | | | | | | | | | |
| 1310 | Lockers | 1 | Staff Lounge | 1C800 | | 2/20/2014 | | COMA309 | COFFEE MAKER, PLUMBED | 2 | VC | | | 2 | 0 |
| 1311 | Lockers | 1 | Staff Lounge | 1C800 | | 2/20/2014 | | OVM1303 | OVEN, MICROWAVE | 2 | VV | | | 2 | |
| 1312 | Lockers | 1 | Staff Lounge | 1C800 | | 2/20/2014 | | REFR311 | REFRIGERATOR/FREEZER, 21 CU FT W/ ICE MAKER | 2 | VV | | | 2 | |
| 1313 | Lockers | 1 | Staff Lounge | 1C800 | | | | REWA303 | RECEPTACLE, WASTE, 23 GAL, SLIM JIM | 2 | VV | NO | | 2 | 0 |
| 1314 | Lockers | 1 | Staff Lounge | 1C800 | | | | REWA303A | SWING TOP | 2 | VV | - | | 2 | 0 |
| 1315 | Lockers | 1 | Staff Lounge | 1C800 | | 2/20/2014 | | TELE312 | TELEVISION, FLAT PANEL, 52" LCD | 1 | VC | | WE RECEIVED ONE CUT SHEET WITH TWO EQUIPMENT NUMBERS AND ONLY ONE MODEL INDICATED - ARE THEY TO BE THE SAME SIZE? | 1 | |
| 1316 | Lockers | 1 | Staff Lounge | 1C800 | | | | FURN312 | TABLE, ROUND, 4 PERSON | 3 | VV | F | | 3 | |
| 1317 | Lockers | 1 | Staff Lounge | 1C800 | | | | FURN112 | CHAIR, NO ARMS | 12 | VV | F | | 12 | |
| 1318 | Lockers | 1 | Staff Lounge | 1C800 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | |
| 1319 | Lobby | TLTU1 | Female Toilet | | | | | | | | | | | | |
| 1320 | Lobby | TLTU1 | Female Toilet | 1C802 | | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | | 1 | |
| 1321 | Lobby | TLTU1 | Male Toilet | | | | | | | | | | | | |
| 1322 | Lobby | TLTU1 | Male Toilet | 1C806 | | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | | 1 | 1 |
| 1323 | Logistics | | | | | | | | | | | | | | |
| 1324 | Logistics | MMRP1 | Receiving and Issue Area | | | | | | | | | | | | |
| 1325 | Logistics | MMRP1 | Receiving and Issue Area | 1B910 | | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 1 | VV | F | | | |
| 1326 | Logistics | MMRP1 | Receiving and Issue Area | 1B910 | E0078 | | | FURN203 | WORKSTATION, L-SHAPED WITH PENINSULA, FREE STD, 78X72 | 1 | VV | F | | 1 | |
| 1327 | Logistics | MMRP1 | Receiving and Issue Area | 1B910 | F2700 | | | REBA320 | READER, BAR CODE, HAND HELD, WITH INTERFACE | 1 | VV | NO | | 1 | |
| 1328 | Logistics | MMRP1 | Receiving and Issue Area | 1B910 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE | 1 | |
| 1329 | Logistics | MMRP1 | Receiving and Issue Area | 1B910 | | 1/31/2014 | | PRIN300 | PRINTER, LASER | 1 | VV | | ORIGINAL CUT SHEET RECEIVED LATER DECIDED WAS INCORRECT | 1 | |
| 1330 | Logistics | MMRP1 | Receiving and Issue Area | 1B910 | M2020 | | | CASS400 | CABINET, STORAGE, SAFETY, BUILT-IN, VENTED | 1 | VV | | **NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN** | 1 | 0 |
| 1331 | Logistics | MMRP1 | Receiving and Issue Area | 1B910 | M2125 | | | STST400 | STACKER, STRADDLE, 127" LIFT, 2000 LB CAPACITY | 1 | VV | | **NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN** | 1 | 0 |
| 1332 | Logistics | MMRP1 | Receiving and Issue Area | 1B910 | M2130 | | | TRHL400 | TRUCK, HYDRAULIC LIFT, ELECTRIC | 1 | VV | | **NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN** | 1 | 0 |
| 1333 | Logistics | MMRP1 | Receiving and Issue Area | 1B910 | M7780 | 3/7/2014 | | SCDO410 | SCANNER, DOCUMENT | 1 | VV | | | 1 | 1 |
| 1334 | Logistics | MMRP1 | Receiving and Issue Area | 1B910 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | |
| 1335 | Logistics | DOCK1 | Loading Dock Area with Levelers | 1B990 | | | | | | | | | | | |
| 1336 | Logistics | MMCR2 | Unposted Stock Holding Area | 1B913 | | | | | | | | | | | |
| 1337 | Logistics | MMGS1 | Storage, Medical and General | 1B906, 1B907 | | | | | | | | | | | 0 |
| 1338 | Logistics | | Med/Surg Clean Supply Storage | 1B902 | | | | | | | | | | | |
| 1339 | Logistics | OFA02 | Office, Storekeeper, System Furniture | | | | | | | | | | | | 0 |
| 1340 | Logistics | OFA02 | Office, Storekeeper, System Furniture | 1B905 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | 0 |
| 1341 | Logistics | OFA02 | Office, Storekeeper, System Furniture | 1B905 | | 1/31/2014 | | PRMF301 | PRINTER, MULTI-FUNCTION | 1 | VV | | PRMF301 & C0P1300 LISTED ON SAME CUT SHEET WITH ONLY ONE XEROX MODEL CALLED OUT - SIZE DOES NOT WORK IN MOST PRMF301 LOCATIONS | 1 | 1 |
| 1342 | Logistics | OFA02 | Office, Storekeeper, System Furniture | 1B905 | | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 1 | |
| 1343 | Logistics | OFA02 | Office, Storekeeper, System Furniture | 1B905 | | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 1 | VV | F | | 1 | |
| 1344 | Logistics | OFA02 | Office, Storekeeper, System Furniture | 1B905 | | | | FURN260 | WORKSTATION, 2'-0" X 5'-0" | 1 | VV | F | | 1 | |
| 1345 | Logistics | OFA02 | Office, Storekeeper, System Furniture | 1B905 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/ Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|---|--------------|----------|--|------------|---------------------|--------------------|------------------|--|--------------|---------------------------|----------------------|--|-----------|-----------------------|
| 1346 | Logistics | OFA03 | 1 | Office, Open (3) | | | | | | | | | | | |
| 1347 | Logistics | OFA03 | 1 | Office, Open (3) | 1B904 | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 3 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 3 | 0 |
| 1348 | Logistics | OFA03 | 1 | Office, Open (3) | 1B904 | 1/31/2014 | | PRIN300 | PRINTER, LASER | 1 | VV | | ORIGINAL CUT SHEET RECEIVED LATER DECIDED WAS INCORRECT | 1 | 0 |
| 1349 | Logistics | OFA03 | 1 | Office, Open (3) | 1B904 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 3 | VV | No | | 3 | |
| 1350 | Logistics | OFA03 | 1 | Office, Open (3) | 1B904 | 1/31/2014 | | PRMF301 | PRINTER, MULTI-FUNCTION | 1 | VV | | PRMF301 & C0P1300 LISTED ON SAME CUT SHEET WITH ONLY ONE XEROX MODEL CALLED OUT - SIZE DOES NOT WORK IN MOST PRMF301 LOCATIONS | 1 | |
| 1351 | Logistics | OFA03 | 1 | Office, Open (3) | 1B904 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 3 | VV | F | | 3 | |
| 1352 | Logistics | OFA03 | 1 | Office, Open (3) | 1B904 | | | FURN260 | WORKSTATION, 2'-0" X 5'-0" | 3 | VV | F | | 3 | |
| 1353 | Logistics | OFA03 | 1 | Office, Open (3) | 1B904 | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | |
| 1354 | Logistics | MRMB1 | 1 | Mail Room and Distribution Center | | | | | | | | | | | |
| 1355 | Logistics | MRMB1 | 1 | Mail Room and Distribution Center | 1B909 | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | |
| 1356 | Logistics | MRMB1 | 1 | Mail Room and Distribution Center | 1B909 | | | ISBO900 | ISOLATION BOX | 1 | VV | | Request info from Max E via email on 3/25/14. | 1 | 0 |
| 1357 | Logistics | MRMB1 | 1 | Mail Room and Distribution Center | 1B909 | 1/31/2014 | | PRMF301 | PRINTER, MULTI-FUNCTION | 1 | VV | | PRMF301 & C0P1300 LISTED ON SAME CUT SHEET WITH ONLY ONE XEROX MODEL CALLED OUT - SIZE DOES NOT WORK IN MOST PRMF301 LOCATIONS | 1 | 0 |
| 1359 | Logistics | MRMB1 | 1 | Mail Room and Distribution Center | 1B909 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 1 | 0 |
| 1360 | Logistics | MRMB1 | 1 | Mail Room and Distribution Center | 1B909 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 1 | VV | F | | 1 | 1 |
| 1361 | Logistics | SREO1 | 1 | Storage, Equipment | 1B911 | | | | | | | | | | |
| 1362 | Logistics | SRGC1 | 1 | Storage, Full Medical Gas | 1B912 | | | | | | | | | | |
| 1363 | Logistics | SRGC1 | 1 | Storage, Empty Medical Gas | 1B914 | | | | | | | | | | |
| 1364 | Logistics | SRHM1 | 1 | Bio-Hazard Waste Storage | 1B916 | | | | | | | | | | |
| 1365 | Logistics | | 1 | Building Manager | | | | | | | | | | | |
| 1366 | Logistics | | 1 | Building Manager | 1B903 | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | |
| 1367 | Logistics | | 1 | Building Manager | 1B903 | 1/31/2014 | | PRIN300 | PRINTER, LASER | 1 | VV | | ORIGINAL CUT SHEET RECEIVED LATER DECIDED WAS INCORRECT | 1 | |
| 1368 | Logistics | | 1 | Building Manager | 1B903 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 1 | |
| 1369 | Logistics | | 1 | Building Manager | 1B903 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 1 | VV | F | | 1 | |
| 1370 | Logistics | | 1 | Building Manager | 1B903 | | | FURN110 | CHAIR, NO ARMS | 2 | VV | F | | 2 | |
| 1371 | Logistics | | 1 | Building Manager | 1B903 | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 1 | | F | | 1 | |
| 1372 | Logistics | | 1 | Building Manager | 1B903 | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | |
| 1373 | Pathology and Laboratory Medicine (PLM) | | | | | | | | | | | | | | |
| 1374 | PLM | | 1 | Courier Receiving | | | | | | | | | | | |
| 1375 | PLM | | 1 | Courier Receiving | 1C565 | | | CASU313 | CART, SUPPLY 48X24 | 2 | VV | NO | | 2 | 1 |
| 1376 | PLM | LBSM1 | 1 | Lab: Sterilization and Solution Preparation Room | | | | | | | | | | | |
| 1377 | PLM | LBSM1 | 1 | Lab: Sterilization and Solution Preparation Room | 1C557 | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 2 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 2 | |
| 1378 | PLM | LBSM1 | 1 | Lab: Sterilization and Solution Preparation Room | 1C557 | | | PRLA301 | PRINTER, LABEL | 2 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 2 | |
| 1379 | PLM | LBSM1 | 1 | Lab: Sterilization and Solution Preparation Room | 1C557 | 2/20/2014 | | PRWB300 | PRINTER, WRIST BAND | 2 | VV | | NEED PRODUCT WEIGHT | 2 | |
| 1380 | PLM | LBSM1 | 1 | Lab: Sterilization and Solution Preparation Room | 1C557 | 3/7/2014 | | REUC317 | REFRIGERATOR, UNDERCOUNTER, ENERGY EFFICIENT | 1 | VV | | WHICH ELECTRICAL (PLUG) CONFIGURATION? WILL THIS REQUIRE A DATA CONNECTION? | 1 | |
| 1381 | PLM | LBSM1 | 1 | Lab: Sterilization and Solution Preparation Room | 1C557 | | | ROSP300 | ROCKER, SPECIMEN | 2 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 2 | |
| 1382 | PLM | LBSM1 | 1 | Lab: Sterilization and Solution Preparation Room | 1C557 | | | STDO350 | STOOL, DR. WITHOUT ARMS, ADJUSTABLE | 2 | VV | No | | 2 | |
| 1383 | PLM | LBSM1 | 1 | Lab: Sterilization and Solution Preparation Room | 1C557 | | | PACH401 | PAD CHARGER | | | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" confirm with user | | |
| 1384 | PLM | LBVP1 | 1 | Blood Specimen Collection Room | | | | | | | | | | | |
| 1385 | PLM | LBVP1 | 1 | Blood Specimen Collection Room | 1C550 | 2/20/2014 | | CHPH300 | CHAIR, PATIENT BLOOD DRAW | 3 | VV | | reduced quantity by 1 due to wheelchair station - NOT DESCRIBED BY RECEIVED CUT SHEET | 3 | |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|-----------|--------------|----------|--|------------|---------------------|--------------------|------------------|--|--------------|--------------------------|----------------------|--|-----------|-----------------------|
| 1386 | PLM | LBVP1 | 1 | Blood Specimen Collection Room | 1C550 | | | CHPH310 | CHAIR, PATIENT BLOOD DRAW, BARIATRIC | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" confirm with user | 1 | |
| 1387 | PLM | LBVP1 | 1 | Blood Specimen Collection Room | 1C550 | 2/20/2014 | | COSH321 | CONTAINER, SHARPS, 2 GALLON | 5 | VC | | TWO MODELS LISTED, PLEASE CONFIRM WE ARE USING 8509SA (W/O GLOVE BOX) NEED PRODUCT WEIGHT | 5 | |
| 1388 | PLM | LBVP1 | 1 | Blood Specimen Collection Room | 1C550 | | | MAFL302 | MAT, FLOOR, ANTI-FATIGUE | 5 | VV | NO | NOT DESCRIBED BY RECEIVED CUT SHEET | 5 | |
| 1389 | PLM | LBVP1 | 1 | Blood Specimen Collection Room | 1C550 | | | TAPH301 | STAND, PHLEBOTOMY BLOOD DRAW | 5 | VV | | NOT DESCRIBED BY RECEIVED CUT SHEET | 5 | |
| 1390 | PLM | LBVP1 | 1 | Blood Specimen Collection Room | 1C550 | | | WKBL300 | STATION, PHLEBOTOMY BLOOD DRAW, CENTRAL | 4 | VC | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 4 | |
| 1391 | PLM | LBVP1 | 1 | Blood Specimen Collection Room | 1C550 | | | WKBL303 | STATION, PHLEBOTOMY BLOOD DRAW, LEFT END | 1 | VC | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 1392 | PLM | LBVP1 | 1 | LAB: Blood Specimen Collection Room | | | | | | | | | | | 1 |
| 1393 | PLM | LBVP1 | 1 | LAB: Blood Specimen Collection Room | 1F552 | | | CAUT300 | CART, UTILITY | 1 | VV | NO | | 1 | |
| 1394 | PLM | LBVP1 | 1 | LAB: Blood Specimen Collection Room | 1F552 | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | 3 |
| 1395 | PLM | LBVP1 | 1 | LAB: Blood Specimen Collection Room | 1F552 | 1/31/2014 | | PRIN300 | PRINTER, LASER | 1 | VV | | ORIGINAL CUT SHEET RECEIVED LATER DECIDED WAS INCORRECT | 1 | |
| 1396 | PLM | LBVP1 | 1 | LAB: Blood Specimen Collection Room | 1F552 | | | STDO350 | STOOL, DR. WITHOUT ARMS, ADJUSTABLE | 1 | VV | No | | 1 | |
| 1397 | PLM | LBVP1 | 1 | LAB: Blood Specimen Collection Room | 1F552 | 2/20/2014 | | STRE305 | STRETCHER, BARATRIC | 1 | VV | | FILE NAMED STRE305, BUT LABEL SAYS STPR300, AND THERE IS A CORRECTLY NAMED DUPLICATE OF STPR300 - ARE THESE THE SAME PRODUCTS, OR ARE WE MISSING THE STRE305 CUT SHEET | 1 | |
| 1398 | PLM | LBVP1 | 1 | LAB: Peds Blood Specimen Collection Room | | | | | | | | | | | |
| 1399 | PLM | LBVP1 | 1 | LAB: Peds Blood Specimen Collection Room | 1F553 | 2/20/2014 | | BEPE310 | BED/TABLE, PEDIATRIC | 1 | VV | | Peds bed/table | 1 | |
| 1400 | PLM | LBVP1 | 1 | LAB: Peds Blood Specimen Collection Room | 1F553 | | | CAUT300 | CART, UTILITY | 1 | VV | NO | | 1 | |
| 1401 | PLM | LBVP1 | 1 | LAB: Peds Blood Specimen Collection Room | 1F553 | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | |
| 1402 | PLM | LBVP1 | 1 | LAB: Peds Blood Specimen Collection Room | 1F553 | 1/31/2014 | | PRIN300 | PRINTER, LASER | 1 | VV | | ORIGINAL CUT SHEET RECEIVED LATER DECIDED WAS INCORRECT | 1 | 0 |
| 1403 | PLM | LBVP1 | 1 | LAB: Peds Blood Specimen Collection Room | 1F553 | | | STDO350 | STOOL, DR. WITHOUT ARMS, ADJUSTABLE | 1 | VV | No | | 1 | |
| 1404 | PLM | LBVP1 | 1 | LAB: Peds Blood Specimen Collection Room | 1F553 | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | |
| 1405 | PLM | LMMO3 | 1 | Chemistry/Hematology | | | | | | | | | Room 1C562 | | |
| 1406 | PLM | LMMO3 | 1 | Chemistry/Hematology | 1C562 | 2/20/2014 | | ANBL310 | ANALYZER, CBC | 1 | VV | | 110-120 VOLT MODEL OR 220-240 VOLT MODEL? | 1 | 1 |
| 1407 | PLM | LMMO3 | 1 | Chemistry/Hematology | 1C562 | | | ANCH310 | ANALYSER, CHEMISTRY | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 1408 | PLM | LMMO3 | 1 | Chemistry/Hematology | 1C562 | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 3 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 3 | |
| 1409 | PLM | LMMO3 | 1 | Chemistry/Hematology | 1C562 | | | CAST310 | CART, STORAGE GENERAL | 1 | VV | NO | | 1 | |
| 1410 | PLM | LMMO3 | 1 | Chemistry/Hematology | 1C562 | | | CAHD310 | CART, HEAVY DUTY, ANALYZER | 1 | VV | NO | | 1 | |
| 1411 | PLM | LMMO3 | 1 | Chemistry/Hematology | 1C562 | | | MILA202 | MIXER, LAB | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 1412 | PLM | LMMO3 | 1 | Chemistry/Hematology | 1C562 | | | MICR402 | MICROSCOPE, LAB | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 1413 | PLM | LMMO3 | 1 | Chemistry/Hematology | 1C562 | | | MIVO310 | MIXER, VORTEX | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 1414 | PLM | LMMO3 | 1 | Chemistry/Hematology | 1C562 | | | REWA313 | RECEPTACLE, WASTE, XL, 23 GAL, MOBILE | 2 | VV | No | | 2 | 0 |
| 1415 | PLM | LMMO3 | 1 | Chemistry/Hematology | 1C562 | | | REWB307 | RECEPTACLE, WASTE, BIOHAZARD, 44 GAL | 1 | VV | No | | 1 | |
| 1416 | PLM | LMMO3 | 1 | Chemistry/Hematology | 1C562 | | | STDO350 | STOOL, DR. WITHOUT ARMS, ADJUSTABLE | 4 | VV | No | | 4 | |
| 1417 | PLM | LMMO3 | 1 | Chemistry/Hematology | 1C562 | | | STHE310 | STAINER, HEMO | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 1418 | PLM | LMMO3 | 1 | Chemistry/Hematology | 1C562 | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | |
| 1419 | PLM | LMUO2 | 1 | Urinalysis & Microscope | | | | | | | | | | | |
| 1420 | PLM | LMUO2 | 1 | Urinalysis & Microscope | 1C558 | | | CAST310 | CART, STORAGE GENERAL | 1 | VV | NO | | 1 | |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|-----------|--------------|----------|-----------------------------------|--------------|---------------------|--------------------|------------------|---------------------------------------|---|--------------------------|----------------------|---|-----------|-----------------------|
| 1421 | PLM | LMUO2 | 1 | Urinalysis & Microscope | 1C558 | | 3/7/2014 | | CENT302 | CENTRIFUGE, TABLE TOP | 1 | VV | confirm if same as model in Processing due to potential casework modifications. -WHICH MODEL? MULTIPLE LISTED IN PROVIDED CUT SHEET | 1 | 1 |
| 1422 | PLM | LMUO2 | 1 | Urinalysis & Microscope | 1C558 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | |
| 1423 | PLM | LMUO2 | 1 | Urinalysis & Microscope | 1C558 | | | MICR314 | MICROSCOPE, LAB | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | 0 |
| 1424 | PLM | LMUO2 | 1 | Urinalysis & Microscope | 1C558 | | | MILA202 | MIXER, LAB | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 1425 | PLM | LMUO2 | 1 | Urinalysis & Microscope | 1C558 | | 2/20/2014 | 3/10/2014 | REFR323 | REFRIGERATOR/FREEZER, NSF CERTIFIED | 1 | VV | | 1 | |
| 1426 | PLM | LMUO2 | 1 | Urinalysis & Microscope | 1C558 | | | REWA320 | RECEPTACLE, WASTE, METAL, 15 GAL | 1 | VV | No | | 1 | |
| 1427 | PLM | LMUO2 | 1 | Urinalysis & Microscope | 1C558 | | | REWB320 | RECEPTACLE, WASTE, BIOHAZARD, 15 GAL | 1 | VV | NO | | 1 | |
| 1428 | PLM | LMUO2 | 1 | Urinalysis & Microscope | 1C558 | | | STDO350 | STOOL, DR. WITHOUT ARMS, ADJUSTABLE | 1 | VV | No | | 1 | |
| 1429 | PLM | LMUO2 | 1 | Urinalysis & Microscope | 1C558 | | 1/31/2014 | | SYME301 | OMNIRX TWO-CELL / SUPPLIER | 1 | VV | NEED MODEL NUMBER | 1 | |
| 1430 | PLM | LMUO2 | 1 | Urinalysis & Microscope | 1C558 | | | SYME301A | SEISMIC RESTRAINT | 1 | VV | - | | 1 | |
| 1431 | PLM | LMUO2 | 1 | Urinalysis & Microscope | 1C558 | | | URTE310 | URINALYSIS TESTING INSTRUMENT | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 1432 | PLM | LMUO2 | 1 | Urinalysis & Microscope | 1C558 | | | WOTE310 | AFFIRM, WOMENS TESTING | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 1433 | PLM | LMUO2 | 1 | Urinalysis & Microscope | 1C558 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | 1 | |
| 1434 | PLM | TLTU1 | 2 | Toilet, Urine Specimen Collection | | | | | | | | | | | |
| 1435 | PLM | TLTU1 | 2 | Toilet, Urine Specimen Collection | 1F556, 1F555 | | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | 2 | |
| 1436 | PLM | LBBD2 | 1 | Processing | | | | | | | | | | | |
| 1437 | PLM | LBBD2 | 1 | Processing | 1C561 | | | BACS204 | BAR CODE SCANNER | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 1438 | PLM | LBBD2 | 1 | Processing | 1C561 | | | CAAN310 | CART, HEAVY DUTY, ANALYSER | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | 0 |
| 1439 | PLM | LBBD2 | 1 | Processing | 1C561 | | | CAST310 | CART, STORAGE GENERAL | 2 | VV | NO | | 2 | |
| 1440 | PLM | LBBD2 | 1 | Processing | 1C561 | | 3/7/2014 | | CENT302 | CENTRIFUGE, GENERAL PURPOSE | 2 | VV | casework modification required -WHICH MODEL? MULTIPLE LISTED IN PROVIDED CUT SHEET | 2 | |
| 1441 | PLM | LBBD2 | 1 | Processing | 1C561 | | | HEBL310 | HEAT BLOCK | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 1442 | PLM | LBBD2 | 1 | Processing | 1C561 | | | MILA202 | MIXER, LAB | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 1443 | PLM | LBBD2 | 1 | Processing | 1C561 | | | STDO350 | STOOL, DR. WITHOUT ARMS, ADJUSTABLE | 2 | VV | No | | 2 | |
| 1444 | PLM | SRRO2 | 1 | LAB: Storage, Refrigerated | | | | | | | | | | | |
| 1445 | PLM | SRRO2 | 1 | LAB: Storage, Refrigerated | 1C559 | | | CASU313 | CART, SUPPLY 48X24 | 2 | VV | NO | | 2 | |
| 1446 | PLM | SRRO2 | 1 | LAB: Storage, Refrigerated | 1C559 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | |
| 1447 | PLM | SRRO2 | 1 | LAB: Storage, Refrigerated | 1C559 | | 2/20/2014 | | FRUC311 | FREEZER, UNDERCOUNTER | 1 | VV | | 1 | |
| 1448 | PLM | SRRO2 | 1 | LAB: Storage, Refrigerated | 1C559 | | 1/31/2014 | | PRMF301 | PRINTER, MULTI-FUNCTION | 1 | VV | PRMF301 & C0P1300 LISTED ON SAME CUT SHEET WITH ONLY ONE XEROX MODEL CALLED OUT - SIZE DOES NOT WORK IN MOST PRMF301 LOCATIONS | 1 | 0 |
| 1449 | PLM | SRRO2 | 1 | LAB: Storage, Refrigerated | 1C559 | | 2/20/2014 | 3/10/2014 | REFR323 | REFRIGERATOR/FREEZER, 2 DOOR, NSF CERTIFIED | 2 | VC | | 2 | 0 |
| 1450 | PLM | SRRO2 | 1 | LAB: Storage, Refrigerated | 1C559 | | | REWA313 | RECEPTACLE, WASTE, XL, 23 GAL, MOBILE | 1 | VV | No | | 1 | 0 |
| 1451 | PLM | SRRO2 | 1 | LAB: Storage, Refrigerated | 1C559 | | | REWB307 | RECEPTACLE, WASTE, BIOHAZARD, 44 GAL | 1 | VV | No | | 1 | 1 |
| 1452 | PLM | SRSO1 | 1 | LAB: Storage, Bulk & General | | | | | | | | | | | |
| 1453 | PLM | SRSO1 | 1 | LAB: Storage, Bulk & General | 1C564 | | | SHEL300 | SHELVING, 18" DEEP, STARTER | 8 | VC | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 8 | |
| 1454 | PLM | SECO1 | 1 | Office, Secretary/Clerical | | | | | | | | | | | |
| 1455 | PLM | SECO1 | 1 | Office, Secretary/Clerical | 1F551 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 2 | VV | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 2 | 0 |
| 1456 | PLM | SECO1 | 1 | Office, Secretary/Clerical | 1F551 | | | DINU300 | DISPENSER, NUMBER, ELECTRONIC | 1 | VC | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" user recommends Omatic | 1 | 0 |
| 1457 | PLM | SECO1 | 1 | Office, Secretary/Clerical | 1F551 | | | PRLA301 | PRINTER, LABEL | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| | EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/ Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|------|--|-----------|--------------|--|--------------|------------|---------------------|--------------------|------------------|-------------------------------------|--------------|---------------------------|----------------------|--|-----------|-----------------------|
| 1458 | PLM | SECO1 | 1 | Office, Secretary/Clerical | 1F551 | | 1/31/2014 | | PRMF301 | PRINTER, MULTI-FUNCTION | 1 | VV | | PRMF301 & COPI300 LISTED ON SAME CUT SHEET WITH ONLY ONE XEROX MODEL CALLED OUT - SIZE DOES NOT WORK IN MOST PRMF301 LOCATIONS | 1 | |
| 1459 | PLM | SECO1 | 1 | Office, Secretary/Clerical | 1F551 | | 2/20/2014 | | PRWB300 | PRINTER, WRIST BAND | 1 | VV | | NEED PRODUCT WEIGHT | 1 | |
| 1460 | PLM | SECO1 | 1 | Office, Secretary/Clerical | 1F551 | | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 1 | 0 |
| 1461 | PLM | SECO1 | 1 | Office, Secretary/Clerical | 1F551 | | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 2 | VV | F | | 1 | 0 |
| 1462 | PLM | SECO1 | 1 | Office, Secretary/Clerical | 1F551 | | | | FURN200 | WORKSTATION, L-SHAPE, 2'-6" X 6'-0" | 2 | VV | F | | 1 | 0 |
| 1463 | PLM | SECO1 | 1 | Office, Secretary/Clerical | 1F551 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | 1 |
| 1464 | PLM | | 1 | Transport Area/Receiving | | | | | | | | | | | | |
| 1465 | PLM | | 1 | Transport Area/Receiving | 1C566 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | 0 |
| 1466 | PLM | | 1 | Transport Area/Receiving | 1C566 | | 1/31/2014 | | PRMF301 | PRINTER, MULTI-FUNCTION | 1 | VV | | PRMF301 & COPI300 LISTED ON SAME CUT SHEET WITH ONLY ONE XEROX MODEL CALLED OUT - SIZE DOES NOT WORK IN MOST PRMF301 LOCATIONS | 1 | |
| 1467 | PLM | | 1 | Transport Area/Receiving | 1C566 | | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 1 | VV | F | | 1 | 0 |
| 1468 | PLM | | 1 | Transport Area/Receiving | 1C566 | | | | FURN265 | WORKSTATION, 2'-0" X 8'-0" | 2 | VV | F | | 2 | 0 |
| 1469 | PLM | | 1 | Team Area, Workstations | | | | | | | | | | | | |
| 1470 | PLM | | 1 | Team Area, Workstations | 1C568 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 2 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 2 | |
| 1471 | PLM | | 1 | Team Area, Workstations | 1C568 | | 1/31/2014 | | PRMF301 | PRINTER, MULTI-FUNCTION | 1 | VV | | PRMF301 & COPI300 LISTED ON SAME CUT SHEET WITH ONLY ONE XEROX MODEL CALLED OUT - SIZE DOES NOT WORK IN MOST PRMF301 LOCATIONS | 1 | |
| 1472 | PLM | | 1 | Team Area, Workstations | 1C568 | | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 2 | VV | F | | 2 | |
| 1473 | PLM | | 1 | Team Area, Workstations | 1C568 | | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 2 | VV | F | | 2 | 0 |
| 1474 | PLM | | 1 | Team Area, Workstations | 1C568 | | | | FURN534 | BOOKCASE, 15" X 48" | 3 | VV | F | | 3 | 0 |
| 1475 | PLM | | 1 | Team Area, Workstations | 1C568 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | 0 |
| 1476 | PLM | TLTU1 | 1 | Toilet, Staff | | | | | | | | | | | | 0 |
| 1477 | PLM | TLTU1 | 1 | Toilet, Staff | 1C567 | | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | | 1 | 1 |
| 1478 | PLM | WRCO1 | 1 | Waiting Area | | | | | | | | | | | | |
| 1479 | PLM | WRCO1 | 1 | Waiting Area | 1F502 | | | | FURN150 | CHAIR, WAITING ROOM | 4 | VV | F | | 4 | |
| 1480 | PLM | WRCO1 | 1 | Waiting Area | 1F502 | | | | FURN400 | SIDE TABLE | 3 | VV | F | | 3 | |
| 1481 | Pharmacy | | | | | | | | | | | | | | | 0 |
| 1482 | Pharmacy | OFAO1 | 2 | Intake/Consultation Room | | | | | | | | | | | | 0 |
| 1483 | Pharmacy | OFAO1 | 2 | Intake/Consultation Room | 1B503, 1B504 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 2 | |
| 1484 | Pharmacy | OFAO1 | 2 | Intake/Consultation Room | 1B503, 1B504 | | 1/31/2014 | | PRIN300 | PRINTER, LASER | 1 | VV | | ORIGINAL CUT SHEET RECEIVED LATER DECIDED WAS INCORRECT | 2 | |
| 1485 | Pharmacy | OFAO1 | 2 | Intake/Consultation Room | 1B503, 1B504 | | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 2 | |
| 1486 | Pharmacy | OFAO1 | 2 | Intake/Consultation Room | 1B503, 1B504 | | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 1 | VV | F | | 2 | |
| 1487 | Pharmacy | OFAO1 | 2 | Intake/Consultation Room | 1B503, 1B504 | | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 1 | VV | F | | 2 | |
| 1488 | Pharmacy | OFAO1 | 2 | Intake/Consultation Room | 1B503, 1B504 | | | | FURN110 | CHAIR, NO ARMS | 2 | VV | F | | 4 | 1 |
| 1489 | Pharmacy | OFAO1 | 2 | Intake/Consultation Room | 1B503, 1B504 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 2 | |
| 1490 | Pharmacy | PHBS1 | 1 | Drug Receiving: Breakdown and Verification | | | | | | | | | | | | |
| 1491 | Pharmacy | PHBS1 | 1 | Drug Receiving: Breakdown and Verification | 1B513 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 2 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 2 | |
| 1492 | Pharmacy | PHBS1 | 1 | Drug Receiving: Breakdown and Verification | 1B513 | | | | MEMA300 | MEDICATION, MASTER CONTROL STATION | 1 | VV | | **NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN** | 1 | |
| 1493 | Pharmacy | PHBS1 | 1 | Drug Receiving: Breakdown and Verification | 1B513 | | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 2 | VV | F | | 2 | |
| 1494 | Pharmacy | PHBS1 | 1 | Drug Receiving: Breakdown and Verification | 1B513 | | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 2 | VV | F | | 2 | |
| 1495 | Pharmacy | PHOD1 | 1 | Filling and Assembly | | | | | | | | | | | | 0 |
| 1496 | Pharmacy | PHOD1 | 1 | Filling and Assembly | 1B506 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 2 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 2 | 0 |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|-----------|--------------|----------|----------------------------|------------|---------------------|--------------------|------------------|-----------|--|--------------------------|----------------------|---|-----------|-----------------------|
| 1497 | Pharmacy | PHOD1 | 1 | Filling and Assembly | 1B506 | M7265 | 2/20/2014 | | COP1300 | COUNTER, PILL/TABLET, AUTOMATED, COUNTER MOUNTED | 3 | VV | PRMF301 & COP1300 LISTED ON SAME CUT SHEET WITH ONLY ONE XEROX MODEL CALLED OUT - SIZE DOES NOT WORK IN MOST PRMF301 LOCATIONS | 3 | 0 |
| 1498 | Pharmacy | PHOD1 | 1 | Filling and Assembly | 1B506 | M7280 | 1/31/2014 | | DISY300 | DISPENSING SYSTEM, PRESCRIPTION, ROBOTIC | 1 | VV | WITH OR WITHOUT OPTIONAL HOOD? | 1 | 1 |
| 1499 | Pharmacy | PHOD1 | 1 | Filling and Assembly | 1B506 | | 1/31/2014 | | PRMF301 | PRINTER, MULTI-FUNCTION | 2 | VV | PRMF301 & COP1300 LISTED ON SAME CUT SHEET WITH ONLY ONE XEROX MODEL CALLED OUT - SIZE DOES NOT WORK IN MOST PRMF301 LOCATIONS | 2 | |
| 1500 | Pharmacy | PHOD1 | 1 | Filling and Assembly | 1B506 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | 1 | |
| 1501 | Pharmacy | PHOD2 | 1 | Active Storage | | | | | | | | | | | |
| 1502 | Pharmacy | PHOD2 | 1 | Active Storage | 1B510 | E0606 | | | SHPH310 | SHELF UNIT, PHARMACY, WALL MTD., 88"HX48"WX16"D | 5 | VV | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 5 | |
| 1503 | Pharmacy | PHOD2 | 1 | Active Storage | 1B510 | E0612 | | | SHPH312 | SHELF UNIT, PHARMACY, WALL MTD., 88"HX48"WX16"D | 8 | VV | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 8 | |
| 1504 | Pharmacy | SSSO1 | 1 | Pharmacy Vault | | | | | | | | | | | |
| 1505 | Pharmacy | SSSO1 | 1 | Pharmacy Vault | 1B507 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 2 | VV | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 2 | |
| 1506 | Pharmacy | SSSO1 | 1 | Pharmacy Vault | 1B507 | | 1/31/2014 | | PRIN300 | PRINTER, LASER | 2 | VV | ORIGINAL CUT SHEET RECEIVED LATER DECIDED WAS INCORRECT | 2 | 0 |
| 1507 | Pharmacy | SSSO1 | 1 | Pharmacy Vault | 1B507 | | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 2 | VV | No | 2 | |
| 1508 | Pharmacy | SSSO1 | 1 | Pharmacy Vault | 1B507 | | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 2 | VV | F | 2 | |
| 1509 | Pharmacy | SSSO1 | 1 | Pharmacy Vault | 1B507 | | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 2 | VV | F | 2 | |
| 1510 | Pharmacy | SSSO1 | 1 | Pharmacy Vault | 1B507 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | 1 | |
| 1511 | Pharmacy | SSSO1 | 1 | Pick Up | | | | | | | | | | | |
| 1512 | Pharmacy | SSSO1 | 1 | Pick Up | 1B502 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | |
| 1513 | Pharmacy | SSSO1 | 1 | Pick Up | 1B502 | M1855 | 2/20/2014 | | FACS300 | FACSIMILE, MACHINE | 1 | VV | | 1 | 0 |
| 1514 | Pharmacy | SSSO1 | 1 | Pick Up | 1B502 | A1095 | 2/20/2014 | | MEBD310 | MESSAGE BOARD, DIGITAL | 1 | VC | User recommends Omnic, master control here with display units at Waiting - NEED MODEL NUMBER, DIMENSIONS, POWER/DATA REQUIREMENTS. ALSO, WE ARE CURRENTLY ONLY SHOWING THIS IN THE PHARMACY - ARE THERE ADDITIONAL LOCATIONS? | 1 | 0 |
| 1514 | Pharmacy | SSSO1 | 1 | Pick Up | 1B502 | | 2/20/2014 | | MEBD330 | RECEPTION CONSOLE | | | NEED MODEL NUMBER, DIMENSIONS, POWER/DATA REQUIREMENTS - IS THIS JUST SOFTWARE INSTALLED ON THE RECEPTION DESK COMPUTERS? | 1 | 0 |
| 1514 | Pharmacy | SSSO1 | 1 | Pick Up | 1B502 | | 2/20/2014 | | MEBD330 | SELF SERVE KIOSK | | | NEED MODEL NUMBER, DIMENSIONS, POWER/DATA REQUIREMENTS | 1 | 0 |
| 1515 | Pharmacy | SSSO1 | 1 | Pick Up | 1B502 | | 1/31/2014 | | PRIN300 | PRINTER, LASER | 1 | VV | ORIGINAL CUT SHEET RECEIVED LATER DECIDED WAS INCORRECT | 1 | 0 |
| 1516 | Pharmacy | SSSO1 | 1 | Pick Up | 1B502 | M1830 | | | PRIN350 | PRINTER, LABEL, PHARMACY | 1 | VV | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | 1 |
| 1517 | Pharmacy | SSSO1 | 1 | Pick Up | 1B502 | | 1/31/2014 | 2/20/2014 | REUC315 | REFRIGERATOR, UNDERCOUNTER, ADA | 1 | VV | | 1 | |
| 1518 | Pharmacy | SSSO1 | 1 | Pick Up | 1B502 | | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 1 | VV | F | | 0 |
| 1519 | Pharmacy | SSSO1 | 1 | Pick Up | 1B502 | | | | REUC315A | TEMPERATURE ALARM WITH PROBE | 1 | VV | - | 1 | |
| 1520 | Pharmacy | SRRO1 | 1 | Refrigeration/Freezer Area | | | | | | | | | | | |
| 1521 | Pharmacy | SRRO1 | 1 | Refrigeration/Freezer Area | 1B505 | R6060 | 1/31/2014 | 3/10/2014 | REFR350 | REFRIGERATOR, BIOLOGICAL, SS, 2 DOOR, 50 CU. FT. | 1 | VV | WHICH ELECTRICAL (PLUG) CONFIGURATION? NEED DATA REQUIREMENTS | 1 | |
| 1522 | Pharmacy | SRRO1 | 1 | Refrigeration/Freezer Area | 1B505 | | 1/31/2014 | 3/10/2014 | FREE310 | FREEZER, SS, 1 DOOR, 23 CU. FT. | 1 | VV | WHICH ELECTRICAL (PLUG) CONFIGURATION? | 1 | |
| 1523 | Pharmacy | OFAO1 | 1 | Office Shared, Pharmacist | | | | | | | | | | 0 | |
| 1524 | Pharmacy | OFAO1 | 1 | Office Shared, Pharmacist | 1B508 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 2 | VV | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 2 | 0 |
| 1525 | Pharmacy | OFAO1 | 1 | Office Shared, Pharmacist | 1B508 | | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 2 | VV | No | 2 | 0 |
| 1526 | Pharmacy | OFAO1 | 1 | Office Shared, Pharmacist | 1B508 | | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 2 | VV | F | 2 | 0 |
| 1527 | Pharmacy | OFAO1 | 1 | Office Shared, Pharmacist | 1B508 | | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 2 | VV | F | 2 | 1 |
| 1528 | Pharmacy | OFAO1 | 1 | Office Shared, Pharmacist | 1B508 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | 1 | |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/ Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|-----------|--------------|---|--------------|------------|---------------------|--------------------|------------------|---|--------------|---------------------------|----------------------|--|-----------|-----------------------|
| 1529 Pharmacy | TLTU1 | 1 | Toilet, Staff | | | | | | | | | | | | |
| 1530 Pharmacy | TLTU1 | 1 | Toilet, Staff | 1B512 | | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | | 1 | |
| 1531 Pharmacy | SLOO1 | 1 | Staff Lounge | | | | | | | | | | | 0 | |
| 1532 Pharmacy | SLOO1 | 1 | Staff Lounge | 1B511 | | 2/20/2014 | | COMA309 | COFFEE MAKER, PLUMBED | 1 | VC | | | 1 | |
| 1533 Pharmacy | SLOO1 | 1 | Staff Lounge | 1B511 | | 2/20/2014 | | OVM1303 | OVEN, MICROWAVE | 1 | VV | | | 1 | 0 |
| 1534 Pharmacy | SLOO1 | 1 | Staff Lounge | 1B511 | | 2/20/2014 | | REFR311 | REFRIGERATOR/FREEZER, 21 CU FT W/ ICE MAKER | 1 | VV | | | 1 | 0 |
| 1535 Pharmacy | SLOO1 | 1 | Staff Lounge | 1B511 | | | | REWA303 | RECEPTACLE, WASTE, 23 GAL, SLIM JIM | 1 | VV | NO | | 1 | 0 |
| 1536 Pharmacy | SLOO1 | 1 | Staff Lounge | 1B511 | | | | REWA303A | SWING TOP | 1 | VV | - | | 1 | |
| 1537 Pharmacy | SLOO1 | 1 | Staff Lounge | 1B511 | | | | FURN312 | TABLE, ROUND, 4 PERSON | 1 | VV | F | | 1 | |
| 1538 Pharmacy | SLOO1 | 1 | Staff Lounge | 1B511 | | | | FURN112 | CHAIR, NO ARMS | 4 | VV | F | | 4 | |
| 1539 Pharmacy | SLOO1 | 1 | Staff Lounge | 1B511 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | |
| 1540 Pharmacy | SRCS1 | 1 | Bulk Storage, Prosthetic and Medical Supplies | | | | | | | | | | | 0 | |
| 1541 Pharmacy | WRCO1 | 1 | Waiting Area | | | | | | | | | | | 0 | |
| 1542 Pharmacy | WRCO1 | 1 | Waiting Area | 1B501 | A1095 | | | MEBD320 | MESSAGE BOARD, DIGITAL DISPLAY | 3 | VC | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" User recommends Qmatic; display units here with master at Pick-Up. | 3 | 0 |
| 1543 Pharmacy | WRCO1 | 1 | Waiting Area | 1B501 | | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 2 | VV | No | | 2 | 1 |
| 1544 Pharmacy | WRCO1 | 1 | Waiting Area | 1B501 | | 2/20/2014 | | TELE312 | TELEVISION, FLAT PANEL, 52" LCD | 1 | VC | | WE RECEIVED ONE CUT SHEET WITH TWO EQUIPMENT NUMBERS AND ONLY ONE MODEL INDICATED - ARE THEY TO BE THE SAME SIZE? | 1 | |
| 1545 Pharmacy | WRCO1 | 1 | Waiting Area | 1B501 | | | | FURN150 | CHAIR, WAITING ROOM | 8 | VV | F | | 8 | |
| 1546 Pharmacy | WRCO1 | 1 | Waiting Area | 1B501 | | | | FURN142 | CHAIR, BARIATRIC | 3 | VV | F | | 3 | |
| 1547 Pharmacy | WRCO1 | 1 | Waiting Area | 1B501 | | | | FURN400 | SIDE TABLE | 3 | VV | F | | 3 | 0 |
| 1548 Physical Medicine and Rehabilitation (PMR) | | | | | | | | | | | | | | 0 | |
| 1549 PMR | OFAO1 | 1 | PT: Clinic Office | | | | | | | | | | | 1 | |
| 1550 PMR | OFAO1 | 1 | PT: Clinic Office | 1A313 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 2 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 2 | |
| 1551 PMR | OFAO1 | 1 | PT: Clinic Office | 1A313 | | 1/31/2014 | | PRIN300 | PRINTER, LASER | 1 | VV | | ORIGINAL CUT SHEET RECEIVED LATER DECIDED WAS INCORRECT | 1 | 0 |
| 1552 PMR | OFAO1 | 1 | PT: Clinic Office | 1A313 | | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 2 | VV | F | | 2 | |
| 1553 PMR | OFAO1 | 1 | PT: Clinic Office | 1A313 | | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 2 | VV | F | | 2 | 0 |
| 1554 PMR | OFAO1 | 1 | PT: Clinic Office | 1A313 | | | | FURN530 | BOOKCASE, 15" X 36" | 2 | VV | F | | 2 | |
| 1555 PMR | OFAO1 | 1 | PT: Clinic Office | 1A313 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | |
| 1556 PMR | OFAO1 | 1 | OT: Clinic Office | | | | | | | | | | | | |
| 1557 PMR | OFAO1 | 1 | OT: Clinic Office | 1B301 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 4 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 4 | |
| 1558 PMR | OFAO1 | 1 | OT: Clinic Office | 1B301 | | 1/31/2014 | | PRIN300 | PRINTER, LASER | 1 | VV | | ORIGINAL CUT SHEET RECEIVED LATER DECIDED WAS INCORRECT | 1 | |
| 1559 PMR | OFAO1 | 1 | OT: Clinic Office | 1B301 | | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 4 | VV | F | | 4 | |
| 1560 PMR | OFAO1 | 1 | OT: Clinic Office | 1B301 | | | | FURN214 | WORKSTATION, 2'-6" X 3'-6" | 4 | VV | F | | 4 | |
| 1561 PMR | OFAO1 | 1 | OT: Clinic Office | 1B301 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | |
| 1562 PMR | OTGC1 | 1 | OT Treatment Clinic | | | | | | | | | | | | |
| 1563 PMR | OTGC1 | 1 | OT Treatment Clinic | 1A309 | | 2/20/2014 | | TAHA205 | TABLE, HAND | 2 | VV | | NEED PRODUCT WEIGHT | 2 | 1 |
| 1564 PMR | OTGC1 | 1 | OT Treatment Clinic | 1A309 | | 12/19/2013 | | TAMT410 | TABLE, MAT, MOTORIZED, HI-LOW | 1 | VV | | Patterson, Metron Plus, #2228 - NEED OVERALL DIMENSIONS | 1 | |
| 1565 PMR | OTGC1 | 1 | OT Treatment Clinic | 1A309 | | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 4 | VV | F | | 4 | |
| 1566 PMR | OTGC1 | 2 | Treatment Rooms (Quiet Rooms) | | | | | | | | | | | | |
| 1567 PMR | OTGC1 | 2 | Treatment Rooms (Quiet Rooms) | 1A303, 1A302 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 2 | |
| 1568 PMR | OTGC1 | 2 | Treatment Rooms (Quiet Rooms) | 1A303, 1A302 | | 2/20/2014 | | COST300 | COMPUTER STATION, WALL MOUNT | 1 | VC | | WAITING ON PRODUCT SELECTION - NEED DIMENSIONS, WEIGHT, AND POWER / DATA REQUIREMENTS | 2 | |
| 1568 PMR | OTGC1 | 2 | Treatment Rooms (Quiet Rooms) | 1A303, 1A302 | | 2/20/2014 | | COST320 | MOBILE WORKSTATION, KIDNEY SHAPED TABLE | 1 | VV | | | 2 | 0 |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|-----------|--------------|----------|-------------------------------|--------------|---------------------|--------------------|------------------|--|--------------|--------------------------|----------------------|---|-----------|-----------------------|
| 1569 | PMR | OTGC1 | 2 | Treatment Rooms (Quiet Rooms) | 1A303, 1A302 | | | CRMD201 | CART, MODALITY | 1 | VV | | **NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN** | 2 | |
| 1570 | PMR | OTGC1 | 2 | Treatment Rooms (Quiet Rooms) | 1A303, 1A302 | | 2/20/2014 | LIPA310 | LIFT, PATIENT, MOBILE | 1 | VV | | at Room 1024 - NEED MODEL NUMBERS & POWER REQUIREMENTS | 1 | |
| 1571 | PMR | OTGC1 | 2 | Treatment Rooms (Quiet Rooms) | 1A303, 1A302 | | | STDO255 | STOOL, ADJUSTABLE WITHOUT BACK | 1 | VV | NO | | 2 | 1 |
| 1572 | PMR | OTGC1 | 2 | Treatment Rooms (Quiet Rooms) | 1A303, 1A302 | | 12/19/2013 | TATE400 | TABLE, TREATMENT | 1 | VV | | at Room 1024: Patterson, Performa Bariatric Plus Hi-Lo Table, #560274 - NEED OVERALL DIMENSIONS | 1 | |
| 1573 | PMR | OTGC1 | 2 | Treatment Rooms (Quiet Rooms) | 1A303, 1A302 | | 12/19/2013 | TATR400 | TABLE, TRACTION | 1 | VV | | at Room 1023: Patterson, Hi-Lo Traction Packages, #560731 - NEED MODEL NUMBER, WEIGHT, AND POWER REQUIREMENTS | 1 | 2 |
| 1574 | PMR | OTGC1 | 2 | Treatment Rooms (Quiet Rooms) | 1A303, 1A302 | | 12/19/2013 | ULEL400 | ULTRASOUND-ELECTROSTIMULATOR, MOBILE | 1 | VV | | Patterson, Vectra Genisys tower - IS DATA REQUIRED? | 2 | |
| 1575 | PMR | OTGC1 | 2 | Treatment Rooms (Quiet Rooms) | 1A303, 1A302 | | 2/20/2014 | CLWA801 | CLOCK | 1 | VV | | | 2 | |
| 1576 | PMR | OTGC1 | 1 | Treatment Rooms | 1A316, 1A315 | | | | | | | | | | |
| 1577 | PMR | OTGC1 | 1 | Treatment Rooms | 1A316, 1A315 | | 2/20/2014 | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 2 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 2 | |
| 1578 | PMR | OTGC1 | 1 | Treatment Rooms | 1A316, 1A315 | | 2/20/2014 | COST300 | COMPUTER STATION, WALL MOUNT | 2 | VC | | WAITING ON PRODUCT SELECTION - NEED DIMENSIONS, WEIGHT, AND POWER / DATA REQUIREMENTS | 2 | |
| 1578 | PMR | OTGC1 | 1 | Treatment Rooms | 1A316, 1A315 | | 2/20/2014 | COST320 | MOBILE WORKSTATION, KIDNEY SHAPED TABLE | 2 | VV | | | 2 | 0 |
| 1579 | PMR | OTGC1 | 1 | Treatment Rooms | 1A316, 1A315 | | | CRMD201 | CART, MODALITY | 2 | VV | | **NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN** | 2 | |
| 1580 | PMR | OTGC1 | 1 | Treatment Rooms | 1A316, 1A315 | | | STDO255 | STOOL, ADJUSTABLE WITHOUT BACK | 2 | VV | NO | | 2 | |
| 1581 | PMR | OTGC1 | 1 | Treatment Rooms | 1A316, 1A315 | | 12/19/2013 | TATE400 | TABLE, TREATMENT | 2 | VV | | Patterson, Performa Bariatric Plus Hi-Lo Table, #560274 - NEED OVERALL DIMENSIONS | 2 | |
| 1582 | PMR | OTGC1 | 1 | Treatment Rooms | 1A316, 1A315 | | 12/19/2013 | ULEL400 | ULTRASOUND-ELECTROSTIMULATOR, MOBILE | 2 | VV | | Patterson, Vectra Genisys tower - IS DATA REQUIRED? | 2 | |
| 1583 | PMR | OTGC1 | 1 | Treatment Rooms | 1A316, 1A315 | | 2/20/2014 | CLWA801 | CLOCK | 2 | VV | | | 2 | 0 |
| 1584 | PMR | PTEA1 | 1 | Treatment Exercise Area | 1A304 | | | | | | | | Room 1A304 | | |
| 1585 | PMR | PTEA1 | 1 | Treatment Exercise Area | 1A304 | | 12/19/2013 | BAPA400 | BARS, PARALLEL | 1 | VV | | Hausmann Industries, #1362, NEED POWER REQUIREMENTS | 1 | |
| 1586 | PMR | PTEA1 | 1 | Treatment Exercise Area | 1A304 | | 2/20/2014 | BAPR400 | BATHS, PARAFFIN | 1 | VV | | Patterson, Dickson Paraffin Baths, #3550 | 1 | |
| 1587 | PMR | PTEA1 | 1 | Treatment Exercise Area | 1A304 | | 12/19/2013 | BATE400 | BALANCE TESTING, POSTUROGRAPHY | 1 | VV | | NeuroCom, SMART EquiTest, NEED: DIMENSIONS, POWER, DATA REQUIREMENTS | 1 | |
| 1588 | PMR | PTEA1 | 1 | Treatment Exercise Area | 1A304 | G1037 | | CAWE400 | CART, WEIGHT | 1 | VV | | Patterson, #5175 | 1 | |
| 1589 | PMR | PTEA1 | 1 | Treatment Exercise Area | 1A304 | | 2/20/2014 | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | |
| 1590 | PMR | PTEA1 | 1 | Treatment Exercise Area | 1A304 | | | CRMD201 | CART, MODALITY | 1 | VV | | **NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN** | 1 | |
| 1591 | PMR | PTEA1 | 1 | Treatment Exercise Area | 1A304 | | 12/19/2013 | ERGO410 | ERGOMETER, UPPER BODY | 1 | VV | | Soft II PRO2 - NEED POWER REQUIREMENTS | 1 | |
| 1592 | PMR | PTEA1 | 1 | Treatment Exercise Area | 1A304 | G1026 | 12/19/2013 | EXAP400 | EXERCISE APPARATUS, WEIGHT TRAINING, MULTI-STATION (TOTAL GYM) | 1 | VV | | vendor: FreeMotion Cable Cross | 1 | |
| 1593 | PMR | PTEA1 | 1 | Treatment Exercise Area | 1A304 | | 2/20/2014 | EXBI125 | EXERCISE BIKE, UPRIGHT | 1 | VV | | | 1 | |
| 1594 | PMR | PTEA1 | 1 | Treatment Exercise Area | 1A304 | G1043 | 12/19/2013 | EXBR400 | EXERCISE BIKE, RECUMBENT | 1 | VV | | Nustep T5 - NEED POWER & DATA REQUIREMENTS | 1 | |
| 1595 | PMR | PTEA1 | 1 | Treatment Exercise Area | 1A304 | G1007 | 2/20/2014 | EXST400 | EXERCISE STAIRS | 1 | VV | | | 1 | |
| 1596 | PMR | PTEA1 | 1 | Treatment Exercise Area | 1A304 | | 12/19/2013 | FLTH400 | FLUID THERAPY MACHINE | 1 | VV | | DJO Global, Chattanooga, #FLU115D | 1 | |
| 1597 | PMR | PTEA1 | 1 | Treatment Exercise Area | 1A304 | | 12/19/2013 | PASP400 | PAN, SPLINT, HEAT | 1 | VV | | Patterson, Clinic Forma-Splint Pan, #7261 - NEED OVERALL DIMENSIONS & DRAINAGE REQUIREMENTS | 1 | 0 |
| 1598 | PMR | PTEA1 | 1 | Treatment Exercise Area | 1A304 | | 12/19/2013 | PASP410 | PAN, SPLINT, CART | 1 | VV | | Patterson, Rolyan Splint Center, #A5314 - NEED POWER & DRAINAGE REQUIREMENTS FOR CART | 1 | 0 |
| 1599 | PMR | PTEA1 | 1 | Treatment Exercise Area | 1A304 | | 12/19/2013 | LIPA320 | LIFT, PATIENT, REHAB | 1 | VC | | vendor: SoloStep - NEED MODEL NUMBERS & POWER REQUIREMENTS | 1 | 1 |
| 1600 | PMR | PTEA1 | 1 | Treatment Exercise Area | 1A304 | | 2/20/2014 | LIPA310 | LIFT, PATIENT, MOBILE | 1 | VV | | NEED MODEL NUMBERS & POWER REQUIREMENTS | 1 | |
| 1601 | PMR | PTEA1 | 1 | Treatment Exercise Area | 1A304 | | | STDO255 | STOOL, ADJUSTABLE WITHOUT BACK | 1 | VV | NO | | 1 | |
| 1602 | PMR | PTEA1 | 1 | Treatment Exercise Area | 1A304 | | 12/19/2013 | TAMT400 | TABLE, MAT, MOTORIZED | 1 | VV | | Therapeutic Industries, Barihab XS | 1 | |
| 1603 | PMR | PTEA1 | 1 | Treatment Exercise Area | 1A304 | | 12/19/2013 | TAMT410 | TABLE, MAT, MOTORIZED, HI-LOW | 1 | VV | | Patterson, Metron Plus, #2228 - NEED OVERALL DIMENSIONS | 1 | |
| 1604 | PMR | PTEA1 | 1 | Treatment Exercise Area | 1A304 | | 12/19/2013 | TATR410 | TABLE, TREATMENT, 3-SECTION HI-LOW | 1 | VV | | Patterson, Performa 300, #A370506 - NEED MODEL NUMBER AND OVERALL DIMENSIONS | 1 | |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|-----------|--------------|----------|-------------------------|--------------|---------------------|--------------------|------------------|---|--------------|--------------------------|----------------------|--|-----------|-----------------------|
| 1605 | PMR | PTEA1 | 1 | Treatment Exercise Area | 1A304 | | | TRSC401 | TRIAL SCOOTER AND POWER | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | 1 |
| 1606 | PMR | PTEA1 | 1 | Treatment Exercise Area | 1A304 | | 12/19/2013 | TRPT400 | TREADMILL, PATIENT, ANTI-GRAVITY | 1 | VV | | Alter G M320 NEED POWER & DATA REQUIREMENTS | 1 | 1 |
| 1608 | PMR | PTEA1 | 1 | Treatment Exercise Area | 1A304 | | | ULEL410 | ULTRASOUND TREATMENT TOWER, MOBILE | 2 | VV | | Patterson, Vectra Genisys tower | 2 | |
| 1609 | PMR | PTEA1 | 1 | Treatment Exercise Area | 1A304 | | | FURN202 | WORKSTATION, 2'-6" X 6'-0" FREESTANDING | 1 | VV | F | | 1 | |
| 1610 | PMR | PTEA1 | 1 | Treatment Exercise Area | 1A304 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 1 | VV | F | | | 0 |
| 1611 | PMR | PTEA1 | 1 | Treatment Exercise Area | 1A304 | | 2/20/2014 | CLWA801 | CLOCK | 2 | VV | | | 2 | |
| 1612 | PMR | PTEA1 | 1 | Treatment Exercise Area | 1A304 | | 12/19/2013 | HOPM400 | HOT THERAPY, HYDROCOLLATOR, MOBILE | 1 | VV | | | | |
| 1613 | PMR | PTEA1 | 1 | Treatment Exercise Area | 1A304 | | 12/19/2013 | COPM202 | COLD THERAPY CHILLING UNIT | 1 | VV | | NEED PRODUCT WEIGHT | | |
| 1614 | PMR | PTEA1 | 1 | Treatment Exercise Area | 1A304 | | 12/19/2013 | WEA400 | WEIGHT RACK, MOBILE | 1 | VV | | WHICH MODEL #? THERE ARE MULTIPLE LISTED ON CUT SHEET, ONE HAS ALREADY BEEN USED FOR CAWE400 - NEED PRODUCT WEIGHT | | |
| 1615 | PMR | SREO1 | 1 | Storage, General | | | | | | | | | | | |
| 1616 | PMR | SREO1 | 1 | Storage, General | 1A310 | | | SHEL300 | SHELVING, 18" DEEP, STARTER | 7 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 7 | |
| 1617 | PMR | SREO1 | 1 | Storage, General | 1A310 | | 2/20/2014 | RACR300 | RACK, CRUTCH | 2 | VC | | PRODUCT WEIGHT | 2 | |
| 1618 | PMR | SREO1 | 1 | Storage, General | 1A310 | | 2/20/2014 | RACN300 | RACK, CANE | 1 | VC | | PRODUCT WEIGHT | 1 | |
| 1619 | PMR | SREO1 | 1 | Storage, General | 1A310 | | | CRMD201 | CART, MODALITY | 1 | VV | NO | | 1 | 1 |
| 1620 | PMR | SREO1 | 1 | Storage, General | 1A310 | | | WHEE300 | WHEELCHAIR, ADULT STANDARD MANUAL | 24 | VV | NO | | 24 | 1 |
| 1621 | PMR | TLTU1 | 2 | Toilet, Patient | | | | | | | | | | | |
| 1622 | PMR | TLTU1 | 2 | Toilet, Patient | 1D319, 1D320 | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | | 2 | |
| 1623 | PMR | UTLC1 | 1 | Clean Utility Alcove | | | | | | | | | | | |
| 1624 | PMR | UTLC1 | 1 | Clean Utility Alcove | 1A311 | | | CALI303 | CART, LINEN 48" X 24" WITH VINYL COVER | 2 | VV | No | | 2 | |
| 1625 | PMR | UTLS1 | 1 | Soiled Utility Room | | | | | | | | | | | |
| 1626 | PMR | UTLS1 | 1 | Soiled Utility Room | 1A312 | | | CACS300 | CART, COLLECTION, SPD | 1 | VV | NO | | 1 | |
| 1627 | PMR | UTLS1 | 1 | Soiled Utility Room | 1A312 | | | CAUT300 | CART, UTILITY | 1 | VV | NO | | 1 | 0 |
| 1628 | PMR | UTLS1 | 1 | Soiled Utility Room | 1A312 | | | CONT300 | CONTAINER, BRUTE 32 GAL | 1 | VV | No | | 1 | 0 |
| 1629 | PMR | UTLS1 | 1 | Soiled Utility Room | 1A312 | | | CONT300A | FLAT TOP FOR BRUTE, 32 GAL | 1 | VV | - | | 1 | 0 |
| 1630 | PMR | UTLS1 | 1 | Soiled Utility Room | 1A312 | | | CONT300B | DOLLY FOR BRUTE, 32 GAL | 1 | VV | - | | 1 | 0 |
| 1631 | PMR | UTLS1 | 1 | Soiled Utility Room | 1A312 | | 2/20/2014 | COSH321 | CONTAINER, SHARPS, 2 GALLON | 1 | VC | | TWO MODELS LISTED, PLEASE CONFIRM WE ARE USING 8509SA (W/O GLOVE BOX) NEED PRODUCT WEIGHT | 1 | 1 |
| 1632 | PMR | UTLS1 | 1 | Soiled Utility Room | 1A312 | | 2/20/2014 | DIGL300 | DISPENSER, GLOVE, 3 BOX | 1 | VC | | | 1 | |
| 1633 | PMR | UTLS1 | 1 | Soiled Utility Room | 1A312 | | | CASO300 | CART, SOILED LINEN | 1 | VV | NO | | 1 | |
| 1634 | PMR | UTLS1 | 1 | Soiled Utility Room | 1A312 | | | REWB307 | RECEPTACLE, WASTE, BIOHAZARD, 44 GAL | 1 | VV | No | | 1 | |
| 1635 | PMR | UTLS1 | 1 | Soiled Utility Room | 1A312 | | | REWB307A | RECEPTACLE LID | 1 | VV | No | | 1 | |
| 1636 | PMR | | 1 | Consult Room | | | | | | | | | | | |
| 1637 | PMR | | 1 | Consult Room | 1D318 | | 2/20/2014 | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | 0 |
| 1637 | PMR | | 1 | Consult Room | 1D318 | | 2/20/2014 | COST305 | COMPUTER STATION, WALL MOUNT | 1 | VC | | WAITING ON PRODUCT SELECTION - NEED DIMENSIONS, WEIGHT, AND POWER / DATA REQUIREMENTS | 1 | |
| 1637 | PMR | | 1 | Consult Room | 1D318 | | 2/20/2014 | COST320 | MOBILE WORKSTATION, KIDNEY SHAPED TABLE | 1 | VV | | | 1 | 0 |
| 1638 | PMR | | 1 | Consult Room | 1D318 | | 1/31/2014 | PRIN300 | PRINTER, LASER | 1 | VV | | ORIGINAL CUT SHEET RECEIVED LATER DECIDED WAS INCORRECT | 1 | |
| 1639 | PMR | | 1 | Consult Room | 1D318 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 1 | 0 |
| 1640 | PMR | | 1 | Consult Room | 1D318 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 1 | VV | F | | 1 | 0 |
| 1641 | PMR | | 1 | Consult Room | 1D318 | | | FURN110 | CHAIR, NO ARMS | 2 | VV | F | | 2 | 0 |
| 1642 | PMR | | 1 | Consult Room | 1D318 | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 1 | VV | F | | 1 | |
| 1643 | PMR | | 1 | Consult Room | 1D318 | | 2/20/2014 | CLWA801 | CLOCK | 1 | VV | | | 1 | |
| 1644 | PMR | | 1 | Modality Prep. | | | | | | | | | | | |
| 1645 | PMR | | 1 | Modality Prep. | 1A307 | | | RADY201 | RACK, DRYING/HOT PACK TOWELS | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | 0 |
| 1646 | PMR | | 1 | Modality Prep. | 1A307 | | 2/20/2014 | HOPM400 | HOT PACK MACHINE | 1 | VV | | Patterson, Hydrocollator Heating Unit | 1 | |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|------------------------------|--------------|--|--------------|------------|---------------------|--------------------|------------------|---|--------------|--------------------------|----------------------|---|-----------|-----------------------|
| 1647 | PMR | | Modality Prep. | 1A307 | | 12/19/2013 | 2/20/2014 | COPM202 | COLD PACK MACHINE | 1 | VV | | Patterson, Whitehall Little Freeze, NEED PRODUCT WEIGHT | 1 | 0 |
| 1648 | PMR | WRCO1 | Waiting Area | | | | | | | | | | | 0 | |
| 1649 | PMR | WRCO1 | Waiting Area | 1D322 | | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 1 | 0 |
| 1650 | PMR | WRCO1 | Waiting Area | 1D322 | | 2/20/2014 | | TELE312 | TELEVISION, FLAT PANEL, 52" LCD | 1 | VC | | WE RECEIVED ONE CUT SHEET WITH TWO EQUIPMENT NUMBERS AND ONLY ONE MODEL INDICATED - ARE THEY TO BE THE SAME SIZE? | 1 | 0 |
| 1651 | PMR | WRCO1 | Waiting Area | 1D322 | | | | FURN150 | CHAIR, WAITING ROOM | 20 | VV | F | | 20 | 1 |
| 1652 | PMR | WRCO1 | Waiting Area | 1D322 | | | | FURN142 | CHAIR, BARIATRIC | 1 | VV | F | | 1 | |
| 1653 | PMR | WRCO1 | Waiting Area | 1D322 | | | | FURN400 | SIDE TABLE | 4 | VV | F | | 4 | |
| 1654 | PMR | | Group | | | | | | | | | | | | |
| 1655 | PMR | | Group | 1D321 | | 2/20/2014 | 3/10/2014 | BOSM300 | BOARD, SMART, INTERACTIVE | 1 | CC | | VA HAS SUPPLIED CUT SHEETS - IS THIS CONTRACTOR ACQUIRED / CONTRACTOR INSTALLED AS INDICATED? | 1 | |
| 1656 | PMR | | Group | 1D321 | | | | CACC300 | CAMERA, PORTABLE, CCTV WITH RECORDER, CEILING MOUNT | 1 | VV | | **NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN** | 1 | 0 |
| 1657 | PMR | | Group | 1D321 | | | | REWA320 | RECEPTACLE, WASTE, OFFICE, 28 QT, PUBLIC ZONE | 1 | VV | No | | 1 | 0 |
| 1658 | PMR | | Group | 1D321 | | 3/7/2014 | | PRLC300 | PROJECTOR, LCD, DIGITAL | 1 | VV | | | 1 | |
| 1658 | PMR | | Group | 1D321 | | 2/20/2014 | | SCPR300 | SCREEN, PROJECTOR | 1 | VV | | CEILING OR WALL MOUNTED? NEED POWER REQUIREMENTS | 1 | |
| 1658 | PMR | | Group | 1D321 | | 2/20/2014 | | TELE312 | TELEVISION, FLAT PANEL, 52" LCD | 1 | VC | | WE RECEIVED ONE CUT SHEET WITH TWO EQUIPMENT NUMBERS AND ONLY ONE MODEL INDICATED - ARE THEY TO BE THE SAME SIZE? | 1 | 0 |
| 1659 | PMR | | Group | 1D321 | | | | FURN350 | TABLE, CONFERENCE, 12 PERSON | 1 | VV | F | | 1 | 0 |
| 1660 | PMR | | Group | 1D321 | | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 12 | VV | F | | 12 | 1 |
| 1661 | PMR | | Group | 1D321 | | | | FURN170 | CHAIR, LOUNGE | 2 | VV | F | | 2 | |
| 1662 | PMR | | Group | 1D321 | | | | FURN400 | SIDE TABLE | 1 | VV | F | | 1 | |
| 1663 | PMR | | Group | 1D321 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | |
| 1664 | Prosthetics and Sensory Aids | | | | | | | | | | | | | 0 | |
| 1665 | Prosthetics and Sensory Aids | OFAO2 | Shared Office, Dispensing Prosthetic Clerk and Secretary | | | | | | | | | | | 0 | |
| 1666 | Prosthetics and Sensory Aids | OFAO2 | Shared Office, Dispensing Prosthetic Clerk and Secretary | 1A356 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 2 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 2 | 0 |
| 1667 | Prosthetics and Sensory Aids | OFAO2 | Shared Office, Dispensing Prosthetic Clerk and Secretary | 1A356 | | 1/31/2014 | | PRIN300 | PRINTER, LASER | 1 | VV | | ORIGINAL CUT SHEET RECEIVED LATER DECIDED WAS INCORRECT | 1 | 0 |
| 1668 | Prosthetics and Sensory Aids | OFAO2 | Shared Office, Dispensing Prosthetic Clerk and Secretary | 1A356 | | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 1 | 0 |
| 1669 | Prosthetics and Sensory Aids | OFAO2 | Shared Office, Dispensing Prosthetic Clerk and Secretary | 1A356 | | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 2 | VV | F | | 2 | 1 |
| 1670 | Prosthetics and Sensory Aids | OFAO2 | Shared Office, Dispensing Prosthetic Clerk and Secretary | 1A356 | | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 2 | VV | F | | 2 | |
| 1671 | Prosthetics and Sensory Aids | OFAO2 | Shared Office, Dispensing Prosthetic Clerk and Secretary | 1A356 | | | | FURN500 | CABINET, FILE, LOCKABLE | 2 | VV | F | | 2 | |
| 1672 | Prosthetics and Sensory Aids | OFAO2 | Shared Office, Dispensing Prosthetic Clerk and Secretary | 1A356 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | |
| 1673 | Prosthetics and Sensory Aids | OFAO2 | Office, Chief | | | | | | | | | | | | |
| 1674 | Prosthetics and Sensory Aids | OFAO2 | Office, Chief | 1A358 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | |
| 1675 | Prosthetics and Sensory Aids | OFAO2 | Office, Chief | 1A358 | | 1/31/2014 | | PRIN300 | PRINTER, LASER | 1 | VV | | ORIGINAL CUT SHEET RECEIVED LATER DECIDED WAS INCORRECT | 1 | 0 |
| 1676 | Prosthetics and Sensory Aids | OFAO2 | Office, Chief | 1A358 | | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 1 | 1 |
| 1677 | Prosthetics and Sensory Aids | OFAO2 | Office, Chief | 1A358 | | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 1 | VV | F | | 1 | |
| 1678 | Prosthetics and Sensory Aids | OFAO2 | Office, Chief | 1A358 | | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 1 | VV | F | | 1 | |
| 1679 | Prosthetics and Sensory Aids | OFAO2 | Office, Chief | 1A358 | | | | FURN110 | CHAIR, NO ARMS | 2 | VV | F | | 2 | |
| 1680 | Prosthetics and Sensory Aids | OFAO2 | Office, Chief | 1A358 | | | | FURN530 | BOOKCASE, 15" X 36" | 1 | VV | F | | 1 | 1 |
| 1681 | Prosthetics and Sensory Aids | OFAO2 | Office, Chief | 1A358 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | |
| 1682 | Prosthetics and Sensory Aids | | Treatment Room | | | | | | | | | | | | |
| 1683 | Prosthetics and Sensory Aids | | Treatment Room | 1A355 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|------------------------------|--------------|--------------------------------|----------------------------|------------|---------------------|--------------------|------------------|---|--------------|--------------------------|----------------------|---|-----------|-----------------------|
| 1684 | Prosthetics and Sensory Aids | 1 | Treatment Room | 1A355 | | 2/20/2014 | | COST300 | COMPUTER STATION, WALL MOUNT | 1 | VC | | WAITING ON PRODUCT SELECTION - NEED DIMENSIONS, WEIGHT, AND POWER / DATA REQUIREMENTS | 1 | |
| 1685 | Prosthetics and Sensory Aids | 1 | Treatment Room | 1A355 | | | | STD0255 | STOOL, ADJUSTABLE WITHOUT BACK | 1 | VV | NO | | 1 | |
| 1686 | Prosthetics and Sensory Aids | 1 | Treatment Room | 1A355 | | 12/19/2013 | | TATE400 | TABLE, TREATMENT | 1 | VV | | NEED OVERALL DIMENSIONS | 1 | |
| 1687 | Prosthetics and Sensory Aids | 1 | Treatment Room | 1A355 | | | | FURN240 | WORKSTATION, 2'-0" X 4'-0" | 1 | VV | F | | 1 | 0 |
| 1688 | Prosthetics and Sensory Aids | 1 | Treatment Room | 1A355 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | 0 |
| 1689 | Prosthetics and Sensory Aids | SRCS1 | Mailing Area | | | | | | | | | | | 1 | |
| 1690 | Prosthetics and Sensory Aids | SRCS1 | Mailing Area | 1A353 | | | | PASH401 | PAPER, SHIPPING, ROLE | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 1691 | Prosthetics and Sensory Aids | SRCS1 | Mailing Area | 1A353 | | | | STD0350 | STOOL, DR. WITHOUT ARMS, ADJUSTABLE | 1 | VV | No | | 1 | |
| 1692 | Prosthetics and Sensory Aids | SRCS1 | Mailing Area | 1A353 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | 0 |
| 1693 | Prosthetics and Sensory Aids | SRCS1 | Storage Area | | | | | | | | | | | | |
| 1694 | Prosthetics and Sensory Aids | SRCS1 | Storage Area | 1A352 | | | | SHEL310 | SHELVING, 18" DEEP, MOBILE | 9 | VC | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 9 | |
| 1695 | Prosthetics and Sensory Aids | SRCS1 | Wheelchair Storage Area | | | | | | | | | | | | |
| 1696 | Prosthetics and Sensory Aids | SRCS1 | Wheelchair Storage Area | 1A357 | | | | STD0350 | STOOL, DR. WITHOUT ARMS, ADJUSTABLE | 1 | VV | No | | 1 | |
| 1697 | Prosthetics and Sensory Aids | SRCS1 | Wheelchair Storage Area | 1A357 | | | | WHEE300 | WHEELCHAIR, ADULT STANDARD MANUAL | 20 | VV | NO | | 20 | |
| 1698 | Prosthetics and Sensory Aids | SRCS1 | Wheelchair Storage Area | 1A357 | | | | WHLT310 | WHEELCHAIR LIFT | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 1699 | Prosthetics and Sensory Aids | SRCS1 | Wheelchair Storage Area | 1A357 | | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 1 | VV | F | | 1 | 0 |
| 1700 | Prosthetics and Sensory Aids | SRCS1 | Wheelchair Storage Area | 1A357 | | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 1 | VV | F | | 1 | 0 |
| 1701 | Prosthetics and Sensory Aids | SRCS1 | Wheelchair Storage Area | 1A357 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | 0 |
| 1702 | Prosthetics and Sensory Aids | 1 | Reception | | | | | | | | | | | 0 | |
| 1703 | Prosthetics and Sensory Aids | 1 | Reception | 1D351 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | 0 |
| 1704 | Prosthetics and Sensory Aids | 1 | Reception | 1D351 | | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 1 | VV | F | | 1 | 1 |
| 1705 | Radiology | | | | | | | | | | | | | | |
| 1706 | Radiology | DROO1 | Dressing Room | | | | | | | | | | (PREVIOUSLY 3 ROOMS) | | |
| 1707 | Radiology | DROO1 | Dressing Room | 1C403, 1C407, 1C409, 1C411 | | | | HAMP301 | HAMPER, WITH LID, 32" | 1 | VV | No | | 3 | 0 |
| 1708 | Radiology | OFDR1 | Office, Staff Radiologist | | | | | | | | | | | | |
| 1709 | Radiology | OFDR1 | Office, Staff Radiologist | 1C417 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | |
| 1710 | Radiology | OFDR1 | Office, Staff Radiologist | 1C417 | | 1/31/2014 | | PRIN300 | PRINTER, LASER | 1 | VV | | ORIGINAL CUT SHEET RECEIVED LATER DECIDED WAS INCORRECT | 1 | |
| 1711 | Radiology | OFDR1 | Office, Staff Radiologist | 1C417 | | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 1 | 0 |
| 1712 | Radiology | OFDR1 | Office, Staff Radiologist | 1C417 | | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 1 | VV | F | | 1 | |
| 1713 | Radiology | OFDR1 | Office, Staff Radiologist | 1C417 | | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 2 | VV | F | | 2 | |
| 1714 | Radiology | OFDR1 | Office, Staff Radiologist | 1C417 | | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 2 | VV | F | | 1 | |
| 1715 | Radiology | OFDR1 | Office, Staff Radiologist | 1C417 | | | | FURN522 | CABINET, STORAGE, 1'-6" x 3'-0" x 2'-5" | 2 | VV | F | | 1 | 1 |
| 1716 | Radiology | OFDR1 | Office, Staff Radiologist | 1C417 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 1 | 1 |
| 1717 | Radiology | OFDR1 | Office, Tech Work | | | | | | | | | | | | |
| 1718 | Radiology | OFDR1 | Office, Tech Work | 1C408 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 2 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 2 | |
| 1719 | Radiology | OFDR1 | Office, Tech Work | 1C408 | | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 2 | VV | F | | | |
| 1720 | Radiology | OFDR1 | Office, Tech Work | 1C408 | | | | WOPA400 | WORKSTATION, PACS, DUAL MONITOR | 2 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 2 | |
| 1721 | Radiology | 1 | Office, Ultra Tech Work | | | | | | | | | | | | |
| 1722 | Radiology | 1 | Office, Ultra Tech Work | 1C402 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 3 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 3 | |
| 1723 | Radiology | 1 | Office, Ultra Tech Work | 1C402 | | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 2 | VV | F | | | |
| 1724 | Radiology | 1 | Office, Ultra Tech Work | 1C402 | | | | WOPA400 | WORKSTATION, PACS, DUAL MONITOR | 2 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 2 | |
| 1725 | Radiology | XDR01 | General Purpose Radiology Room | | | | | | | | | | | | |
| 1726 | Radiology | XDR01 | General Purpose Radiology Room | 1C406, 1C410 | F3200 | | | CLAT800 | CLOCK, ATOMIC | 1 | VV | | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 2 | |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|-----------------------|--------------|----------|--------------------------------|--------------|---------------------|--------------------|------------------|-----------|-------------------------------------|--------------------------|----------------------|---|-----------|-----------------------|
| 1727 | Radiology | XDR01 | 2 | General Purpose Radiology Room | 1C406, 1C410 | | 2/20/2014 | | COSH321 | CONTAINER, SHARPS, 2 GALLON | 1 | VV | TWO MODELS LISTED, PLEASE CONFIRM WE ARE USING 8509SA (W/O GLOVE BOX) NEED PRODUCT WEIGHT | 2 | |
| 1728 | Radiology | XDR01 | 2 | General Purpose Radiology Room | 1C406, 1C410 | | 2/20/2014 | | DIGL300 | DISPENSER, GLOVE, 3 BOX | 1 | VV | | 2 | 0 |
| 1729 | Radiology | XDR01 | 2 | General Purpose Radiology Room | 1C406, 1C410 | X5900 | 2/20/2014 | 3/10/2014 | RAGP300 | RADIOGRAPHIC UNIT, 80kW, TILT TABLE | 1 | VC | WAITING FOR FINALIZED POWER REQUIREMENTS | 2 | |
| 1737 | Radiology | XDR01 | 2 | General Purpose Radiology Room | 1C406, 1C410 | | | | SHRA400 | SHEILDING, RADIATION | 1 | CC | | 2 | 0 |
| 1738 | Radiology | XDR01 | 2 | General Purpose Radiology Room | 1C406, 1C410 | | | | WILE400 | WINDOW, VIEWING LEAD GLASS | 1 | CC | On window schedule | 2 | |
| 1739 | Radiology | XDR01 | 2 | General Purpose Radiology Room | 1C406, 1C410 | | | | WAXR400 | WARNING LIGHT, X-RAY | 1 | CC | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 2 | |
| 1740 | Radiology | XDR01 | 2 | General Purpose Radiology Room | 1C406, 1C410 | | | | REWA303 | RECEPTACLE, WASTE, 23 GAL, SLIM JIM | 1 | VV | NO | 2 | |
| 1741 | Radiology | XDR01 | 2 | General Purpose Radiology Room | 1C406, 1C410 | | | | STDO350 | STOOL, DR. WITHOUT ARMS, ADJUSTABLE | 1 | VV | No | 2 | |
| 1742 | Radiology | | 2 | Ultrasound | 1C404, 1C413 | | | | | | | | Room 1C404 & 1C413 | | |
| 1743 | Radiology | | 2 | Ultrasound | 1C404, 1C413 | | | | CASU313 | CART, SUPPLY 48X24 | 1 | VV | NO | 1 | |
| 1744 | Radiology | | 2 | Ultrasound | 1C404, 1C413 | F3200 | | | CLAT800 | CLOCK, ATOMIC | 1 | VV | "NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN" | 1 | |
| 1745 | Radiology | | 2 | Ultrasound | 1C404, 1C413 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | |
| 1746 | Radiology | | 2 | Ultrasound | 1C404, 1C413 | | 2/20/2014 | | COSH321 | CONTAINER, SHARPS, 2 GALLON | 1 | VV | TWO MODELS LISTED, PLEASE CONFIRM WE ARE USING 8509SA (W/O GLOVE BOX) NEED PRODUCT WEIGHT | 1 | |
| 1747 | Radiology | | 2 | Ultrasound | 1C404, 1C413 | | 2/20/2014 | | DIGL300 | DISPENSER, GLOVE, 3 BOX | 1 | VV | | 1 | |
| 1748 | Radiology | | 2 | Ultrasound | 1C404, 1C413 | | 1/31/2014 | | PRIN300 | PRINTER, LASER | 1 | VV | ORIGINAL CUT SHEET RECEIVED LATER DECIDED WAS INCORRECT | 1 | |
| 1749 | Radiology | | 2 | Ultrasound | 1C404, 1C413 | | | | REWA303 | RECEPTACLE, WASTE, 23 GAL, SLIM JIM | 1 | VV | NO | 1 | |
| 1750 | Radiology | | 2 | Ultrasound | 1C404, 1C413 | | | | SPHY306 | SPHYGMOMANOMETER, HAND HELD | 1 | VV | (SEE EQRA300 FOR MOUNTING) | 1 | 0 |
| 1751 | Radiology | | 2 | Ultrasound | 1C404, 1C413 | | | | STDO350 | STOOL, DR. WITHOUT ARMS, ADJUSTABLE | 1 | VV | No | 1 | 0 |
| 1752 | Radiology | | 2 | Ultrasound | 1C404, 1C413 | | 2/20/2014 | | STPR300 | STRETCHER, PROCEDURAL | 1 | VV | WHICH TMM4 MODEL? | 1 | |
| 1753 | Radiology | | 2 | Ultrasound | 1C404, 1C413 | | 2/20/2014 | | ULTR304 | SCANNER, ULTRASOUND, MOBILE | 1 | VV | | 1 | |
| 1761 | Radiology | | 2 | Ultrasound | 1C404, 1C413 | | | | ALSE400 | ALARM BUTTON, SECURITY/DURESS | 1 | CC | NO | 1 | 0 |
| 1762 | Radiology | | 2 | Ultrasound | 1C404, 1C413 | | | | FURN240 | WORKSTATION, 2'-0" X 4'-0" | 1 | VV | F | 1 | |
| 1763 | Radiology | | 2 | Ultrasound | 1C404, 1C413 | | | | FURN110 | CHAIR, NO ARMS | 1 | VV | F | 1 | 0 |
| 1764 | Radiology | XDM01 | 1 | Future Mammography | | | | | | | | | Room 1C404 - NOW SECOND ULTRASOUND | | |
| 1765 | Radiology | UTLC1 | 1 | Alcove, Clean Utility | | | | | | | | | | | 0 |
| 1766 | Radiology | UTLC1 | 1 | Alcove, Clean Utility | 1C414 | | | | CASU313 | CART, SUPPLY 48X24 | 1 | VV | NO | 1 | 0 |
| 1767 | Radiology | UTLS1 | 1 | Alcove, Soiled Utility | | | | | | | | | | | 0 |
| 1768 | Radiology | UTLS1 | 1 | Alcove, Soiled Utility | 1C415 | | | | CASO300 | CART, SOILED LINEN | 1 | VV | NO | 1 | |
| 1769 | Radiology | TLTU1 | 2 | Toilet, Patient Ultrasound | | | | | | | | | (PREVIOUSLY I CHANGED STAFF RESTROOM TO FUTURE MAMMOGRAPHY PATIENT RESTROOM) | | |
| 1770 | Radiology | TLTU1 | 2 | Toilet, Patient Ultrasound | 1C416, 1F401 | | | | HAMP301 | HAMPER, WITH LID, 32" | 1 | VV | No | 1 | 0 |
| 1771 | Radiology | TLTU1 | 2 | Toilet, Patient Ultrasound | 1C416, 1F401 | | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | 1 | 0 |
| 1772 | Radiology | TLTU1 | 1 | Toilet, Staff | | | | | | | | | NO STAFF TOILET | | 1 |
| 1773 | Radiology | TLTU1 | 1 | Toilet, Staff | | | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | 1 | |
| 1774 | Radiology | WRCO1 | 1 | Waiting Area | | | | | | | | | | | 0 |
| 1775 | Radiology | WRCO1 | 1 | Waiting Area | 1F418 | | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 3 | VV | No | 3 | 0 |
| 1776 | Radiology | WRCO1 | 1 | Waiting Area | 1F418 | | 2/20/2014 | | TELE312 | TELEVISION, FLAT PANEL, 52" LCD | 1 | VC | WE RECEIVED ONE CUT SHEET WITH TWO EQUIPMENT NUMBERS AND ONLY ONE MODEL INDICATED - ARE THEY TO BE THE SAME SIZE? | 1 | |
| 1777 | Radiology | WRCO1 | 1 | Waiting Area | 1F418 | | | | FURN150 | CHAIR, WAITING ROOM | 37 | VV | F | 37 | |
| 1778 | Radiology | WRCO1 | 1 | Waiting Area | 1F418 | | | | FURN142 | CHAIR, BARIATRIC | 4 | VV | F | 4 | |
| 1779 | Radiology | WRCO1 | 1 | Waiting Area | 1F418 | | | | FURN400 | SIDE TABLE | 9 | VV | F | 9 | |
| 1780 | Radiology | | 1 | Reception | | | | | | | | | | | 0 |
| 1781 | Radiology | | 1 | Reception | 1F400 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 2 | VV | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 2 | 0 |
| 1782 | Radiology | | 1 | Reception | 1F400 | | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 2 | VV | No | 2 | 0 |
| 1783 | Radiology | | 1 | Reception | 1F400 | | | | FURN110 | CHAIR, NO ARMS | 2 | VV | F | 2 | 0 |
| 1784 | Radiology | | 1 | Reception | 1F400 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | 1 | 0 |
| 1788 | Service Organizations | | | | | | | | | | | | | | |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|---|--------------|----------|---|--|---------------------|--------------------|------------------|-------------------------------------|--------------|--------------------------|----------------------|---|-----------|-----------------------|
| 1789 | Service Organizations | OFA01 | 2 | Office, Service Organization Representative | | | | | | | | | | 0 | |
| 1790 | Service Organizations | OFA01 | 2 | Office, Service Organization Representative | 1G751, 1G752 | | 2/20/2014 | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 2 | 0 |
| 1791 | Service Organizations | OFA01 | 2 | Office, Service Organization Representative | 1G751, 1G752 | | 1/31/2014 | PRIN300 | PRINTER, LASER | 1 | VV | | ORIGINAL CUT SHEET RECEIVED LATER DECIDED WAS INCORRECT | 2 | 0 |
| 1792 | Service Organizations | OFA01 | 2 | Office, Service Organization Representative | 1G751, 1G752 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 2 | 0 |
| 1793 | Service Organizations | OFA01 | 2 | Office, Service Organization Representative | 1G751, 1G752 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 1 | VV | F | | 2 | 0 |
| 1794 | Service Organizations | OFA01 | 2 | Office, Service Organization Representative | 1G751, 1G752 | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 1 | VV | F | | 2 | 1 |
| 1795 | Service Organizations | OFA01 | 2 | Office, Service Organization Representative | 1G751, 1G752 | | | FURN110 | CHAIR, NO ARMS | 2 | VV | F | | 4 | |
| 1796 | Service Organizations | OFA01 | 2 | Office, Service Organization Representative | 1G751, 1G752 | | | FURN520 | DRAWER, FILE, 15" X 36" | 1 | VV | F | | 2 | |
| 1797 | Service Organizations | OFA01 | 2 | Office, Service Organization Representative | 1G751, 1G752 | | 2/20/2014 | CLWA801 | CLOCK | 1 | VV | | | 2 | |
| 1798 | Service Organizations | OFA01 | 1 | DoD Patient Advocate Office | | | | | | | | | | | |
| 1799 | Service Organizations | OFA01 | 1 | DoD Patient Advocate Office | 1G750 | | 2/20/2014 | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | |
| 1800 | Service Organizations | OFA01 | 1 | DoD Patient Advocate Office | 1G750 | | 1/31/2014 | PRIN300 | PRINTER, LASER | 1 | VV | | ORIGINAL CUT SHEET RECEIVED LATER DECIDED WAS INCORRECT | 1 | 0 |
| 1801 | Service Organizations | OFA01 | 1 | DoD Patient Advocate Office | 1G750 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 1 | 0 |
| 1802 | Service Organizations | OFA01 | 1 | DoD Patient Advocate Office | 1G750 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 1 | VV | F | | 1 | 0 |
| 1803 | Service Organizations | OFA01 | 1 | DoD Patient Advocate Office | 1G750 | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 1 | VV | F | | 1 | 0 |
| 1804 | Service Organizations | OFA01 | 1 | DoD Patient Advocate Office | 1G750 | | | FURN110 | CHAIR, NO ARMS | 2 | VV | F | | 2 | 0 |
| 1805 | Service Organizations | OFA01 | 1 | DoD Patient Advocate Office | 1G750 | | | FURN520 | DRAWER, FILE, 15" X 36" | 1 | VV | F | | 1 | 1 |
| 1806 | Service Organizations | OFA01 | 1 | DoD Patient Advocate Office | 1G750 | | 2/20/2014 | CLWA801 | CLOCK | 1 | VV | | | 1 | |
| 1807 | Supply, Processing and Distribution (SPD) | | | | | | | | | | | | | | |
| 1808 | Volunteer Service | | | | | | | | | | | | | 0 | |
| 1809 | Volunteers | OFA01 | 1 | Office, Voluntary Service | | | | | | | | | | 0 | |
| 1810 | Volunteers | OFA01 | 1 | Office, Voluntary Service | 1B704 | | 2/20/2014 | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | |
| 1811 | Volunteers | OFA01 | 1 | Office, Voluntary Service | 1B704 | | 1/31/2014 | PRIN300 | PRINTER, LASER | 1 | VV | | ORIGINAL CUT SHEET RECEIVED LATER DECIDED WAS INCORRECT | 1 | |
| 1812 | Volunteers | OFA01 | 1 | Office, Voluntary Service | 1B704 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 1 | 0 |
| 1813 | Volunteers | OFA01 | 1 | Office, Voluntary Service | 1B704 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 1 | VV | F | | 1 | |
| 1814 | Volunteers | OFA01 | 1 | Office, Voluntary Service | 1B704 | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 1 | VV | F | | 1 | |
| 1815 | Volunteers | OFA01 | 1 | Office, Voluntary Service | 1B704 | | | FURN110 | CHAIR, NO ARMS | 2 | VV | F | | 2 | 1 |
| 1816 | Volunteers | OFA01 | 1 | Office, Voluntary Service | 1B704 | | | FURN530 | BOOKCASE, 15" X 36" | 1 | VV | F | | 1 | 1 |
| 1817 | Volunteers | OFA01 | 1 | Office, Voluntary Service | 1B704 | | 2/20/2014 | CLWA801 | CLOCK | 1 | VV | | | 1 | 0 |
| 1818 | Volunteers | OFA03 | 1 | Volunteer Sign-in Area | | | | | | | | | | | |
| 1819 | Volunteers | OFA03 | 1 | Volunteer Sign-in Area | 1B701 | | 2/20/2014 | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | |
| 1820 | Volunteers | OFA03 | 1 | Volunteer Sign-in Area | 1B701 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 1 | VV | F | | 1 | |
| 1821 | Volunteers | OFA03 | 1 | Volunteer Sign-in Area | 1B701 | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 1 | VV | F | | 1 | 0 |
| 1822 | Women's Health | | | | | | | | | | | | | | |
| 1823 | Women's Health | EXRG3 | 10 | Exam Room | | | | | | | | | | | |
| 1824 | Women's Health | EXRG3 | 10 | Exam Room | 3A701, 3B700, 3A703, 3B702, 3A705, 3B704, 3A711, 3B710, 3A713, 3A715 | | 2/20/2014 | CASP306 | CART, SPECIALTY | 1 | VV | | CUT SHEET IS FROM 2001, IS THE INFORMATION STILL ACCURATE? | 10 | |
| 1825 | Women's Health | EXRG3 | 10 | Exam Room | 3A701, 3B700, 3A703, 3B702, 3A705, 3B704, 3A711, 3B710, 3A713, 3A715 | | 2/20/2014 | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 10 | |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| | EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/ Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|------|--|-----------|--------------|-----------------|--|------------|---------------------|--------------------|------------------|---|--------------|---------------------------|----------------------|---|-----------|-----------------------|
| 1826 | Women's Health | EXRG3 | 10 | Exam Room | 3A701, 3B700, 3A703, 3B702, 3A705, 3B704, 3A711, 3B710, 3A713, 3A715 | | 2/20/2014 | | COST300 | COMPUTER STATION, WALL MOUNT | 1 | VC | | WAITING ON PRODUCT SELECTION - NEED DIMENSIONS, WEIGHT, AND POWER / DATA REQUIREMENTS | 10 | 0 |
| 1827 | Women's Health | EXRG3 | 10 | Exam Room | 3A701, 3B700, 3A703, 3B702, 3A705, 3B704, 3A711, 3B710, 3A713, 3A715 | | 2/20/2014 | | COSH321 | CONTAINER, SHARPS, 2 GALLON | 1 | VC | | TWO MODELS LISTED, PLEASE CONFIRM WE ARE USING 8509SA (W/O GLOVE BOX) NEED PRODUCT WEIGHT | 10 | 1 |
| 1828 | Women's Health | EXRG3 | 10 | Exam Room | 3A701, 3B700, 3A703, 3B702, 3A705, 3B704, 3A711, 3B710, 3A713, 3A715 | | 2/20/2014 | | DIGL300 | DISPENSER, GLOVE, 3 BOX | 1 | VC | | | 10 | |
| 1829 | Women's Health | EXRG3 | 10 | Exam Room | 3A701, 3B700, 3A703, 3B702, 3A705, 3B704, 3A711, 3B710, 3A713, 3A715 | | 2/20/2014 | | MOBP302 | MONITOR WITH STAND, BLOOD PRESSURE | 2 | VV | | NEED DIMENSIONS, WEIGHT, POWER REQUIREMENTS | 20 | 1 |
| 1830 | Women's Health | EXRG3 | 10 | Exam Room | 3A701, 3B700, 3A703, 3B702, 3A705, 3B704, 3A711, 3B710, 3A713, 3A715 | | 2/20/2014 | | MOBP305 | MONITOR, BLOOD PRESSURE, WALL MOUNTED | 1 | VV | | NEED DIMENSIONS, WEIGHT, POWER REQUIREMENTS | 10 | 0 |
| 1831 | Women's Health | EXRG3 | 10 | Exam Room | 3A701, 3B700, 3A703, 3B702, 3A705, 3B704, 3A711, 3B710, 3A713, 3A715 | | 1/31/2014 | | OTOP300 | OPHTHALMOSCOPE/OTOSCOPE, WALL BOARD | 1 | VC | | WHICH MODEL NUMBER AND ACCESSORY MODULES? (SEE EQRA300 FOR MOUNTING) | 10 | |
| 1832 | Women's Health | EXRG3 | 10 | Exam Room | 3A701, 3B700, 3A703, 3B702, 3A705, 3B704, 3A711, 3B710, 3A713, 3A715 | | 1/31/2014 | | PRIN300 | PRINTER, LASER | 1 | VV | | ORIGINAL CUT SHEET RECEIVED LATER DECIDED WAS INCORRECT | 10 | |
| 1833 | Women's Health | EXRG3 | 10 | Exam Room | 3A701, 3B700, 3A703, 3B702, 3A705, 3B704, 3A711, 3B710, 3A713, 3A715 | | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | | 10 | 1 |
| 1834 | Women's Health | EXRG3 | 10 | Exam Room | 3A701, 3B700, 3A703, 3B702, 3A705, 3B704, 3A711, 3B710, 3A713, 3A715 | | | | SPHY306 | SPHYGMOMANOMETER, HAND HELD | 1 | VV | | (SEE EQRA300 FOR MOUNTING) | 10 | 1 |
| 1835 | Women's Health | EXRG3 | 10 | Exam Room | 3A701, 3B700, 3A703, 3B702, 3A705, 3B704, 3A711, 3B710, 3A713, 3A715 | | | | STDO350 | STOOL, DR. WITHOUT ARMS, ADJUSTABLE | 1 | VV | No | | 10 | |
| 1836 | Women's Health | EXRG3 | 10 | Exam Room | 3A701, 3B700, 3A703, 3B702, 3A705, 3B704, 3A711, 3B710, 3A713, 3A715 | | 2/20/2014 | | TAEX302 | TABLE, EXAM, POWER | 1 | VV | | | 10 | |
| 1837 | Women's Health | EXRG3 | 10 | Exam Room | 3A701, 3B700, 3A703, 3B702, 3A705, 3B704, 3A711, 3B710, 3A713, 3A715 | | | | SCBA500 | SCALE, BABY | 1 | VV | | **NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN** COUNTERTOP | 10 | |
| 1838 | Women's Health | EXRG3 | 10 | Exam Room | 3A701, 3B700, 3A703, 3B702, 3A705, 3B704, 3A711, 3B710, 3A713, 3A715 | | | | FURN140 | CHAIR, BARIATRIC | 1 | VV | F | | 10 | |
| 1838 | Women's Health | EXRG3 | 10 | Exam Room | 3A701, 3B700, 3A703, 3B702, 3A705, 3B704, 3A711, 3B710, 3A713, 3A715 | | | | MOVI300 | V-TEL SYSTEM - SMART TV / MONITOR WITH CISCO SYSTEM | 1 | VV | | | 10 | |
| 1839 | Women's Health | EXRG3 | 10 | Exam Room | 3A701, 3B700, 3A703, 3B702, 3A705, 3B704, 3A711, 3B710, 3A713, 3A715 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | | 10 | |
| 1840 | Women's Health | TLTU1 | 2 | Toilet, Public | | | | | | | | | | | | 0 |
| 1841 | Women's Health | TLTU1 | 2 | Toilet, Public | 3D151, 3D152 | | 2/20/2014 | | BACH300 | BABY CHANGING STATION | 1 | VV | | REFER TO SCHEDULE B | 2 | |
| 1842 | Women's Health | TLTU1 | 2 | Toilet, Public | 3D151, 3D152 | | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | | 2 | |
| 1843 | Women's Health | MEDP1 | 1 | Medication Room | | | | | | | | | | Room 3A209 | | 1 |
| 1844 | Women's Health | MEDP1 | 1 | Medication Room | 3A209 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | 1 |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|----------------|--------------|----------|------------------|--------------|---------------------|--------------------|------------------|---|--|--------------------------|----------------------|---|-----------|-----------------------|
| 1845 | Women's Health | MEDP1 | 1 | Medication Room | 3A209 | | 2/20/2014 | | COSH321 | CONTAINER, SHARPS, 2 GALLON | 1 | VC | TWO MODELS LISTED, PLEASE CONFIRM WE ARE USING 8509SA (W/O GLOVE BOX) NEED PRODUCT WEIGHT | 1 | |
| 1846 | Women's Health | MEDP1 | 1 | Medication Room | 3A209 | | 2/20/2014 | | DIGL300 | DISPENSER, GLOVE, 3 BOX | 1 | VC | | 1 | |
| 1847 | Women's Health | MEDP1 | 1 | Medication Room | 3A209 | | 1/31/2014 | | MEST330 | MEDICATION, STATION | 1 | VC | WHAT IS THE MODEL NUMBER FOR THE SECOND PIECE OF EQUIPMENT AS INDICATED? | 1 | 0 |
| 1848 | Women's Health | MEDP1 | 1 | Medication Room | 3A209 | | | MEST330A | SEISMIC BRACKET FOR ACUDOSE RX | 1 | VC | - | | 1 | 0 |
| 1849 | Women's Health | MEDP1 | 1 | Medication Room | 3A209 | | 1/31/2014 | | PRIN300 | PRINTER, LASER | 1 | VV | ORIGINAL CUT SHEET RECEIVED LATER DECIDED WAS INCORRECT | 1 | 0 |
| 1850 | Women's Health | MEDP1 | 1 | Medication Room | 3A209 | | 1/31/2014 | | REUC325 | REFRIGERATOR, FREEZER, UNDERCOUNTER, ADA | 1 | VV | | 1 | |
| 1851 | Women's Health | MEDP1 | 1 | Medication Room | 3A209 | | | REUC325A | TEMPERATURE ALARM WITH PROBE | 1 | VV | - | | 1 | |
| 1852 | Women's Health | MEDP1 | 1 | Medication Room | 3A209 | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | | 1 | |
| 1853 | Women's Health | MEDP1 | 1 | Medication Room | 3A209 | | 1/31/2014 | | SYME301 | OMNIRX TWO CELL / SUPPLIER | 1 | VV | NEED MODEL NUMBER | 1 | 0 |
| 1854 | Women's Health | MEDP1 | 1 | Medication Room | 3A209 | | | SYME301A | INSTALLATION, SEISMIC RESTRAINT | 1 | VV | - | | 1 | |
| 1855 | Women's Health | MEDP1 | 1 | Medication Room | 3A209 | | 2/20/2014 | | WAPH300 | WASTE, PHARMACEUTICAL, 2 GAL | 1 | VV | NEED DIMENSIONS & WEIGHT | 1 | 0 |
| 1856 | Women's Health | MEDP1 | 1 | Medication Room | 3A209 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | 1 | 0 |
| 1857 | Women's Health | NSTA4 | 1 | Team Work Area | | | | | | | | | | | 0 |
| 1858 | Women's Health | NSTA4 | 1 | Team Work Area | 3A310 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 6 | VV | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 6 | 0 |
| 1859 | Women's Health | NSTA4 | 1 | Team Work Area | 3A310 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 10 | VV | F | | 6 | 1 |
| 1860 | Women's Health | NSTA4 | 1 | Team Work Area | 3A310 | | | FURN312 | TABLE, ROUND, 4 PERSON | 1 | VV | F | | | |
| 1861 | Women's Health | NSTA4 | 1 | Team Work Area | 3A310 | | | FURN244 | WORKSTATION, 2'-0" X 4'-0" | 6 | VV | F | | 6 | 1 |
| 1862 | Women's Health | | 2 | Group | | | | | | | | | | | |
| 1863 | Women's Health | | 2 | Group | 3A200, 3A201 | | 2/20/2014 | 3/10/2014 | BOSM300 | BOARD, SMART, INTERACTIVE | 1 | CC | VA HAS SUPPLIED CUT SHEETS - IS THIS CONTRACTOR ACQUIRED / CONTRACTOR INSTALLED AS INDICATED? | 2 | |
| 1864 | Women's Health | | 2 | Group | 3A200, 3A201 | | | CACC300 | CAMERA, PORTABLE, CCTV WITH RECORDER, CEILING MOUNT | 1 | VV | | NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN | 2 | |
| 1865 | Women's Health | | 2 | Group | 3A200, 3A201 | | 3/7/2014 | | PRLC300 | PROJECTOR, LCD, DIGITAL | 1 | VV | | 1 | |
| 1865 | Women's Health | | 2 | Group | 3A200, 3A201 | | | REWA320 | RECEPTACLE, WASTE, OFFICE, 28 QT, PUBLIC ZONE | 1 | VV | No | | 2 | |
| 1865 | Women's Health | | 2 | Group | 3A200, 3A201 | | 2/20/2014 | | SCPR300 | SCREEN, PROJECTOR | 1 | VV | CEILING OR WALL MOUNTED? NEED POWER REQUIREMENTS | 1 | |
| 1866 | Women's Health | | 2 | Group | 3A200, 3A201 | | 2/20/2014 | | TELE312 | TELEVISION, FLAT PANEL, 52" LCD | 1 | VC | WE RECEIVED ONE CUT SHEET WITH TWO EQUIPMENT NUMBERS AND ONLY ONE MODEL INDICATED - ARE THEY TO BE THE SAME SIZE? | 2 | 0 |
| 1867 | Women's Health | | 2 | Group | 3A200, 3A201 | | | FURN350 | TABLE, CONFERENCE, 12 PERSON | 1 | VV | F | | 2 | 0 |
| 1868 | Women's Health | | 2 | Group | 3A200, 3A201 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 12 | VV | F | | 24 | 1 |
| 1869 | Women's Health | | 2 | Group | 3A200, 3A201 | | | FURN170 | CHAIR, LOUNGE | 2 | VV | F | | 4 | |
| 1870 | Women's Health | | 2 | Group | 3A200, 3A201 | | | FURN400 | SIDE TABLE | 1 | VV | F | | 2 | |
| 1871 | Women's Health | | 2 | Group | 3A200, 3A201 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | 2 | |
| 1872 | Women's Health | | 1 | Lactation Room | | | | | | | | | | | |
| 1873 | Women's Health | | 1 | Lactation Room | 3D150 | | 2/20/2014 | | BACH300 | BABY CHANGING STATION | 1 | VV | REFER TO SCHEDULE B | 1 | 0 |
| 1874 | Women's Health | | 1 | Lactation Room | 3D150 | | | CHGL300 | CHAIR, GLIDER | 2 | VV | No | | 2 | 0 |
| 1875 | Women's Health | | 1 | Lactation Room | 3D150 | | 2/20/2014 | | OVMI303 | OVEN, MICROWAVE | 1 | VV | | 1 | 0 |
| 1876 | Women's Health | | 1 | Lactation Room | 3D150 | | 1/31/2014 | 2/20/2014 | REUC315 | REFRIGERATOR, UNDERCOUNTER, ADA | 1 | VV | | 1 | 1 |
| 1877 | Women's Health | | 1 | Lactation Room | 3D150 | | 1/31/2014 | | REUC315A | TEMPERATURE ALARM WITH PROBE | 1 | VV | | 1 | |
| 1878 | Women's Health | | 1 | Lactation Room | 3D150 | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 1 | VV | No | | 1 | |
| 1879 | Women's Health | | 1 | Lactation Room | 3D150 | | | FURN434 | ROUND TABLE | 2 | VV | F | | 2 | |
| 1880 | Women's Health | | 1 | Lactation Room | 3D150 | | 2/20/2014 | | CLWA801 | CLOCK | 1 | VV | | 1 | |
| 1881 | Women's Health | SL002 | 1 | Teamlet Workroom | | | | | | | | | | | |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| | EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|------|--|-----------|--------------|--------------------|--------------|------------|---------------------|--------------------|------------------|---|--------------|--------------------------|----------------------|--|-----------|-----------------------|
| 1882 | Women's Health | SL002 | 1 | Teamlet Workroom | 3D314 | | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 24 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 8 | |
| 1882 | Women's Health | SL002 | 1 | Teamlet Workroom | 3D314 | | | | MOPT300 | MONITOR, PATIENT TRACKING | 1 | VV | | **NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN** | 1 | |
| 1883 | Women's Health | SL002 | 1 | Teamlet Workroom | 3D314 | | | | HAMP301 | HAMPER, WITH LID, 32" | 6 | VV | No | | 2 | |
| 1884 | Women's Health | SL002 | 1 | Teamlet Workroom | 3D314 | | 1/31/2014 | | PRMF301 | PRINTER, MULTI-FUNCTION | 2 | VV | | PRMF301 & COPI300 LISTED ON SAME CUT SHEET WITH ONLY ONE XEROX MODEL CALLED OUT - SIZE DOES NOT WORK IN MOST PRMF301 LOCATIONS | 1 | |
| 1885 | Women's Health | SL002 | 1 | Teamlet Workroom | 3D314 | | | | REWA300 | RECEPTACLE, WASTE, OFFICE, 28 QT | 12 | VV | No | | 4 | 0 |
| 1886 | Women's Health | SL002 | 1 | Teamlet Workroom | 3D314 | | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 24 | VV | F | | 8 | |
| 1887 | Women's Health | SL002 | 1 | Teamlet Workroom | 3D314 | | | | FURN240 | WORKSTATION, 2'-0" X 4'-0" | 24 | VV | F | | 2 | 0 |
| 1888 | Women's Health | SL002 | 1 | Teamlet Workroom | 3D314 | | 2/20/2014 | | CLWA801 | CLOCK | 2 | VV | | | 1 | |
| 1889 | Women's Health | | 1 | Alcove, Omnicell | | | | | | | | | | | | |
| 1890 | Women's Health | | 1 | Alcove, Omnicell | 3A312 | | 1/31/2014 | 2/20/2014 | SYME302 | OMNIRX THREE CELL / SUPPLIER | 4 | VV | | NEED MODEL NUMBER | 4 | |
| 1891 | Women's Health | | 1 | Alcove, Omnicell | 3A312 | | | | SYME302A | INSTALLATION, SEISMIC RESTRAINT | 4 | VV | - | | 4 | |
| 1892 | Women's Health | | 1 | Alcove | | | | | | | | | | | | |
| 1893 | Women's Health | | 1 | Alcove | 3A313 | | 1/31/2014 | 2/20/2014 | SYME302 | OMNIRX THREE CELL / SUPPLIER | 2 | VV | | NEED MODEL NUMBER | 2 | |
| 1894 | Women's Health | | 1 | Alcove | 3A313 | | | | SYME302A | INSTALLATION, SEISMIC RESTRAINT | 2 | VV | - | | 2 | |
| 1895 | Women's Health | | 1 | Alcove | 3A313 | | 1/31/2014 | | PRMF301 | PRINTER, MULTI-FUNCTION | 2 | VV | | PRMF301 & COPI300 LISTED ON SAME CUT SHEET WITH ONLY ONE XEROX MODEL CALLED OUT - SIZE DOES NOT WORK IN MOST PRMF301 LOCATIONS | 2 | 1 |
| 1896 | Women's Health | | 1 | Print | | | | | | | | | | | | 1 |
| 1897 | Women's Health | | 1 | Print | 3A311 | | 1/31/2014 | | PRMF301 | PRINTER, MULTI-FUNCTION | 2 | VV | | PRMF301 & COPI300 LISTED ON SAME CUT SHEET WITH ONLY ONE XEROX MODEL CALLED OUT - SIZE DOES NOT WORK IN MOST PRMF301 LOCATIONS | 2 | |
| 1898 | Women's Health | | 1 | Print | 3A311 | | | | FURN200 | WORKSTATION, 2'-6" X 6'-0" | 1 | VV | F | | | |
| 1899 | Women's Health | TLTU1 | 2 | Toilet, Patient | | | | | | | | | | | | |
| 1900 | Women's Health | TLTU1 | 2 | Toilet, Patient | 3A708, 3B709 | | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | | 2 | 0 |
| 1901 | Women's Health | USCL1 | 1 | Soiled Room | | | | | | | | | | | | |
| 1902 | Women's Health | USCL1 | 1 | Soiled Room | 3B706 | | | | CASO300 | CART, SOILED LINEN | 1 | VV | NO | | 1 | 0 |
| 1903 | Women's Health | USCL1 | 1 | Soiled Room | 3B706 | | | | CACS300 | CART, COLLECTION, SPD | 1 | VV | NO | | 1 | |
| 1904 | Women's Health | USCL1 | 1 | Soiled Room | 3B706 | | | | CAUT300 | CART, UTILITY | 1 | VV | NO | | 1 | 0 |
| 1905 | Women's Health | USCL1 | 1 | Soiled Room | 3B706 | | | | CONT300 | CONTAINER, BRUTE 32 GAL. | 1 | VV | No | | 1 | 0 |
| 1906 | Women's Health | USCL1 | 1 | Soiled Room | 3B706 | | | | CONT300A | FLAT TOP FOR BRUTE, 32 GAL | 1 | VV | - | | 1 | 0 |
| 1907 | Women's Health | USCL1 | 1 | Soiled Room | 3B706 | | | | CONT300B | DOLLY FOR BRUTE, 32 GAL | 1 | VV | - | | 1 | |
| 1908 | Women's Health | USCL1 | 1 | Soiled Room | 3B706 | | 2/20/2014 | | COSH321 | CONTAINER, SHARPS, 2 GALLON | 1 | VC | | TWO MODELS LISTED, PLEASE CONFIRM WE ARE USING 8509SA (W/O GLOVE BOX) NEED PRODUCT WEIGHT | 1 | 0 |
| 1909 | Women's Health | USCL1 | 1 | Soiled Room | 3B706 | | 2/20/2014 | | DIGL300 | DISPENSER, GLOVE, 3 BOX | 1 | VC | | | 1 | 0 |
| 1910 | Women's Health | USCL1 | 1 | Soiled Room | 3B706 | | | | REWB307 | RECEPTACLE, WASTE, BIOHAZARD, 44 GAL | 1 | VV | No | | 1 | |
| 1911 | Women's Health | USCL1 | 1 | Soiled Room | 3B706 | | | | REWB307A | RECEPTACLE LID | 1 | VV | No | | 1 | |
| 1912 | Women's Health | TLTU1 | 1 | Toilet, Staff | | | | | | | | | | | | |
| 1913 | Women's Health | TLTU1 | 1 | Toilet, Staff | 3A309 | | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL | 1 | VV | No | | 1 | |
| 1914 | Women's Health | WRCO1 | 1 | Waiting Area (W) | | | | | | | | | | | | |
| 1915 | Women's Health | WRCO1 | 1 | Waiting Area (W) | 3D402 | | | | REWA320 | RECEPTACLE, WASTE, OFFICE, 28 QT, PUBLIC ZONE | 9 | VV | No | | 6 | |
| 1916 | Women's Health | WRCO1 | 1 | Waiting Area (W) | 3D402 | | | | TELE320 | TELEVISION, FLAT PANEL, 52" LCD | 4 | VV | | WE RECEIVED ONE CUT SHEET WITH TWO EQUIPMENT NUMBERS AND ONLY ONE MODEL INDICATED - ARE THEY TO BE THE SAME SIZE? | 3 | 0 |
| 1917 | Women's Health | WRCO1 | 1 | Waiting Area (W) | 3D402 | | | | FURN150 | CHAIR, WAITING ROOM | 21 | VV | F | | 22 | |
| 1918 | Women's Health | WRCO1 | 1 | Waiting Area (W) | 3D402 | | | | FURN142 | CHAIR, BARIATRIC / LOVE SEAT | 3 | VV | F | | 3 | |
| 1919 | Women's Health | WRCO1 | 1 | Waiting Area (W) | 3D402 | | | | FURN400 | TABLE, SIDE | 5 | VV | F | | 5 | |
| 1920 | Women's Health | | 1 | Children Play Area | | | | | | | | | | | | |
| 1921 | Women's Health | | 1 | Children Play Area | 3D403 | | | | FURN450 | TABLE, KID'S PLAY | 2 | VV | F | | 2 | |
| 1922 | Women's Health | | 1 | Children Play Area | 3D403 | | | | FURN160 | CHAIR, KID'S | 10 | VV | F | | 10 | 0 |
| 1923 | Mental Health | | | | | | | | | | | | | | | |
| 1924 | Mental Health | OPHM1 | 2 | Group Therapy Room | | | | | | | | | | | | 0 |

EQUIPMENT GUIDE LIST (Excludes Schedule B Items)

Updated May 6, 2014 - Gold cells indicate product information has not been received by design team

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/Installation | Architectural Impact | Item Description & Notes | Total Qty | Coordination Priority |
|--|---|--------------|----------|--------------------|--------------|---------------------|--------------------|-------------------|-------------------------------------|--------------|--------------------------|----------------------|---|-----------|-----------------------|
| 1925 | Mental Health | OPHM1 | 2 | Group Therapy Room | 2G701, 2G702 | | | CACC300 | SECURITY CAMERA | 2 | VV | | **NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN** | 4 | |
| 1926 | Mental Health | OPHM1 | 2 | Group Therapy Room | 2G701, 2G702 | 3/7/2014 | | PRLC300 | PROJECTOR, LCD, DIGITAL | 1 | VV | | | 2 | |
| 1927 | Mental Health | OPHM1 | 2 | Group Therapy Room | 2G701, 2G702 | 2/20/2014 | | SCPR300 | SCREEN, PROJECTOR | 1 | VV | | CEILING OR WALL MOUNTED? NEED POWER REQUIREMENTS | 2 | |
| 1928 | Mental Health | OPHM1 | 2 | Group Therapy Room | 2G701, 2G702 | | | CACO301 | CART, COMPUTER, POWERED | 1 | | | | 1 | |
| 1928 | Mental Health | OPHM1 | 2 | Group Therapy Room | 2G701, 2G702 | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | |
| 1928 | Mental Health | OPHM1 | 2 | Group Therapy Room | 2G701, 2G702 | 2/20/2014 | | TELE312 | TELEVISION, FLAT PANEL, 52" LCD | 1 | VV | | WE RECEIVED ONE CUT SHEET WITH TWO EQUIPMENT NUMBERS AND ONLY ONE MODEL INDICATED - ARE THEY TO BE THE SAME SIZE? | 2 | |
| 1929 | Mental Health | OPHM1 | 2 | Group Therapy Room | 2G701, 2G702 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 25 | VV | F | | 46 | |
| 1930 | Mental Health | OPHM1 | 1 | Group Therapy Room | 2G706 | | | CACC300 | SECURITY CAMERA | 2 | VV | | **NO INFORMATION AVAILABLE FROM VA TO COMPLETE DESIGN** | 2 | |
| 1931 | Mental Health | OPHM1 | 1 | Group Therapy Room | 2G706 | 3/7/2014 | | PRLC300 | PROJECTOR, LCD, DIGITAL | 1 | VV | | | 1 | |
| 1932 | Mental Health | OPHM1 | 1 | Group Therapy Room | 2G706 | 2/20/2014 | | SCPR300 | SCREEN, PROJECTOR | 1 | VV | | CEILING OR WALL MOUNTED? NEED POWER REQUIREMENTS | 1 | |
| 1933 | Mental Health | OPHM1 | 1 | Group Therapy Room | 2G706 | | | CACO301 | CART, COMPUTER, POWERED | 1 | | | | 1 | |
| 1934 | Mental Health | OPHM1 | 1 | Group Therapy Room | 2G706 | 2/20/2014 | | COPE300 | COMPUTER, PERSONAL/WORKSTATION | 1 | VV | | WAITING ON MORE INFORMATION, MAY BE MULTIPLE TYPES REQUIRING MULTIPLE NUMBERS | 1 | |
| 1934 | Mental Health | OPHM1 | 1 | Group Therapy Room | 2G706 | 2/20/2014 | | TELE312 | TELEVISION, FLAT PANEL, 52" LCD | 1 | VV | | WE RECEIVED ONE CUT SHEET WITH TWO EQUIPMENT NUMBERS AND ONLY ONE MODEL INDICATED - ARE THEY TO BE THE SAME SIZE? | 1 | |
| 1935 | Mental Health | OPHM1 | 1 | Group Therapy Room | 2G706 | | | FURN100 | CHAIR, OFFICE, TASK CHAIR WITH ARMS | 19 | VV | F | | 19 | |
| 1936 | Mental Health | TLTU1 | 1 | Toilet, Staff | | | | | | | | | | | |
| 1937 | Mental Health | TLTU1 | 1 | Toilet, Staff | 2G704 | | | REWA312 | RECEPTACLE, WASTE, LARGE, 18 GAL. | 1 | VV | No | | 1 | |
| | ITEM NOT CURRENTLY LISTED ON SCHEDULE F OR REPRESENTED ON FLOOR PLANS | | | | | 2/20/2014 | | BODE310 / BODE320 | SMART BOARD | | | | WHERE IS THIS LOCATED? | | |
| | ITEM NOT CURRENTLY LISTED ON SCHEDULE F OR REPRESENTED ON FLOOR PLANS | | | | | 2/20/2014 | | LIEX304 | LED EXAM LIGHT | | | | WHERE IS THIS LOCATED? | | |
| | ITEM NOT CURRENTLY LISTED ON SCHEDULE F OR REPRESENTED ON FLOOR PLANS | | | | | 2/20/2014 | | OVM1320 | MICROWAVE | | | | WHERE IS THIS LOCATED? | | |
| | ITEM NOT CURRENTLY LISTED ON SCHEDULE F OR REPRESENTED ON FLOOR PLANS | | | | | 2/20/2014 | | REDO310 | REFRIGERATOR - 2 DOOR | | | | WHERE IS THIS LOCATED? | | |
| | ITEM NOT CURRENTLY LISTED ON SCHEDULE F OR REPRESENTED ON FLOOR PLANS | | | | | 2/20/2014 | | REUC310 | UNDERCOUNTER REFRIGERATOR | | | | WHERE IS THIS LOCATED? | | |
| | ITEM NOT CURRENTLY LISTED ON SCHEDULE F OR REPRESENTED ON FLOOR PLANS | | | | | 2/20/2014 | | REUC320 | UNDERCOUNTER REFRIGERATOR | | | | WHERE IS THIS LOCATED? | | |
| | ITEM NOT CURRENTLY LISTED ON SCHEDULE F OR REPRESENTED ON FLOOR PLANS | | | | | 2/20/2014 | | SCPR310 | PROJECTOR SCREEN | | | | NOT CURRENTLY LISTED ON SCHEDULE F OR LOCATED IN THE DRAWINGS, BUT WE HAVE LARGE SCREENS IN THE THIRD FLOOR CONFERENCE ROOMS THAT HAVE NOT BEEN ASSIGNED EQUIPMENT NUMBERS - ARE THESE CUT SHEETS DESCRIBING THOSE SCREENS? | | |
| | ITEM NOT CURRENTLY LISTED ON SCHEDULE F OR REPRESENTED ON FLOOR PLANS | | | | | 2/20/2014 | | SCWC300 | WHEELCHAIR SCALE | | | | NEED PRODUCT WEIGHT, POWER & DATA REQUIREMENTS | | |

| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | | | | | | | | | | | | | |
|--|-----------|--------------|----------|--------------|------------|---------------------|--------------------|------------------|----------------------|--------------|--------------------------|----------------------|--|
| Updated May 6, 2014 - Gold cells indicate product information has not been received by design team | | | | | | | | | | | | | |
| EQUIPMENT GUIDE LIST (Excludes Schedule B Items) | Room Code | Qty of Rooms | Function | Room Numbers | JSN Number | Cut Sheets Received | Cut Sheets Updated | Equipment Symbol | Item Name | Qty per Room | Acquisition/Installation | Architectural Impact | Item Description & Notes |
| | | | | | | | | | | | | | |
| ITEM NOT CURRENTLY LISTED ON SCHEDULE F OR REPRESENTED ON FLOOR PLANS | | | | | | 2/20/2014 | | SKBL303 | ? | | | | NUMBER LISTED ON PHLEBOTOMY WORKSTATION CUT SHEET, BUT IT IS NOT CURRENTLY ON SCHEDULE F OR LOCATED ON DRAWINGS, AND NOT DESCRIBED BUT THE CUT SHEET - WHAT / WHERE IS THIS? |
| ITEM NOT CURRENTLY LISTED ON SCHEDULE F OR REPRESENTED ON FLOOR PLANS | | | | | | 2/20/2014 | | TAEX305 | PEDIATRIC EXAM TABLE | | | | SHOULD THIS TABLE REPLACE ALL EXAM TABLES IN PEDIATRICS DEPT? ALSO, IT IS THE SAME MODEL BEPE310, SHOULD TAEX305 REPLACE THE BEPE310 EQUIPMENT NUMBER? |
| END OF LIST | | | | | | | | | | | | | |
| UNLISTED EQUIPMENT | | | | | | | | | | | | | |

Architectural impact:
 (Blank) = Yes or Unknown
 F = Furniture item
 No = No Arch. Impact
 (-) = Part of another equipment item